AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Gas Appliances
APM Object	CT.HVAC.GASAPPLIANCE
APM Description	Gas-powered appliances and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.GH - GAS	**Related CT Areas:**	CT.SAFE.FLAMGASDETECT - CT.HVAC.GASDET		

Scope

Any site with gas appliances, such as kitchen equipment (e.g. gas stoves). This standard does not include boilers or Combined Heat and Power Stations which are covered under standards CT.HVAC.BOILERS and CT.HVAC.COMBINEDHP respectively.
Gas installations and pipework are covered in standard CT.HVAC.GASINSTALL.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas appliances.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance logbook	PM					EVID		
All		At least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions.	Examination of safe operation, physical integrity and performance of all appliances, connections and associated infrastructure (e.g. flues) to ensure safe operation, examine physical condition and ensure correct performance. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use, Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Inspection records, report or certificate. Risk assessment	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Decree No. 85/1978 Coll., Decree No.21/1979 Coll., ČSN 69 0012, ČSN EN 12 186	Third party. Specialized technician of gas equipment.	Regular maintenance in accordance with the manufacturer's recommendations. Inspections of appliances and valves at least every 12 months.

DE	BetrSichV Anhang 3 (zu § 14 Abs. 4) Abschnitt 2 Flüssiggasanlagen DGUV Regel 110-003 - Branche Küchenbetriebe DVGW G 600 DVGW-TRGI 2018 - Technische Regel für Gasinstallationen Arbeitsstättenverordnung (ArbStättV) Niederdruckanschlussverordnung (NDAV) DVGW G 495 - Gasanlagen – Betrieb und Instandhaltung DVGW-Arbeitsblatt G 631 - Installation von gewerblichen Gasgeräten in Anlagen für Bäckereien und Konditoreien, Fleischereien, Gastronomie und Küche, Räuchereien, Reifung, Trocknung sowie Wäschereien	Competent Person (befähigte Person) according to DGUV 110-003 VIU/DVGW approved company.	Inspections to be carried out regularly, at least every 2 years for mobile gas installations and every 4 years for fixed gas installations. Visual inspection at least every 12 months.
ES	RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11. UNE 60670 on gas appliances	Accredited company, gas installers.	Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years.
FR	No additional requirements Observe local site permit	N/A	No additional requirements
IT	Legislative Decree 9/04/2008 n.81 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) Decree 22/01/2008 n. 37 Decree 08/11/2019 UNI EN 1749:2020 (Gas appliance classification) UNI EN 1729:2015 (Gas installations) UNI EN 203:2014 (Gas kitchen equipment) Regulation 2016/426/EU DM 37/2008 ISO 23551-4:2018 (Valves)	Competent person, considered best practice to outsource to specialist	Maintenance as per manufacturer instructions. Inspections every 5 years (operation) and 10 years (integrity). Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065) Regulation of the Minister of Economy of 26 April 2013 on the technical conditions to be met by gas networks and their location (Journal of Laws 2016, item 640)	Qualified or competent person.	Inspections of appliances and shut-off valves in accordance with manufacturer's instruction, but at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Engineer on the RGII.	Regular maintenance in accordance with manufacturer's recommendations. Inspections of appliances and valves at least every 12 months
SK	Act No. 314/2001 Coll. on fire protection Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections	Qualified and certified person.	Periodic inspections in accordance with manufacturer recommendation and fire protection/prevention rules. Frequency of professional inspection: 12 months or less frequently, depending on the type of gas appliance. Frequency of Professional test: 3 years or less frequently, depending on the type of gas appliance.
UK	The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk) Safety in the installation and use of gas systems and appliances (hse.gov.uk) Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004	Competent engineer on the Gas Safe Register.	Routine maintenance in accordance with manufacturer's recommendations. Inspections of appliance and valves every 12 months.