# AMAZON BASE BUILDING COMPLIANCE STANDARD

| | |
|---|---|
| **Task Title** | Gas Installations |
| **APM Object** | CT.HVAC.GASINSTALL |
| **APM Description** | Gas infrastructure, pipework and supply. |
| **General tasks always required** | Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc.<br>Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required<br>Add notes for each observation and create a FWO if necessary to eliminate defects<br>Use appropriate tools, chemicals and industry standard practices (RME policy permitting)<br>Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE)<br>To suggest improvements please raise a SIM or contact document authors<br>Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA)<br>SIM - Link to SIM template |

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| **Last Update: (Version)** | ago-23 | **Last Update Change Detail:** | Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft. | **Activities may be covered by No-Go restrictions:** | Yes | **Special Certification Required:** | **Delivered By:** |
| **Evidenced part or full by PM:** | Yes | **Related BBM PM:** | GAS - HVAC.RTU - HVAC.CU - HVAC.CHILL - HVAC.GH - HVAC.BLR - HVAC.HTR | **Related CT Areas:** | CT.SAFE.FLAMGASDETECT - CT.HVAC.GASAPPLIANCE - CT.HVAC.ODS - CT.HVAC.FGAS - CT.HVAC.GASDET | | |

## Scope

Any site with a gas supply and installations, including gas main supply and, or LPG tanks.
The standard excludes gas cylinders. It is also expected that where a gas main supply is incoming, the utility provider is responsible for the maintenance of that infrastructure.
Where agreed in writing, it is expected that the maintenance of LPG tanks would be the responsibility of the provider.

## Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

## Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

## Key to Abbreviations

The key to the below document is as follows:
**CT** - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
**CT*** - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
**(CT)** - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
**PM** - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
**(PM)** - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
**EVID** - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
**EVID*** - Conditional requirement to upload evidence at the interval provided
**N A R** - No Additional Requirement

## Required Tasks

| Region | Task Index | Task Frequency | Task Requirements | Qualification of Inspector | Records Required | PM | Weekly | Monthly | 3 Monthly | 6 Monthly | 12 Monthly | 24 Monthly | Additional |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| All | 1 | In accordance with manufacturer's instructions and recommendations. | Routine maintenance of all gas installations and storage (where applicable). | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | | | | | | CT | | |
| All | 2 | In line with written maintenance strategy and risk assessment, but at least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions. | Examination of safe operation, physical integrity and performance of all appliances, gas installations, labelling, telemetry, control valves and infrastructure to ensure safe operation, examine physical condition and ensure correct performance. This includes LPG supply tank (where not owned by the company that supplies the gas). | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | PM | | | | | EVID | | |
| All | 3 | In line with written maintenance strategy and risk assessment, but at least every 12 months, but more frequent inspections might be required based on use and site-specific environmental conditions. | If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue. | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | | | | | | CT | | |
| All | 4 | Slam shut-off valves to be inspected every 12 months. | Regular checks of slam shut valves (if present) to ensure correct operation. | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | | | | | | CT | | |
| All | 5 | In accordance with manufacturer's instructions and recommendations. | Specific components - Identify where manufacturer has stated an expiration date for any component – a PM task should be created for replacement. | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | | | | | | CT | | |

| | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| All | 6 | In line with written maintenance strategy and risk assessment with minimum of annual visual inspection and leak/pressure testing every 2 years (unless reason to suspect damage or leak). | Above ground pipework including supports valves, coupling, cathodic protection etc (visual inspection, leak testing in line with written maintenance strategy). | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | (PM) | | | | | (EVID) | | |
| All | 7 | In line with written maintenance strategy and risk assessment. Dependent on pipework material (plastic or metal), depth, land use above and ground conditions.<br>Suggest minimum of:<br>-Excavation and visual inspection | Buried gas supply pipework including valves, coupling, cathodic protection, steel risers etc (periodic excavation, visual inspection, leak testing). | Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.) | Inspection records, examination and leak checking report or certificate.<br>Risk assessment<br>Maintenance strategy | | | | | | | CT | 5Y<br>12Y<br>CT |

| Related Regional Legislation | | | |
|---|---|---|---|
| **Region** | **Relevant legislation** | **Vendor Certification** | **Statutory requirement** |
| CZ | Decree No. 85/1978 Coll.,<br>Decree No.21/1979 Coll.,<br>ČSN 69 0012,<br>ČSN EN 12 186 | Third party. Specialised technician of gas equipment. | 12 months inspection (routine checks), 36 months operational inspection. 4 months for shut-off valves. |
| DE | BetrSichV Anhang 3 (zu § 14 Abs. 4) Abschnitt 2 Flüssiggasanlagen<br>DVGW G 600 DVGW-TRGI 2018 - Technische Regel für Gasinstallationen<br>Arbeitsstättenverordnung (ArbStättV)<br>Niederdruckanschlussverordnung (NDAV)<br>DVGW G 495 - Gasanlagen – Betrieb und Instandhaltung | Competent Person (befahigte Person) according to DGUV 110-003.<br>VIU/DVGW approved company. | Inspections to be carried out before first use (according to DVGW G 469) and then regularly, at least every 2 years for mobile gas installations and every 4 years for fixed gas installations.<br>Visual inspection at least every 12 months of any pipe systems on plaster, and for piping systems with operating pressures up to 100 mbar, a serviceability test every 12 years. |
| ES | RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11. | Accredited company, gas installers. | Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years. |
| FR | No additional requirements, observe local site permit<br>Best practice: The NF EN 15001-2 standard defines the conditions for the installation of gas pipes in industrial establishments | N/A | No additional requirements |
| IT | Legislative Decree 9/04/2008 n.81<br>DM 11/04/2011<br>DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008)<br>Decree 04/03/2014<br>Legislative Decree 11/02/1998 n.32<br>UNI EN 12186:2014 (Functional requirements)<br>UNI EN 12327:2012 (Functional requirements)<br>UNI EN 15399:2019 (Safety requirements)<br>UNI 9165:2020 (Maintenance)<br>UNI 9860:2020 (Maintenance) | Competent and accredited person, considered best practice to outsource to specialist. | Maintenance as per manufacturer instructions. Inspections every 5 years (operation) and 10 years (integrity).<br>Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used. |
| PL | Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333)<br>Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)<br>Regulation of the Minister of Economy of 28 December 2009 on occupational health and safety in the construction and operation of gas networks and the commissioning of natural gas installations (Journal of Laws 2010, number 2, item 6)<br>Regulation of the Minister of Economy of April 26, 2013 on the technical conditions to be met by gas networks and their location (Journal of Laws 2016, item 640)<br>Regulation of Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) | Qualified or competent person. | Inspections of appliances and shut-off valves in accordance with manufacturer's instruction, but at least every 12 months. |
| ROI | S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) | Competent person. Engineer on the RGII. | Regular maintenance in accordance with manufacturer's recommendations. Inspections of appliances and valves at least every 12 months. |
| SK | Act No. 314/2001 Coll. on fire protection<br>Act No. 124/2006 Coll. on safety and health at work<br>Ordinance No. 121/2002 Coll. on fire prevention<br>Ordinance No. 401/2007 Coll. on the technical conditions and requirements for fire safety during installation and operation of fuel appliances, electro thermal appliances and central heating equipment, and the construction and use<br>Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. | Qualified and certified person | Inspections in accordance with manufacturer recommendation and fire protection/prevention rules.<br>Frequency of professional inspection: 6 months or less frequent, depending on the type of gas installation;<br>Frequency of Professional test: 3 years or less frequently, depending on the type of gas installation. |

| | | | |
|---|---|---|---|
| UK | The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk)<br>Safety in the installation and use of gas systems and appliances (hse.gov.uk)<br>Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004 | Competent engineer on the Gas Safe Register. | Routine maintenance in accordance with manufacturer's recommendations. Inspections in accordance with written maintenance strategy. |