AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Goods lift
APM Object	CT.LIFT.GOODS
APM Description	Goods lifts.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIFTS.GOODS	**Related CT Areas:**	Not Specified		

Scope

Any site which uses goods lifts to transfer loads in working environments (e.g. between different levels).
This only applies to lifts used to transport goods e.g. service lift, gantry cranes and heavy lifting equipment etc. For passenger lifts refer to Compliance Standard CT.LIFT.PASSENGER

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	- pipelaying tractors;	Competent person.	Maintenance records	PM					EVID		
All	2	Once assembled, before it is first used.	- mobile elevating work platforms.)	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records. Retain until employer ceases to use equipment.								ON off EVID
All	3	At least every 12 months. More frequent examinations might be conducted based on site specific risk assessment.	Regular thorough (technical) examination of safety-critical parts to ensure safe use. This includes lifting (e.g. ropes, chains) and non-lifting (e.g. electrical devices, safety gear, load detectors) parts of the equipment. If defects identified, prevent subsequent use through quarantine prior to repair or disposal and replacement - do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, reports or certificate. Retain until next report is made. Risk assessment Marking, e.g. inspection test sticker to be placed inside elevator/permit for use	(PM)					EVID		
CZ	4	Inspection every 6 months. Equipment testing every 6 years.	No additional requirements	Independent, accredited or authorised to undertake inspections.	Inspection records	(PM)					EVID		
FR	6	No additional requirements	No additional requirements	No additional requirements	Security register								NAR

IT	5	Thorough inspection of safety critical lifting components every 3 months (visual testing and cleaning).	No additional requirements	Independent, accredited or authorised to undertake inspections.	Inspection records. CE Declaration of Conformity.	(PM)					EVID		
ROI	7	Regular inspections every 6 months.	No additional requirements	No additional requirements	Inspection and maintenance records	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 Government Regulation No. 378/2001 Coll., EN 81-1 EN 81-2 ČSN 274007 – ČSN 274002 EN 81 - 80	Competent person. Lift equipment technician.	Inspections carried out every 6 months. Testing undertaken every 6 years.
DE	BetrSichV – Betriebsicherheitsverordnung, §3, §15 & §16 and Annex 2 Section 2 Technische Regeln für Betriebssicherheit: TRBS 1201 Teil 4 - Prüfung von überwachungsbedürftigen Anlagen - Prüfung von Aufzugsanlagen TRBS 3121 - Betrieb von Aufzugsanlagen	Accredited inspection bodies (zugelassenen Überwachungsstellen) according to BetrSichV	Inspection before first use, after changes subject to inception and recurrent inspections. Recurrent inspections include main inspection (every 2 years) and intermediate inspection (between the main inspection) PPM in place.
ES	RD 2291/1985, approving regulation for lifting machines and their maintenance. RD 1314/1997, pronouncing about the applicable regulation related to European Parliament Directive 95/16/CE, aboutlifts. RD 88/2013, approving the Complementary Technical Instruction AEM 1 "Lifts". RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD 203/2016, establishing essential safety requirements for the commercialisation of lifts and their security components.	Competent person.	Maintenance according to manufacturer's instructions. Inspection frequency depends on operating conditions.
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Inspections at least every 12 months.
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 CEI EN 60947-5-1:2019 (Control circuits) CEI EN 60529:2009 (Protection degrees of enclosures) UNI EN 12159:2013 (Constructions lift) UNI EN 81-20:2020 (Safety requirements for the construction and installation of lifts) UNI EN 294:1993 (Safety requirements) UNI EN 953:2009 (Safety requirements - General requirements for the design and construction of fixed and mobile shelters) UNI EN 349:2008 (Safety requirements- Minimum spaces to avoid crushing body parts)	Competent person, outsource to specialist company.	Regular maintenance as per manufacturer's instructions. Inspection of lifting components (slings, ropes) every 3 months. Periodic inspection every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811) Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	UDT technical inspection, government body.	Inspections at least every 12 months
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment	Competent person, outsource to specialist company.	Professional inspections of goods lifts to be conducted at least every 6 months. Professional examination at least every 6 years. Repeated official test by Technical Inspection (or any other authorized legal entity) every 10 years.

UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before first use and every 12 months. PPM must be in place.