AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Passenger lifts
APM Object	CT.LIFT.PASSENGER
APM Description	Passenger (people)carrying lifts.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Passenger lifts	**Related CT Areas:**	Not Specified		

Scope

Any site with passenger carrying lifts.
Goods lifts are covered under Compliance Standard CT.LIFT.GOODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Planned regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent person.	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment	PM					EVID		
All	2	Once assembled, before it is first used.	Installation inspection – upon first assembly	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment								One Time
All	3	Inspection frequency based on risk assessment, but at least every 6 months.	Professional thorough inspection of safety-critical parts to ensure safe use. This includes lifting parts (e.g. chains, slings) and non-lifting parts (electrical devices, brakes, lights, detectors) of the lift. If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Register of lifting equipment, inspection and maintenance records, report or certificates. Risk assessment	PM					EVID		
CZ	5	Internal checks on passenger lifts are carried out every 14 days. Professional inspections of passenger carrying lifts to be conducted at least every 4 months (if no public access). Every 3 years - professional	Check the "Protokol o urceni vnejsich vlivu", which defines the environmental conditions, use and maintenance requirements of electrical equipment.	No additional requirements	"Protokol o urceni vnejsich vlivů" Inspection records, report or certificates. Risk assessment	(PM)					EVID		4Mo CT 3Yr CT 6Yr CT 9YR CT
FR	8	6 weeks	Inspections as per [1].	Independent, accredited or authorised to undertake the inspection and maintenance or competent, trained person.	Maintenance logbook and Security register Inspection report	(PM)					EVID		

FR	9	6 months	Inspections as per [3].: Brakes, cables or chain, anti-drift device	Accredited company	Maintenance logbook and Security register Inspection report	(PM)				CT	EVID		
FR	10	12 months	Inspections as per [3].: bowl, cab roof, machinery, pulley, speed limiter, parachute, means of protection against uncontrolled movements, safety out-of-travel devices, hand pump, manually operated drop valve	Accredited company	Maintenance logbook and Security register Inspection report	(PM)					CT EVID		
FR	11	5 years	Technical exam on full equipment	Accredited company	Maintenance logbook and Security register Inspection report								5 Yr CT
IT	12	No additional requirements	No additional requirements.	No additional requirements	CE Declaration of Conformity.								NAR
PL	6	Technical maintenance of elevators to be conducted at least every month.	Inspections as per [3].	No additional requirements	Book of revision and maintenance logbook.	(PM)					EVID		
SK	7	Internal inspections passenger carrying lifts to be conducted weekly. Professional inspections of passenger carrying lifts to be conducted at least every 3 months. Professional examination at least	Inspections as per [3].	No additional requirements	Inspection records, report or certificates. Risk assessment	(PM)					EVID		
UK	4	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme.	(PM)							

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 ČSN EN 81-1 ČSN EN 81-2 ČSN EN 274007 ČSN EN 274002 ČSN EN 81 – 80	Competent person, outsource to specialist company.	Maintenance every week. Professional inspection every 4 months (if no public access), and examination every 3 years. Official test every 6 years (after lift has been installed for 9 years).
DE	BetrSichV – Betriebssicherheitsverordnung, §3, §15 & §16 and Annex 2 Section 2 Technische Regeln für Betriebssicherheit: TRBS 1201 Teil 4 - Prüfung von überwachungsbedürftigen Anlagen - Prüfung von Aufzugsanlagen TRBS 3121 - Betrieb von Aufzugsanlagen	Accredited inspection bodies (zugelassener Überwachungsstelle – ZÜS) according to BetrSichV	Before its first use, after Recommissioning, and main periodic inspections (including electrical parts) at least every 2 years. Intermediate inspections must be carried out in the time between the main inspections. PPM in place.
ES	RD 2291/1985, por el que se aprueba el Reglamento de Aparatos de Elevación y Manutención de los mismos. RD 1314/1997, por el que se dictan las disposiciones de aplicación de la Directiva del Parlamento Europeo y del Consejo 95/16/CE, sobre ascensores. RD 57/2005, por el que se establecen prescripciones para el incremento de la seguridad del parque de ascensores existente. RD 1644/2008, por el que se establecen las normas para la comercialización y puesta en servicio de las máquinas. RD 88/2013, por el que se aprueba la Instrucción Técnica Complementaria AEM 1 "Ascensores". RD 203/2016, por el que se establecen los requisitos esenciales de seguridad para la comercialización	Accredited company by ENAC (Entidad Nacional de Acreditación)	Maintenance of all lifting equipment at least monthly. Inspections carried out: - every 24 months in industries and publicly used buildings. - every 48 months in dwelling buildings withs more than 20 apartments or more than 4 floors. - every 72 months in other cases.
FR	Ministerial Order 18 November 2004 to lifting equipment maintenance "Arrêté du 18 novembre 2004 relatif à l'entretine des installations d'ascenseurs" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000254219/ Construction Code Article R125-1 relating to Lifting equipment periodic technical exam "Code de la construction article R125-2-4 relatif à l'entretien at au contrôle technique des ascenseurs" https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000032499015/ Labour Code Art. R. 4323-22 à R. 4323-28 relating to the periodic verification of work equipment. "Code du travail Article R4323-22 à R4323-28 relatifs à la vérification périodique des équipements de travail" https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489757/#L	Qualified person Accredited company	Maintenance of all lifting equipment at least every 6 weeks Inspections at least every 6 months and 12 months. Technical exam every 5 years.
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 Presidential Decree of 10 January 2017, n. 23 - Regulation laying down the provisions on the implementation of Directive 2014/33/EU concerning lifts UNI 10411:2014 (Modifications to electric lifts not in conformity with Directive 95/16/EC) UNI EN 81-80:2019 (Safety requirements - methodology for improving the safety of existing lifts) UNI EN 14502-1:2010 (Cradles) EC 1-2010 UNI EN 14502-2:2008 (People lifting equipment) UNI EN 81-43:2009 (Lifters for cranes) UNI EN 81-50:2020 (Safety requirements - Checks and tests)	Competent person, outsource to specialist company.	Regular maintenance according to manufacturer's instructions. Inspection every 24 months (verification). Inspection of lifting components (ropes, slings) every 3 months.

PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811)	UDT technical inspection, government body.	Maintenance at least every month. Inspections at least every 12 months. It includes escalators.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 4002: Lifts. Installation, testing and operation of electric lifts	Competent person, outsource to specialist company.	Weekly check recommended by STN 27 4002. Professional inspection every 3 months, and professional examination every 3 years. Repeated official test every 6 years.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk)	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before first use and at least every 6 months. PPM in place. Escalators must be thoroughly inspected every 6 months. Written Scheme of Examination required for each asset.