AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Conveyors and machine guarding and e-stops
APM Object	CT.SAFE.CONVGUARDING
APM Description	Conveyors and machine guarding
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with conveyors and other machinery are required to ensure they are used safely, which may include the provision of guarding and/or emergency stops and interlocks.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of all guarding, including hinges and slides, replacement of damaged or worn parts, lubrication, etc.	Competent person. Can be internally or externally sourced	Maintenance logbook						CT		
All	2	Based on risk assessment, but at least annually (it is assumed supervisors will check for unauthorised modifications more frequently)	Regular inspection and servicing of all guarding to ensure correct operation, including damage, unauthorised modification, missing or damaged fasteners, etc. to avoid unsafe conditions for employees	Competent person. Can be internally or externally sourced	CE Marking/ CE declaration of conformity Risk assessment Inspection records, report or certificate						CT		
All	3	Based on risk assessment and manufacturer's instructions, but at least monthly	Regular inspection and maintenance of interlocks and emergency stops.	Competent person. Can be internally or externally sourced	CE Marking/ CE declaration of conformity Risk assessment Inspection records, report or certificate			CT					
CZ	4	Between 6 - 36 months	Inspection and maintenance of equipment (depending on type and environment)	Competent person.	Inspection records						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll. Decree No. 50/1978 Coll. ČSN 33 1600 ed.2.	Competent person, best practices for outsourcing to a specialist.	Inspection every 12 months. Inspection and maintenance of equipment (depending on type and environment) between 6 - 36 months
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 1203 - Befähigte Personen DGUV 2018-018 - Stetigförderer	Competent person (befähigte Person) according to TRBS 1203	Before initial commissioning and after any modifications or repairs. Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually. Additional intermediate inspection in accordance with the operating conditions. Regular inspection of emergency stops in line with risk assessment.
ES	Directive 2006/42 / EC of the European Parliament and of the Council of 17 May 2006 on machines. RD 1644/2008, of October 10, which establishes the rules for marketing and commissioning of the machines. RD 1215/1997, of July 18, establishing minimum security provisions and Health for the use by workers of work equipment. RD 1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	Labor Code Art. R4322-1 to R4322-3 relating to Maintaining compliance Code du travail article R4322-1 à 3 relatifs au maintien en état de conformité https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489696/#LEGIARTI000018531541	Qualified person	Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually
IT	Legislative Decree 9.04.2008 n° 81 Directive 2006/42/CE on machinery	Competent person.	Regular inspections and maintenance in accordance with manufacturer's instructions and risk assessment.
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228) Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Dz.U. 2008 nr 199 poz. 1228)	Qualified or competent person	Regular maintenance. Before initial commissioning and after any modifications or repairs. Periodic inspection of conveyors and machine guarding based on risk assessment, but at least annually. Regular inspections of emergency stops in accordance with manufacturer's instructions and risk assessment.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, trained to undertake the tasks	Regular maintenance. Frequent inspections of all guarding in line with risk assessment, but at least annually. Regular inspection and maintenance of e-stops and interlocks in line with risk assessment and manufacturer's instructions
SK	Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person	Electric installation of guardings: Annual inspection and testing Guardings: Annual inspection
UK	The Provision and Use of Work Equipment Regulations 1998 The Supply of Machinery (Safety) Regulations 2008 The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 PUWER White Paper ed1 v2.doc (machinesafety.co.uk) BS EN ISO 12100:2010 Safety of machinery. General principles for design. Risk assessment and risk reduction BS EN 953:1997+A1+2009 Safety of machinery. Guards. General requirements for the design and construction of fixed and movable guards *	Competent person, trained to undertake the tasks	Regular maintenance. Frequent inspections of all guarding in line with risk assessment, but at least annually. Regular inspection and maintenance of e-stops and interlocks in line with risk assessment and manufacturer's instructions, but at least monthly.