AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Drinking water stations
APM Object	CT.WATER.DRINKING
APM Description	Plumbed and free-standing drinking water points
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.DWDISP	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.ELEC.PAT		

Scope

Any site with either plumbed in drinking water fountains/dispensers and, or free standing water coolers. (e.g. Hydrachill, Water Logic, Niagara units).
It is assumed that routine cleaning of handles and spouts and emptying of any overflow device will be completed by the cleaning contractor.
Where units are on a hire arrangement, some services maybe fulfilled by an external contractor. A PPM task should still be raised.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least weekly	If a drinking station is plumbed into the cold water system, flush through water distribution dead legs to drain for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		
All		At least every 6 months	All drinking stations (free standing and plumbed) must be serviced and filters changed (lines and fittings should be sterilised and spouts descaled)	Competent person, can be externally (i.e. external provider/contractor) or internally sourced.	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		
All		At least every 12 months	Service and disinfect base exchange softeners	Competent person, usually sourced internally.	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	Act No. 544/2020 Coll. – Water Act Act No. 205/2020 Coll. - Public Health Protection Act Government Regulation No. 101/2005 Coll. - Regulation on more detailed requirements for workplaces and working environments. Nam. Government Regulation No. 378/2001 Coll. - Regulation laying down more detailed requirements for the safe operation and use of machinery, technical equipment, instruments and tools Decree no. 70/2018 Coll. - establishes the sanitary requirements for drinking water and hot water and the frequency and extent of inspection of drinking water	Competent person	Carry out checks every 12 months.
DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung VDI/BTGA/ZVSHK 6023 Blatt 2 - Hygiene in Trinkwasser-Installationen - Gefährdungsanalyse	Competent person	Water taps / extraction fittings: use daily if possible, at least every seven days. Maintenance of softening unit every 6 months. Maintenance of system separator and backflow preventer: maintenance and function check every 12 months.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption, and further modifications such as RD902/2018, of July 20. RD 865/2003, laying down the hygienic-sanitary criteria for the prevention and control of legionellosis. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Competent person. Cleaning and disinfection works must be carried out by authorised company according to RD830/2010	Cleaning, disinfection and sampling of equipment in line with risk assessment. At least once per year according to Appendix 3 of RD865/2003. Review of the state of conservation and cleanliness must be carried out every 3 months in tanks and monthly in a representative number, rotating throughout the year, of the terminal points (taps) of the inner drinking water net. At the end of the year all terminal points must have been reviewed.
FR	Labour Code article R4225-4 relating to the drink water provision https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/2008-05-01	Competent person	Best Practice: Annual inspection, cleaning, disinfection and sampling of equipment.
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31, Annex I UNI EN 918:2014(hot and cold water supply and distribution systems). UNI EN 806-5:2012 (operation and maintenance of installations inside buildings for the conveyance of water intended for human consumption)	Qualified person	Frequency of periodical check and inspection are not specified by Italian legislation. Regarding the plumbed drinking water points, inspections and maintenance in accordance with the risk assessment. Concerning the free-standing systems, inspection and maintenance in accordance with manufacturer's instructions, best practice is every 6 months.
PL	Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	Competent person	Carryout checks every 12 months. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in accordance with manufacturer's instructions or risk assessment. Service and disinfect base exchange softeners, in accordance with manufacturer's instructions risk assessment, Water supplied must be wholesome (i.e. free from contamination/pathogens
ROI	Safety, Health and Welfare at Work (General Application) Regulations 2007	Competent person	Regular flushing of sentinel outlets, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Service and disinfect base exchange softeners, in line with risk assessment, but at least annually. Regular cleaning and disinfection of component parts including filters. Frequency in line with risk assessment. Water supplied must be wholesome (i.e., free from contamination/pathogens)
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Regular control conducted by competent and qualified person Regular inspections conducted by competent person, best practice to outsource to specialist	Annual water quality control or control based at request from the regional public health office. Periodic inspection of technical equipment: Cleaning and maintenance of water facilities, areas, premises and facilities that are part of the drinking water distribution system or which may adversely affect the quality of drinking water.
UK	Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992	Competent person	Regular flushing of sentinel outlets, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Service and disinfect base exchange softeners, in line with risk assessment, but at least annually. Regular cleaning and disinfection of component parts including filters. Frequency in line with risk assessment. Water supplied must be wholesome (i.e. free from contamination/pathogens)