AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lead
APM Object	CT.WATER.LEAD
APM Description	Water supply - lead monitoring.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites are required under Health and Safety regulations to ensure their employees' health is maintained. As such, employers have the responsibility of ensuring their water supply is wholesome.
Water provided by the city/municipality/water company should not contain lead in excess of statutory levels. Responsibility for supply and distribution outside the facility boundary is not part of the scope of the standard.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Initial inspection at start of tenancy/purchase	Pipework survey to identify lead pipes in your water distribution network. This includes only those pipes within the boundary of the installation or those whose responsibility is the owner of the installation/building.	Competent person	Survey report								One Off EVID
All	2	Regular water sampling and laboratory testing in line with risk assessment, but at least annually.	If lead pipes are identified following, a water sampling and monitoring program must be in place to ensure employees are not exposed to lead levels above statutory levels	Competent person, laboratory analysis via accredited laboratory	Analysis results Risk assessment Sampling and monitoring programme						CT		
All	3	As programmed	Where lead pipes are identified a replacement programme should be scheduled and undertaken	Competent person	Project file showing replacement						DOC		
SK	4	Full analysis: 12 times per year Minimum analysis: 4 times per year	Inspection requirements are set up for water service provider.	No additional requirements	No additional requirements			CT*	CT*				

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act No. 258/2000 Coll.	Accredited company	Carry out regular analyses according to the scope of the legislation.
DE	Trinkwasserverordnung (TrinkwV)	Health department (Gesundheitsamt) or Accredited institutions (zugelassene Institute/Prüfstellen) Health Department or Specialist plumbing and heating companies (Gesundheitsamt / Fachbetriebe der Sanitär- und Heizungstechnik) for removal of pipes.	Monitoring water quality for lead presence, at least every three years, if piping is made of lead. Removal of lead pipes. If lead in drinking water exceeds the threshold value of 0.010 mg/l.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. RD 902/2018, which modifies RD 140/2003. RD 314/2016. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Outside piping systems: Local authorities. Private properties: owner, site manager. Lead sampling: authorised laboratories (ENAC).	Removal of lead pipes. Monitoring water quality for lead presence.
FR	Ministerail Order of 2010, January 21st relating to sanitary control analyses for water supplied by a distribution network https://cdnmedia.eurofins.com/european-west/media/1216/arr%C3%AAt%C3%A9-du-21-janvier-2010-relatif-au-contr%C3%B4le-sanitaire.pdf	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31 UNI EN 806-5:2012(maintenance)	Qualified personnel	Monitoring to be undertaken periodically. The periodicity is not set by Italian Legislation.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 27 April 2001 on Environmental Law (Journal of Laws 2020, item 1219) Act of 7 June 2001 on collective water supply and collective sewage disposal. (Journal of Laws 2020, item 2028) Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294)	Qualified or competent person (authorised under Construction Law)	Initial survey when handing over of building and installation.
ROI	Safety, Health and Welfare at Work Act 2005 (No. 10 of 2005) Safety S.I. No. 122/2014 - European Union (Drinking Water) Regulations 2014. (irishstatutebook.ie)	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead.
SK	Act No. 355/2007 Coll. on the protection, promotion and development of public health and on the amendment of certain laws Act No. 442/2002 Coll. on public water supply and public sewerage Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Competent and authorized person Water samples must be tested by accredited laboratory.	Non drinkable water: Annual sample analysis Drinkable water: before the first use of the system and based at specific requirements.
UK	The Water Supply (Water Quality) Regulations 2018 (legislation.gov.uk) The Water Supply (Water Quality) (Scotland) Regulations 2001 (legislation.gov.uk) The Water Supply (Water Quality) Regulations (Northern Ireland) 2017 (legislation.gov.uk)	Mainly managed by water supply companies.	Monitoring of water quality parameters, including lead