amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	BUILDING, BUILDING INTERIOR - 4
APM Object	BLDG.INT
APM EC	AMZ.BLDG.INT
BBM Handbook Title	Building Interior
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Dec-23	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	TBC	**Special Certificaion Required:**	TBC	**Delivered By:**	TBC	**OCB:**	BBM
Evidence for CT:	TBC	**Pricing template Position:**	4	**Related CT Areas:**	Not Identified	**Assets included in this PM:**	TECHNICAL ROOMS	**Schedule With:**	BLDG.STRUCTURE BLDG.MEZZANINE				

Description of System / Technology (According to BBM Handbook)

This system has been created only for the allocation of Standard PM's which will cover all: internal structures, ceilings and floors. The Building Interior system has been created to reduce the number of proactive WOs and administrative workload. This system is not to be used for reactive WO's
BLDG.STRUCTURE
BLDG.CEILINGS

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Technical Rooms	Check all technical rooms for alarms, leaks, unnecessarily stored equipment, correct functioning of safety equipment and obvious damage		SC								

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.
June 2024 - Moved tasks regarding with ceiling, floor and structure/walls to BLDG.STRUCTURE PM.