amazon rme

# AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

| | |
|---|---|
| **Task Title** | BUILDING, METAL DETECTORS - 14 |
| **APM Object** | BLDG.METALDET |
| **APM EC** | AMZ.BLDG.METALDET |
| **BBM Handbook Title** | Metal Detectors |
| **General tasks always required** | Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc.<br>Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required<br>Add notes for each observation and create a FWO if necessary to eliminate defects<br>Use appropriate tools, chemicals and industry standard practices (RME policy permitting)<br>Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure<br>These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed.<br>To suggest improvements please raise a SIM<br><br>SIM - Link to SIM template |

| | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| **Last Update: (Version)** | Jul-23 | **Geo Applied:** | Intl APM Instance | **F-Gas** | Not Identified | **Activies may be covered by No-Go restrictions:** | TBC | **Special Certificaion Required:** | TBC | **Delivered By:** | TBC | **OCB:** | BBM |
| **Evidence for CT:** | YES | **Pricing template Position:** | 14 | **Related CT Areas:** | Not Identified | | | **Assets included in this PM:** | METAL DETECTORS | **Schedule With:** | - | | |

## Description of System / Technology (According to BBM Handbook)

Metal Detectors

## Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

| Task Index | Component | Tasks | Tasks Nested for frequencies > weekly | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Daily | Weekly | Monthly | 3 Monthly | 6 Monthly | 12 Monthly | 24 Monthly | 36 Monthly | 48 Monthly | 60 Monthly |
| 1 | Documentation | Is the documentation of the equipment available & complete | | | | | | SC | | | | |
| 2 | Safety | Check the safety devices for correct function | | | | | | SC | | | | |
| 3 | Metal detector | Check of the metal detector for damage and corrosion | | | | | | SC | | | | |
| 4 | Metal detector | Carry out a functional test using the right type of material<br>Plan a calibration if required | | | | | | SC | | | | |
| 5 | Metal detector | Check for any signs of moisture at the unit and if gaskets are in correct order | | | | | | SC | | | | |
| 6 | Electrical components | Is the area properly illuminated | | | | | | SC | | | | |
| 7 | Electrical components | The cables are routed and fixed properly | | | | | | SC | | | | |
| 8 | Electrical components | Electrical terminations are secure | | | | | | SC | | | | |
| 9 | Functional cleaning | Carry out a functional cleaining of the metal detector unplugged using neutral detergant | | | | | | SC | | | | |
| 10 | Functional cleaning | Carry out a functional cleaining of the metal detector unplugged using neutral detergant | | | | | | SC | | | | |

## Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.