amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	BUILDING, ROOF AND ROOF DRAINAGE - 7
APM Object	BLDG.ROOF
APM EC	AMZ.BLDG.ROOF.GRP
BBM Handbook Title	Roof and Roof Drainage
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Jun-23	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	Yes	**Special Certificaion Required:**	TBC	**Delivered By:**	TBC	**OCB:**	BBM
Evidence for CT:	TBC	**Pricing template Position:**	7	**Related CT Areas:**	CT.FAC.ROOFTOPINSPECT			**Assets included in this PM:**	ROOF AND ROOF DRAINAGE - ROOFLIGHTS	**Schedule With:**	BLDG.LIGHTNING		

Description of System / Technology (According to BBM Handbook)

Roof and Roof Drainage.

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.
Note: Roof drainage up to the inlet in the base plate, from there PM under the drainage system.

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	General	Is the documentation of installed BBA available & complete - e.g. drainage, skylights						PM		PM		
2	Roof surface	Check if any kind material is stored on the rioof Schedule removal it in case of any kind of risk for the building or people			SC		SC	PM		PM		
3	Roof surface	Check for coarse dirt and gravel deposits on the roof Schedule cleaning the surface if required			SC		SC	PM		PM		
4	Roof surface	Check for unwanted vegetation from the roof Schedule removal it from any surface if required			SC		SC	PM		PM		
5	Roof surface	Visual check of the membrane including seam connection for obvious damage						PM		PM		
6	Roof surface	Gravel roof - check unwanted shifting of the gravel						PM		PM		
7	Roof surface	Gravel roof - check walkway plates for correct position & damage						PM		PM		
8	Roof surface	Visual check for water retention on the roof (visible puddles) Schedule action in case of any risk for the building or people			SC		SC	PM		PM		
9	Connections / Seals	Check the connections for damage (roof to facade, skylights & other structures)						PM		PM		
10	Drainage	Visual check for damage & dirt build-up of gutters Schedule cleaning gutters if necessary			SC		SC	PM		PM		
11	Drainage	Visual check of the surfaces around drainage inlets Schedule cleaning if debris accumulated			SC		SC	PM		PM		
12	Drainage	Visual check of the drainage inlet grids for damage & dirt Schedule cleaning if blocked (primary & secondary)			SC		SC	PM		PM		
13	Drainage	Dismount drain inlet grids, clean drain inlet and surrounding area						PM		PM		
14	Drainage	Syphonic system - dismount grid & check correct function of the flap						PM		PM		
15	Drainage	Visual check of drainage outlets incl. emergency outlets at the walls Schedule cleaning if blocked			SC		SC	PM		PM		
16	Drainage	Check if there are any damaged or loose parts at the drainage pipes which is attached to the building								PM		
17	Drainage pipe system	Carry out a camera inspection of the drainage system (inside the drain pipes)								PM		
18	Drainage pipe system	Check for damage of the drain pipes, insulation, suspension inside the building						PM		PM		
19	Drainage pipe system	Open maintenance flaps & check drain pipe inside for deposits and clogging								PM		
20	Roof installations	Check all handrails and other structures (installations) are not damaged & fixed properly					SC	PM		PM		
21	Rooflights	Check the rooflights for damage						PM		PM		
22	Roof installations	Check Installations (e.g. cable trays, pipe systems,etc.) for corrosion & damage								PM		

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.