amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	ELECTRICAL SYSTEM, METERS - 11
APM Object	ELEC.MET
APM EC	AMZ.ELEC.METERS.GRP
BBM Handbook Title	Electrical Meters
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Jul-23	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	TBC	**Special Certificaion Required:**	TBC	**Delivered By:**	Carried out by trained on site technician	**OCB:**	BBM
Evidence for CT:	TBC	**Pricing template Position:**	11	**Related CT Areas:**	CT.ELEC.ELECINST			**Assets included in this PM:**	ELECTRICAL METER	**Schedule With:**	ELEC.LV.CABS ELEC.LV.BSBR ELEC.LV.PFC ELEC.LV.SWBD BLDG.EARTHING		

Description of System / Technology (According to BBM Handbook)

Electric meters -> analog – manual read, or smart meters – connected to BMS. Electrical meter will be the main utility meter and submeters are any meters downstream at the site. Update the Alias description with meter type, if utility meter include utility meter number and if submeter include location of meter.

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.
Note: smart meters which are connected to the BMS are captured under the BMS PM

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Electric meter	Check all electric meters for correct function, display in the BMS, alarms & damage			SC							
2	Measurement	List all meter names & consumption in kWh to the notes			SC							

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.