amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	FIRE DETECTION SYSTEM, ASPIRATING SMOKE - 10
APM Object	FIRE.DET.ASD
APM EC	AMZ.FIRE.ASP.GRP
BBM Handbook Title	Aspirating Smoke Detection System (ASD)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Dec-23	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	YES	**Special Certificaion Required:**	TBC	**Delivered By:**	Carried out by trained on site technician with relevant certificates	**OCB:**	BBM
Evidence for CT:	YES	**Pricing template Position:**	10	**Related CT Areas:**	CT.FIRE.FAS CT.FIRE.ASD			**Assets included in this PM:**	ASPIRATING SMOKE DETECTOR	**Schedule With:**	FIRE.DET.SMOKE FIRE.DET.HEAT FIRE.DET.SMOKEHEATCO FIRE.DET.SMOKEHEAT FIRE.DET.BEAM FIRE.DET.DUCT FIRE.DET.LINEAR FIRE.DET.FLAME		

Description of System / Technology (According to BBM Handbook)

An aspirating smoke detector (ASD) is a system used in active fire protection, consisting of a central detection unit which draws air through a network of pipes to detect smoke. The sampling chamber is based on a nephelometer that detects the presence of smoke particles suspended in air by detecting the light scattered by them in the chamber. ASDs can typically detect smoke before it is visible to the naked eye.

Additional Information

Ensure the filters are changed minimum once a year or according to O&M manual if a shorter interval is recommended
All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

IMPORTANT
Ensure that a different group of devices are tested each quarter so that all devices will be tested within one year

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Aspirating Smoke Detector	Check for alarms on the ASD unit				PM		PM				
2	Aspirating Smoke Detector	Vacuum ASD pipes with a vacuum cleaner				PM		PM				
3	Aspirating Smoke Detector	Check the ASD pipe filter and change if necessary, or clean if it is a reusable filter				PM		PM				
4	Aspirating Smoke Detector	Check, clean & adjust pressure sensor according to manufacturer & Amazon FLS requirements				PM		PM				
5	ASD filter change	Add detail of filter change into notes if changed				PM		PM				
6	Final Check	Consult the O&M manual and perform any additional tasks as specified						PM				

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.
June 2024 - Adding info in Who is for? Removing 6M, 12M, and 24M frecuencies.