amazon rme

AMAZON BASE BUILDING MAINTENANCE STANDARD

GLOBAL CENTRAL RME STANDARDS & COMPLIANCE

Task Title	FIRE DETECTION SYSTEM, BEAM - 10
APM Object	FIRE.DET.BEAM
APM EC	AMZ.FIRE.BEAM.GRP
BBM Handbook Title	Fire Detection System Overview
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure These tasks are based on industry guidance, SME knowledge and HIE learning. Please ensure vendor specific requirements are followed. To suggest improvements please raise a SIM SIM - Link to SIM template

Last Update: (Version)	Jun-24	**Geo Applied:**	Intl APM Instance	**F-Gas**	Not Identified	**Activies may be covered by No-Go restrictions:**	TBC	**Special Certificaion Required:**	TBC	**Delivered By:**	Carried out by trained on site technician with relevant certificates	**OCB:**	BBM
Evidence for CT:	YES	**Pricing template Position:**	10	**Related CT Areas:**	CT.FIRE.FAS CT.FIRE.SMOKEDETECT			**Assets included in this PM:**	BEAM DETECTOR	**Schedule With:**	FIRE.DET.SMOKE FIRE.DET.HEAT FIRE.DET.SMOKEHEATCO FIRE.DET.SMOKEHEAT FIRE.DET.DUCT FIRE.DET.LINEAR FIRE.DET.FLAME FIRE.DET.ASD		

Description of System / Technology (According to BBM Handbook)

A beam detector is a fire detection device that uses infrared beams to detect the presence of smoke. Using a detector on one wall and a reflector on the one opposite, the detector shoots the infrared beam across an open area to the reflector, which sends it straight back.

Additional Information

All sites with the above listed Base Building Asset should conduct routine maintenance and inspections according to this standard PM package. The Amazon maintenance standard supports compliance, reduces safety risks,improves asset reliability & efficiency.
Some maintenances captures several assets within one PM package -> Ensure that corrective/reactive maintenance for assets where proactive maintenance is contained under another asset is created against the original asset.

IMPORTANT
Ensure that a different group of devices are tested each quarter so that all devices will be tested within one year

Task Index	Component	Tasks	Tasks Nested for frequencies > weekly									
			Daily	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	36 Monthly	48 Monthly	60 Monthly
1	Detection	Check for physical damage, dirt, dust, or obstructions on the emitter and receiver lenses. Ensure the beam path is clear of obstacles						PM	PM			
2	Detection	Verify proper alignment of the detector using the manufacturer's tool or method. Ensure the alignment indicator is within acceptable tolerance levels						PM	PM			
3	Detection	Simulate a smoke condition to test the detector's response and ensure proper activation of the fire alarm system						PM	PM			
4	Detection	Verify that the detector forwards the alarm correctly to the fire alarm panel with an accurate message of origin						PM	PM			
5	Detection	Confirm the detector's sensitivity setting (e.g., obscuration rate) meets manufacturer specifications and adjust if needed						PM	PM			
6	Detection	Clean the emitter and receiver lenses with a soft, non-abrasive cloth to maintain optimal performance						PM	PM			
7	Battery	Ensure battery is properly charged and replace if applicable						PM	PM			
8	Battery	Replace battery if applicable							PM			

Change Log

July 2023 - First issue in new format. Simplification of task scope, alignment with CT.
June 2024 - New PM.
Aug 2024 - Added task to check for battery after learnings from LATAM field RME