AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Indoor air quality
APM Object	CT.AIR.INDOOR
APM Description	Indoor air quality and associated air handling plant e.g. HVAC, ducting, control panels etc
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Air Roof Top Units Air Conditioning Units Air Conditioning	**Related CT Areas:**	Not Specified		

Scope

Any site where mechanical ventilation systems are installed to maintain workplaces adequately ventilated with sufficient quantity of fresh or purified air (not the removal of hazardous emissions). This includes air conditioning systems, humidifiers and mechanical fresh air ventilation systems, as well as the associated infrastructure (e.g. air ducts, grills, filters, etc.).
This standard excludes legionella, and extraction of hazardous air

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but minimum of every 6 months. Air intake and filters may need more frequent cleaning/replacement – particularly due to COVID 19	Ongoing regular maintenance and cleaning of all mechanical ventilation systems e.g. vents, filters, ducting, HVAC, fan motors, extraction and circulation systems	Competent person	Maintenance logbook	PM					EVID		
All	2	Based on risk assessment, but at least every 12 months.	Inspection of HVAC equipment to ensure correct and safe operation, and adequate air exchange. To include associated infrastructure after first installation and thereafter at regular intervals.	Competent person	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	3	Based on risk assessment and in the event of a change of use, conversion or renovation, or in the event of a complaint/grievance or failure of statutory threshold.	Undertake air quality monitoring (if necessary) of key parameters as identified by risk assessment (e.g. microbiological inspection, particulate matter, CO, bacteria and fungi, temperature, etc.).	Competent person	Inspection records, report or certificate. Risk assessment								3Y CT
ES	4	Every 12 months.	Indoor Air Quality Inspections according to UNE 100012 and UNE 171330 standards in buildings.	No additional requirements	No additional requirements						CT		
IT	5	Best practice is to conduct inspections at least every 6 months.	Maintenance of adiabatic humidification systems or humid climate.		Inspection records, report or certificate.	PM					EVID		

PL	6	Where operates all year test at least twice a year, once in the winter season (October-March) and once in the summer season (April-September).	Monitoring for a source that requires a permit to introduce gases or dust into the air	No additional requirements	Inspection records, report or certificate.					CT			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No 378/2001	Manufacturer or person authorized by the manufacturer	Inspection of the device once every 12 months, keeping the workspace healthy and safe
DE	Betriebsicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln) DGUV Regel 109-002 – Arbeitsplatzlüftung – Lufttechnische Maßnahmen	Inspection and maintenance: competent person (befähigte Person) according to BetrSichV	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2103 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. UNE 171330 standards in buildings. Indoor air quality (part 1, 2, 3). UNE 100012: 2005 Standard. Cleaning of ventilation and air conditioning systems.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years.
FR	Arrêté du 8 octobre 1987 relatif au contrôle périodique des installations d'aération et d'assainissement des locaux de travail - Légifrance (legifrance.gouv.fr) Arrêté du 9 octobre 1987 relatif au contrôle de l'aération et de l'assainissement des locaux de travail pouvant être prescrit par l'agent de contrôle de l'inspection du travail mentionné à l'article L. 8112-1 du code du travail - Légifrance (legifrance.gouv.fr)	Qualified person	Inspection conducted at least every 12 months.
IT	D.P.R. 16/04/2013, n. 74 Legislative Decree 13/08/2010 n.155 (Adoption of Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 24/12/2012 n.250 (Changes and integrations to Legislative Decree no. 155 of August 13, 2010, implementing Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 9/98/2008 n.81 Decree 10/02/2014 Decree 22/01/2008 n.37 (regulation on the reorganization of the provisions on the installation of systems inside buildings.)	Competent, qualified person	Periodic cleaning and maintenance in accordance with manufacturer's recommendations. Regular and periodic inspections. Filter's maintenance usually every 3 months, installation maintenance every 24 months.
PL	Regulation of the Minister of Labor and Social Policy of 26 September 1997 on general health and safety at work regulations (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Regulation of the Minister of Health of 22 April 2005 on harmful biological agents for health in the work environment and protection of the health of workers professionally exposed to these factors (Journal of Laws 2005, number 81, item 716)	Qualified or competent person.	Initial test of the ventilation system after installation. Inspections and maintenance in accordance with manufacturer's recommendations.
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007	Competent person, best practice to outsource to specialist.	Inspections of all ventilation systems to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 355/2007 Coll. on the protection, promotion and development of public health Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certifiedperson, best practice to outsource to specialist.	Periodic maintenance every 5 years for AC with installed power of 70kW and more. Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment . Minimum safety and health requirements for the workplace.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 The Provision and Use of Work Equipment Regulations 1998 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource to specialist.	Periodic maintenance of equipment in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment.