AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Local exhaust ventilation
APM Object	CT.AIR.LEV
APM Description	Local Exhaust Ventilation systems.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites where Local Exhaust Ventilation systems are used as individual mechanical means of ventilation for activities, processes or areas that are likely to produce fumes, smoke, gas or air emissions which may be toxic or harmful if inhaled/exposed, including those mounted to machinery, mobile units and fixed units.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Maintenance of all LEV systems	Competent person	Maintenance logbook	PM					EVID		
All	2	At least every 12 months. More frequent inspections might be required based on risk assessment.	Inspection of all Local Exhaust Ventilation systems to ensure safe and correct operation, including hygienic and ventilation properties.	Competent person, normally outsourced	Inspection and examination records, reports or certificate. Risk assessment.	PM					EVID		
PL	3	At least every 6 months.	Inspections of LEV systems if it is within a potentially explosive atmosphere.	No additional requirements	No additional requirements					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Act No. 22/1997 Coll. ČSN 331600 Government Regulation No 378/2001 Coll.	Competent person, Review technician	Inspections of equipment Revision of electrical components

DE	Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Competent person (befähigte Person)	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	Building Technical Code (CTE). Health Standards Basic Document (DB HS3 – Air Quality). RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2103 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 374/2001, of April 6, about health and safety protection on workers against risks related to chemical agents during worktime. Technical Guide for the evaluation and prevention of risks related to the exposure of chemical agents on workplaces. Prevention Technical Note NTP 742. General ventilation on buildings. Prevention Technical Note NTP 741. General ventilation by dilution.	Competent person.	Maintenance and inspections conducted at least every 12 months.
FR	No additional requirements	N/A	No additional requirements.
IT	Legislative Decree 13/08/2010 n.155 (Adoption of Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Legislative Decree 24/12/2012 n.250 (Changes and integrations to Legislative Decree no. 155 of August 13, 2010, implementing Directive 2008/50/EC on ambient air quality and cleaner air for Europe) Decree 10/02/2014 Decree 22/01/2008 n.37 Legislative Decree 9/04/2008 n.81 Legislative Decree 3/04/2006 n.152 Directive 2006/42/EC	Competent person.	Regular maintenance in accordance with manufacturer's instructions. Inspections at least every 12months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 26 September 1997 of Minister of Labor and Social Policy on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 12 April 2002 of Minister of Infrastructure on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of the Environment of August 24, 2012 on the levels of certain substances in the air (Journal of Laws 2021, item 845) Regulation of Minister of Environment of 2 July 2010 on the types of installations the operation of which requires notification (Journal of Laws 2019, item 1510)	Competent or qualified person	Inspections every 12 months. If within a potentially explosive atmosphere, every 6 months.
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 78/2001 - Safety, Health and Welfare At Work (Carcinogens) Regulations, 2001. S.I. No. 619/2001 - Safety, Health and Welfare At Work (Chemical Agents) Regulations, 2001 S.I. No. 572/2013 - Safety, Health and Welfare at Work (Biological Agents) Regulations 2013.	Competent person, best practice to outsource to specialist.	Inspections of all LEV to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Ordinance No. 94/2004 Coll. on technical requirements for fire safety during construction and use of buildings Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions or technical norm. Inspections based on standardized testing of selected technical equipment.
UK	The Control of Substances Hazardous to Health Regulations 2002 Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003	Competent person, best practice to outsource to specialist.	Thorough Examinations of all LEV to be conducted at least every 14 months.