AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	General lighting
APM Object	CT.ELEC.LIGHTING
APM Description	Indoor and outdoor lighting systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIGHT.EXT LIGHT.INT	**Related CT Areas:**	Not Specified		

Scope

All sites with indoor and/or outdoor lighting systems.
Inspection requirements of the electrical installation of which the indoor/outdoor lighting system is part of is covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's and vendor's recommendations and instructions	Routine maintenance of all lighting systems (cleaning, repairing or replacing and disposing of lamps/luminaires).	Competent person	Maintenance logbook	PM					EVID		
All		Based on risk assessment	Check of correct illuminance for the specific tasks being undertaken in each area.	Competent person	Inspection records. Risk assessment	PM					EVID		
All		Based on risk assessment	Routine inspection to assess health and safety risks arising from incorrect lighting systems (e.g. glare, flickers, etc.)	Competent person	Inspection records. Risk assessment	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.

DE	Technische Regeln für Arbeitsstätten: ASR A3.4 - Beleuchtung Betriebssicherheitsverordnung (BetrSichV) DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel	Qualified electrician (Elektrofachkraft).	Inspection intervals determined based on risk assessment and manufacturer recommendations.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-44. Lighting system receivers. DB- SUA4 – CTE (Construction Technical Code- Safety Using Basic Document number 4 – section 2).	Competent person	Routine maintenance and inspections based on risk assessment.
FR	Labour Code Art. R4223-4 relating to lighting conditions https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018532265	N/A	N/A
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 UNI EN 12464-1:2011 (Lighting at work-internal) UNI EN 12464-2:2014 (Lighting at work-external)	Competent person	Maintenance and inspection every 5 years, or every 2 if there is a risk of fire.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Competent person	Routine maintenance and inspections based on risk assessment, at least every 5 years.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) untitled (hsa.ie)	Competent person	Routine maintenance and inspections based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Competent person	At least annually. In case of significant dust sediments, at least two times or four times per year.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations Lighting at work - HSG38 (hse.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Competent person	Routine maintenance and inspections based on risk assessment.