AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Thermal scanning					
APM Object	CT.ELEC.THERMAL					
APM Description	Thermal scans of electrical installations					
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template					
Last Update: (Version) ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:** Not Specified	**Special Certification Required:**	**Delivered By:**	
Evidenced part or full by PM: Not Specified	**Related BBM PM:**	LIFTS.PASSENGER - LIFTS.GOODS - LIGHT.SAFETY - FIRE.DET.FIREALRM - FIRE.DET.BOS - FIRE.DET.COMM - FIRE.SUP - FIRE.SUP.PUMP.CNTRL - ELEC..LV.CABS - ELEC.LV.BSBR - ELEC.HV.SWITCHGEAR -	**Related CT Areas:**	Not Specified		

Scope

Any site where thermal imaging/scanning is used for inspections of electrical systems to help in the early identification of faults before they occur, and therefore preventing breakdowns, replacements and even fires.
Thermographic surveys are generally part of the thorough inspection of the electrical installation, which is covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	After installation is complete	Initial thermographic survey at installation stage.	Competent person, usually outsourced	Inspection records, report or certificate. Risk assessment								One off EVID
All	2	Thermographic surveys are generally part of the inspection of the electrical installation as a whole, and therefore they frequency is based on risk assessment (type, use and operating conditions), but normally between 3 and 5 years.	Periodic thermographic surveys of the electrical installation and equipment to aid in the early detection and the prevention of issues.	Competent person, usually outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
CZ	3	No additional requirements	Inspection as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500 ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305 ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.

DE	DIN 54191 - Zerstörungsfreie Prüfung - Thermografische Prüfung elektrischer Anlagen	Qualified electrician (Elektrofachkraft)	Regular thermal scans depending on the use and operating conditions of the equipment, and risk assessment. Annual scans are recommended.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions.RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Frequency not stipulated by regulations.
FR	N/A	N/A	Frequency not stipulated by regulations.
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-14 (Guidelines for electrical installations inspections) CEI O-10 (Guidelines for maintenance) CEI 64-8/6 (Electric installations under 1000V-Inspections) UNI EN ISO 9712:2012 (Qualification of non-destructive testing personnel) UNI EN 16714-3:2016 (Thermographic testing)	Competent person.	Frequency not stipulated by regulations.
PL	N/A	N/A	Frequency not stipulated by regulations.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020.	Registered electrician, approved by ECSSA.	Initial inspection and at least every 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person.	Depends on class. Minimum inspection period is 3 years.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations The Electricity at Work Regulations 1989. Guidance on Regulations (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Initial inspection and at least every 5 years