AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Surge Protection Devices
APM Object	CT.ELEC.TVSS
APM Description	Surge Protection Devices (SPDs)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Surge Protection Devices (SPDS), also known as Transient Voltage Surge Suppressor (TVSS), are used to provide protection to electrical equipment and appliances due to surges of voltage, which can be due to lighting strikes, switching operations or electrostatic discharges.
Lightning protection equipment is covered in Lightning protection.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all SPDs.	Competent person	Maintenance logbook	PM					EVID		
All		Based on risk assessment (type, use, operational conditions and risks associated with the area, but at least every 12.	Visual check of all SPDs to ensure.	Competent person. Generally, externally sourced.	CE Declaration of Conformity Risk assessment Inspection records, reports or certificates.						CT		
All		Based on risk assessment (type, use, operational conditions and risks associated with the area), but at least every 2 years.	Testing of all SPDs to ensure correct operation. This is achieved through a simulated surge voltage to confirm the device functionality.	Competent person. Generally, externally sourced.	CE Declaration of Conformity Risk assessment Inspection records, reports or certificates.							CT	

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A

CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6 and 60 months.
DE	DIN EN 62305-3 VDE 0185-305-3:2011-10 – DIN VDE 0100-443 - Errichten von Niederspannungsanlagen – Teil 4-44: Schutzmaßnahmen – Schutz bei Störspannungen und elektromagnetischen Störgrößen DIN VDE 0100-534 – Errichten von Niederspannungsanlagen – Teil 5-54: Auswahl und Errichtung elektrische Betriebsmittel – Trennen, Schalten und Steuern	Lightning protection specialist (Blitzschutz Fachkraft)	Regular inspections should be carried out every 1 to 4 years. Protection class I and II should have a visual inspection, and an inspection of critical systems at least every year, and a general inspection at least every 2 years. Protection class III and IV should have a visual inspection at least every 2 years, an inspection of critical systems at least every year, and a general inspection at least every 4 years.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions.RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions.	Accredited company (OCA) by ENAC.	Low voltage Inspections and testing at least every 5 years. High Voltage inspections and testing to be conducted at least every 3 years.
FR	26th December 2011 Decree about electrical installations verification ""Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025046978/	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DM 22/01/2008 n.37 CEI 64-8; V5 (Sections 443;534: safety requirements for surge protection devices) CEI EN 61643-11 (Safety requirements) CEI 64-14 (Guidelines for electrical installations inspections) CEI O-10 (Guidelines for maintenance) CEI 64-8/3 (Electric installations under 1000V- general informations) CEI 64-8/6 (Electric installations under 1000V-Inspections) CEI 64-8/7 (Electric installations under 1000V-special applications) CEI EN 50191 (Installation and use of electric systems)	Competent person	Inspection every 5 years, or every 2 if there is a risk of fire.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 1994 No. 89 pos. 414), as amended Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Act of April 24, 2009 on batteries and accumulators (Journal of Laws 2020, item 1850) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830)	Competent person	Inspection every 5 years, or every year if there is a risk of fire.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI - IS 10101:2020 on 6 March 2020.	Competent, trained electrician	Routine maintenance. Inspection and testing frequency based on risk assessment.
SK	Act No. 124/2006 Coll. on safety and health at work Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 94/2004 Coll. laying down technical requirements for fire safety in the construction and use of buildings	Qualified and certified person	Protection systems level I and II require a visual inspection yearly and a functional inspection and testing every 2 years. Protection systems level III and IV require visual inspection yearly and a functional inspection and testing every 4 years.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Electricity at Work Regulations 1989 (legislation.gov.uk) BS 7671 / IET Wiring Regulations Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk) BS EN 62305-3 Protection Against Lightning BS 7430 Code of Practice for Earthing	Competent, trained or qualified engineer, authorised to undertake the task.	Routine maintenance. Inspection frequency dependant on the building, type of SPD, use and operational conditions. Generally, visual checks at least annually and testing at least every 2 years.