AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Kitchen extract and grease management
APM Object	CT.ENVIRO.EXTRACT
APM Description	Kitchen grease systems, including air ducts, fans, chambers, filters, etc.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.DH	**Related CT Areas:**	CT.ENVIRO.INTERCEPTOR		

Scope

Any site with a kitchen air extraction system (e.g. exhaust air ducts, extractor hoods, chimneys etc.) that require inspection in order to reduce the risk of fire occurring.
The maintenance of grease traps is covered in the procedure CT.ENVIRO.INTERCEPTOR

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, suggested monthly.	Regular maintenance of the equipment (lubrication, filter replacement, parts replacement, etc.).	Competent person.	Records of inspections (including cleaning and maintenance).	PM					EVID		
All	2	Maintenance frequency not specified in regulations, based on site fire risk assessment. Generally, every 6-12 months unless heavy use (>12-16hrs/day).	Regular inspection, cleaning and removal of grease from extractor system, including flow efficiency, cleanliness, checks on filters to ensure they are not clogged.	Operator. Competent person (cleaning and filter change).	Records of inspections (including cleaning and maintenance) Recommended to be included in the site Fire Risk Assessment.	PM					EVID		
DE	3	Aerosol separators must be checked every working day and cleaned if necessary. In case of heavy grease accumulation, daily cleaning of the separators may be necessary. Kitchen ventilation ceilings and bonnets should be checked	Maintenance as per [1]	No additional requirements	No additional requirements	(PM)					(EVID)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Law No. 133/1985 Coll., Fire protection; Law No. 201/2012 Coll., Air protection Decree No. 246/2001 Coll. about fire prevention	Competent person. Usually outsourced.	Regular inspection and maintenance. Frequency based on risk assessment.

DE	VDI 2052 - Raumlufttechnik - Küchen (VDI-Lüftungsregeln) DIN EN 16282 - Equipment in commercial kitchens - Elements for aeration and ventilation TRBS 1201 Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Expert (sachkundige Person). Knowledgeable person for simple inspection, cleaning and maintenance.	Aerosol separators must be checked every working day and cleaned if necessary. In case of heavy grease accumulation, daily cleaning of the separators may be necessary. Kitchen ventilation ceilings and bonnets should be checked regularly and cleaned if necessary e.g. kitchen ventilation bonnets should be checked daily and ceilings at least monthly for soiling. The components of the exhaust air system (e.g. exhaust air ducts, fans, unit chambers) should be checked at least every six months and cleaned if necessary.
ES	Real Royal Decree 732/2019 Technical Code of Buildings NORMA UNE 100165 on fumes extraction	Competent person.	Monthly maintenance and cleaning. Inspections carried out every 12 months.
FR	Decree of 10th October 2005 on fire security rules Arrêté du 10 octobre 2005 portant approbation de diverses dispositions complétant et modifiant le règlement de sécurité contre les risques d'incendie et de panique dans les établissements recevant du public - Légifrance (legifrance.gouv.fr)	Competent, qualified person.	Chimney sweeping and verification of potential obstructions every 12 months.
IT	Legislative Decree n. 81 of 9 April 2008 - regarding the protection of health and safety in the workplace UNI EN 16798-1:2019 (Ventilation for buildings). UNI EN 16798-3:2018 (Energy performance of buildings) UNI 7129 (Gas plant)	Competent person. Usually outsourced	Inspections follow manufacturer's instructions. Generally every 12 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333), as amended	Competent, trained person.	Inspections at least twice a year. Notification in writing the building inspector.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 Fire Services Act 1981	Competent, qualified person.	Inspection frequency follow manufacturer's instructions.
SK	Act No. 314/2001 Coll. on fire protection Ordinance No.121/2002 Coll. on fire prevention	Competent person. Usually outsourced.	Inspection frequency follow manufacturer's instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 Fire Scotland (2005) Act RC44 (FPA/BSRIA) Recommendations for fire risk assessment of catering extract ventilation The Fire and Rescue Services (Northern Ireland) Order 2006 The Fire Safety Regulations (Northern Ireland) 2010	Competent person, best practice is to outsource to specialist.	Regular maintenance. Cleaning frequency based on hours of use. 3 months (12-16h/day), 6 months (6-12h/day) and 12 months (2-6h/day). Inspection frequency based on risk assessment.