AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hazmat Cabinets
APM Object	CT.ENVIRO.HAZCAB
APM Description	Hazmat Cabinets
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site using and storing hazardous products, with safety cabinets designed to safely store hazardous materials (e.g. flammable liquids).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency based on risk assessment. Generally, every 12 months.	Identify hazardous substances used and identify storage requirements using Safety Data Sheet	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
All	2	Frequency based on risk assessment. Generally, every 12 months.	Correctly label all substances hazardous to health used or stored at the site and ensure storage containers are labelled with appropriate hazard pictograms and stored away from conflicting hazard sources e.g. separate oxidisers and flammables.	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
All	3	Frequency based on risk assessment. Generally, every 12 months.	Periodic inspection to ensure correct integrity of the cabinets e.g. spill prevention or resistance to fire.	Competent person (likely to be internal)	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.						CT		
CZ	4	HAZMAT cabinets are generally inspected at least every 6 months.	Inspection as per [3]	No additional requirements	Records of inspections. Risk assessment. Records of training evidence. Site map of storage locations and integration into site Fire Risk Assessment.					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act No. 258/2000 Coll. on public health protection (§44a) Regulation No. 375/2017 Coll. on safety signs and signalisation (§4) Labour Code No. 262/2006 Coll. (§101-103) Water Act No. 254/2001 Coll. (§39) Decree No. 450/2005 Coll. on requirements of handling harmful substances and emergency plan (§3), Decree No. 246/2001 Coll. on fire safety (§44) CSN 65 0201	N/A	There are no specific stipulations for safety cabinets. In general HAZMAT warehouses or cabinets should be inspected every 6 months at least. Specific provisions for flammables are set in CSN 65 0201 (see Annex 5).
DE	Gefahrstoffverordnung (GefStoffV) Betriebssicherheitsverordnung (BetrSichV) Technical Rules for hazardous substances: TRGS 510 – Storage of hazardous substances in portable containers	Competent person (fachkundige Person).	Cabinets for hazardous substances must be regularly checked (TRGS 510), frequency based on risk assessment; annual inspection is common; follow the manufacturer recommendation.
ES	Royal Decree 656/2017 on the storage of hazardous chemicals	Depending on the quantity and hazard assessment, by competent person or by a certified company.	Exam periodicity depends on stored quantities and type of hazard assessment.
FR	French Labor Code – Article R4412-1 to 57 - Chemicals management: labelling and storage rules for risk assessment and prevention https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018490115/#LEGISCTA000018531162	N/A	Exam periodicity has to be defined by the risk assessment as Best Practice to manage chemical hazards
IT	Legislative Decree n. 81 of 9 April 2008 - regarding the protection of health and safety in the workplace EN 14470-1:2005 EN 14470-2:2007 EN 1363-1:2020	Competent person.	Hazardous substances (toxic and flammable substances) must be properly stored in order to avoid any damaging events. Frequency of the periodic inspections of the cabinets, which must be periodically performed, depends on the content of the cabinet and must be in line with the maintenance manual provided by the manufacturer.
PL	N/A	N/A	N/A
ROI	Dangerous Substances Act, 1972	N/A	Limits the maximum amount of fuel stored on site and conditions on storage.
SK	Act No. 67/2010 Coll. - Chemical Act Government Regulation No. 355/2006 Coll. on the protection of workers from the risks related to exposure to chemical agents at work STN EN 14470-1: Fire safety storage cabinets - Part 1: Safety storage cabinets for flammable liquids	N/A	No special legislation for Hazmat cabinets. Stated legislation is more general, setting up compliance with EU RME Standards .Technical norm sets up technical requirements for storage cabinets for flammable liquids.
UK	The Control of Substances Hazardous to Health Regulations 2002 Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003	N/A	Regular inspection of chemical storage areas, including the condition of the structure and fittings within the storing area.