AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Interceptor
APM Object	CT.ENVIRO.INTERCEPTOR
APM Description	Oil and grease interceptors fitted to drainage network.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.OILSEP BLDG.GREASESEP	**Related CT Areas:**	CT.ENVIRO.EXTRACT		

Scope

Any site with an oil or grease interceptor fitted to provide treatment of surface or foul drainage systems prior discharge

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency not specified in regulations. It is based on site conditions, manufacturer instructions, risk assessment or conditions of sewage permit. Suggest monthly inspection/clean for kitchen grease trap and 12 month	Regular inspection, cleaning and removal of waste to ensure the effectiveness of the interceptor in line with manufacturers instructions.	Competent person	Records of inspections (including cleaning and maintenance). Records of the site water drainage plan.	PM					EVID		
DE	2	General inspection by expert every 5 years. 12 monthly maintenance, emptying and cleaning of interceptor. Sludge trap and grease separator must be completely emptied and cleaned at least	Maintenance and inspection of the grease interceptor, including sludge trap and grease separator to ensure optimal operation.	Expert person (sachkundige Person).	Record of periodic general inspection. Operational logbook.	PM					EVID		5Y CT

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Water Act No. 258/2000 Coll. Act No. 274/2001 Coll., on Water supply and sewerage systems for public use CSN EN 858-2 Decree No. 8/2021 Coll., waste catalogue Waste Act No. 541/2020 Coll.	Competent person, best practice is to outsource to specialist.	Regular inspections following manufacturer's instructions or operation rules, regular cleaning and removal of waste, frequency based on the site conditions and risk assessment. Where a site has a discharge permit or a wastewater contract follow given conditions. The CSN EN 858-2 recommends general inspection every 5 years and inspection every 6 months.
DE	Verordnung über Anlagen zum Umgang mit wassergefährdenden Stoffen (AwSV) DIN 1999-100 - Abscheideranlagen für Leichtflüssigkeiten - Teil 100: Anwendungsbestimmungen für Abscheideranlagen für Leichtflüssigkeiten nach DIN EN 858-1 und DIN EN 858-2 DIN 4040-100 Grease Separators Wasserhaushaltsgesetz – WHG (Federal Water Act) and Abwasserverordnung (AbwV) (discharge of stormwater and wastewater law) https://www.bmu.de/themen/wasser-abfall-boden/binnengewaesser/gewaesserschutzrecht/deutschland/das-wasserhaushaltsgesetz/	Expert (sachkundige Person).	General inspection (Generalinspektion) every 5 years. Self-inspection every month. Maintenance, emptying and cleaning every 6 months.

ES	Royal Decree 732/2019 Technical Code of Buildings UNE-EN 1825-1 and 2	Competent person.	Recommended inspection every 6 months and maintenance every 2 years.
FR	Departemental Sanitary Regulations – Article 29 https://www.hauts-de-seine.gouv.fr/content/download/1942/13180/file/R%C3%A9glement%20sanitaire%20d%C3%A9partemental%20-%20ARS%2092.pdf This is a local regulation (Department area) but all departments request the same regular cleaning.	Competent person.	Regular cleaning, emptying and maintenance. Frequency not specified and region-specific.
IT	European Standard BS EN 858-1 Legislative Decree n.152 of 3 April 2006 - Environmental code	Competent person, best practice is to outsource to specialist.	Inspections every 3, 6 and 12 months, depending on site conditions. Periodic inspections frequency must be in line with the maintenance manual provided by the manufacturer.
PL	Regulation of the Minister of Maritime Economy and Inland Navigation of 12 July 2019 on substances particularly harmful to the aquatic environment and the conditions to be met when discharging sewage into waters or soil, as well as when discharging rainwater or meltwater into waters or into devices water (Journal of Laws 2019, item 1311) Act of 20 July 2017 - Water Law (Journal of Laws of 2017, item 1566) The Act of July 7, 1994 - Construction Law. (Journal of Laws 1994 No. 89 item 414)	Competent, trained person.	Inspections every 6 and 12 months, depending on site conditions. Periodic inspections frequency must be in line with the maintenance manual provided by the manufacturer.
ROI	Water Services Act 2007	Competent person.	Ensure maintenance to avoid hazards and damage to network. No frequency specified in regulations.
SK	Act No. 364/2004 Coll. on Waters Ordinance No. 200/2018 Coll., laying down details on the treatment of pollutants, on the details of the emergency plan and on the procedure for dealing with extraordinary water deterioration STN 75 0905/Z1: Water and sewerage tanks. Testing of water-tightness.	Competent person. Usually outsourced.	Regular frequency following manufacturer's instructions.
UK	Water Industry Act 1991 The Water and Sewerage Services (Northern Ireland) Order 2006	Competent person, with appropriate training.	In line with conditions of Trade Effluent Consent