AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Oil Tanks
APM Object	CT.ENVIRO.OIL
APM Description	Any site with oil storage containers above and below ground (e.g. tanks, drums, intermediate bulk containers (IBCs) and mobile containers (bowsers).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.FUELSTOR	**Related CT Areas:**	Not Specified		

Scope

Any site with oil storage containers above and below ground (e.g. tanks, drums, intermediate bulk containers (IBCs) and mobile containers (bowsers).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment.	Competent person.	Visual inspection records and associated maintenance repair reports.	PM					EVID		
All	2	Where site has a tank permit – inspection should be completed in line with permit conditions. For other tanks, detailed maintenance inspection every 6 months of tank and infrastructure. Annual calibration/test of	Inspection of the oil storage containers over 200L capacity, including pipework, gauges, alarms, pumps and associated structures to monitor condition, identify defects, ensure correct operation and leaks are identified and fixed promptly.	Competent person. Best practice to outsource	Visual inspection records and associated maintenance repair reports. Pressure testing and leak detection certificate.	PM					EVID		
All	3	Weekly inspection of external bunds for rainwater and damage.	Where an above ground, single skin tank is sited outside a building it should be fitted with secondary containment, the bund should be inspected for defects (damage, holes, cracking etc) and the accumulation of rainwater and debris.	Competent person (likely to be internal)	Visual inspection records and associated maintenance repair reports.		CT						
DE	4	Before first use or after any additions/changes, and at least every 30 months.	Underground tanks >200L	No additional requirements	No additional requirements								One off 30 monthly CT
IT	5	Every 3 years.	Internal inspection of tanks containing fuel oils.	No additional requirements	Inspection Report								3Y CT

IT	6	Every 5 years.	Internal inspections of tanks containing diesel fuel	No additional requirements	Inspection Report								5Y CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Water Act No. 254/2001 Coll. (§39), Decree No. 450/2005 Coll. on requirements of handling harmful substances and emergency plan (§3, 3a) CSN 75 3415 CSN 65 0201	Competent person, best practice is to outsource to specialist.	In general, regular inspection of the oil tanks and associated pipework/structures (inspection every 6 months, leak detection test by an external qualified company every 5 years). Specific provisions are set for flammables in CSN 65 0201 (Annex 5) – a leak test annually, a pressure test every 10 years for tanks which cannot be controlled externally, every 20 years for tanks externally controllable.
DE	Verordnung über Anlagen zum Umgang mit wassergefährdenden Stoffen (AwSV) TRGS 510 - Storage of hazardous substances in non-stationary containers ADR / RID 6.5.4.4 for IBC inspection	Expert (sachkundige Person) according to AwSV.	Underground tanks >200L: before first use or after any additions/changes, and at least every 30 months. Aboveground tanks >1000L: before first use or after additions/changes, and at least every 5 years. For IBCs before first use, and at least every 5 years according to ADR/RID.
ES	Royal Decree 656/2017 on the storage of hazardous chemicals Royal Decree 1523/1999, modifying MI-IP03, approved by Royal Decree 1427/1997 on fuel storage for internal use	Depending on the quantity and hazard assessment, by competent person or by a certified company.	Exam periodicity depends on stored quantities and type of hazard assessment. Normally every 5 to 10 years
FR	Decree 22nd June 1998 on flammable liquids "Arrêté du 22 juin 1998 relatif aux réservoirs enterrés de liquides inflammables ou combustibles et de leurs équipements annexes" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000572509/	Accredited company.	Regular inspection of oil tanks for leaks and correct operation. Maintenance every 5 years. Single skin tanks located in a pit must be checked for leaks every five years by an accredited company. For double outer jacket tanks, inspections every 10 years.
IT	UNI 8364-3: 2007 (Heating plant) Guidelines for Underground Storage Tanks of Local environmental protected agency ARPA of Lombardy Region "Linee guida sui serbatoi interrati ARPA 15/03/2013"	Competent person, best practice is to outsource to specialist.	Inspections in accordance with manufacturer's instruction. Every 3 years for tanks containing fuel oils, every 5 years for tanks containing diesel. In case of an Underground Storage Tanks (UST), a thickness test must be performed periodicity: - Every year: in case of an UST installed more than 30 years ago - Every 2 years: in case of an UST installed between 15 and 30 years ago
PL	Regulation of the Minister of Economy of 18 September 2001 on the technical conditions of technical inspection to be met by non-pressure and low-pressure tanks intended for the storage of flammable liquids (Journal of Laws 2001, No. 113, item 1211) Regulation of the Minister of Development of 2 June 2016 on simple pressure vessels (Journal of Laws of 2016, item 812) Regulation of the Minister of Economy of April 16, 2002 on the technical conditions of technical inspection to be met by non-pressure and low-pressure tanks intended for the storage of poisonous or corrosive materials (Journal of Laws of 2002, No. 63, item 572) Regulation of the Council of Ministers of 7 December 2012 on the types of technical devices subject to technical inspection (Journal of Laws of 2012, item 1468)	Competent, trained person.	Periodic frequency, in accordance with regulations and/or manufacturer's instructions and hazard assessment.
ROI	Local Government (Water Pollution) Act 1977	Competent person.	Not specified
SK	Act No. 364/2004 Coll. on Waters Ordinance No. 200/2018 Coll., laying down details on the treatment of pollutants, on the details of the emergency plan and on the procedure for dealing with extraordinary water deterioration STN 75 3415/Z1: Water protection against petroleum substances. Plants for handling of petroleum matters and their storage. STN 65 0201/Z2: Flammable liquids. Plants and storage rooms.	Competent person. Usually outsourced.	Regular frequency in accordance with manufacturer's instructions.
UK	The Control of Pollution (Oil Storage) (England) Regulations 2001 (legislation.gov.uk) Control of Pollution (Oil Storage) (Wales) Regulations 2016 The Water Environment (Oil Storage) (Scotland) Regulations 2006 Control of Pollution (Oil Storage) Regulations (Northern Ireland) 2010	Competent person.	Regular inspection of the oil tanks and associated pipework/structures. Best practice is 1 year.