AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Aspirating Smoke Detectors (ASD)
APM Object	CT.FIRE.ASD
APM Description	Aspirating air sampling systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.DET.FIREALRM	**Related CT Areas:**	Not Specified		

Scope

Any site where aspirating air samplers are used as a replacement or supplement to smoke detectors to aid in fire prevention strategies and plans.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Inspection and testing of VESDA air sampling systems		Inspection records, report or certificate	PM					EVID		
IT	2	Every 6 months	Inspection as per [1]	No additional requirements	No additional requirements	(PM)					EVID		
IT	3	Every 12 years	Review of the compliance of the installation	No additional requirements	No additional requirements								12Y CT
SK	4	In case of a need to perform more frequent than annual inspection, inspection is performed: Daily (changes in reported parameters); Monthly (mechanical check, communication channels); or	Inspection as per [1].	No additional requirements	No additional requirements	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 54-20:2007. Fire detection and fire alarm systems - Part 20: Aspirating smoke detectors.	Quarterly servicing by competent person Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Routine checks (maintenance) every 3 months. Official maintenance operation every year. Inspections every 10 years.
FR	Labour Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person. APSAD and NF certified companies	Inspection every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's instructions. Inspections every 6 months. Review of the compliance of the installation every 12 years.
PL	Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person	In accordance with manufacturer's instructions, but at least yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI	Competent person, best practice to outsource to specialist.	Inspection and testing every 12 months.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist. (e.g. fire protection technician)	Regular inspections. In case annual inspection is performed, more frequent inspections are not needed.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Competent person, best practice to outsource to specialist.	Inspection and testing every 12 months.