AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire dampers
APM Object	CT.FIRE.DAMPERS
APM Description	Fire dampers of all types including (for example) curtain, pivot and intumescent.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where fire dampers are used to prevent fire (when occurring) from escaping the room where it originated through ducting vents.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 12 months.	Regular inspection and servicing of fire dampers	Competent person (e.g. fire safety engineer)	Inspection records, report or certificate						CT		
DE	2	Every 6 months. *If no defects are found during 2 consecutive inspections, frequency is changed to 12 months.	Inspection as per [1]	No additional requirements	No additional requirements					CT*			
ES	3	6 months	Regular maintenance of fire dampers to ensure correct operation	Accredited company	No additional requirements					CT			
IT	4	Every 6 months	Inspection as per [1]	No additional requirements	CE Declaration of Conformity.					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company – manufacturer trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN EN 15650/ Muster-Verwaltungsvorschrift Technische Baubestimmungen des DIBt (MVV TB) DIN EN 13306 DIN 31051	Competent person according to state building law (befähigte Person)	Inspection before commencement, in case of significant changes and at regular intervals: Inspection and servicing every 6 months. If 2 consecutive inspections show no defects, inspections can be done yearly. In certain cases, inspection can be omitted; if: The release is thermoelectric and not via a fusible link; Fire dampers are equipped with actuators on which function tests can be carried out by remote control; Moving parts are secured with an enclosure; and Functional tests are carried out at least once a month.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) RD 842/2013, of October 31, approving the classification of construction products and construction elements based on their reaction properties and resistance to fire.	Qualified person or competent external company	Maintenance (functional) before commissioning and every 6 months. Inspections every 10 years.
FR	Labor Code Article R4227-28 to 33: Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Qualified person or competent external company	Maintenance (functional) before commissioning.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 15423:2008 (Maintenance) UNI EN 15650:2010 (Fire dumpers)	Competent, qualified person, best practice to outsource to specialist	Checks conducted every 6 months (Cleaning and visual inspection, checks of opening/closing mechanism).
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Inspection by competent engineer	Inspected and serviced yearly.
SK	Ordinance No. 478/2008 Coll. on the properties, specific operating conditions and ensuring regular inspection of the fire separation closures Ordinance No. 121/2002 Coll. on fire prevention	Qualified & certified person	Inspection every 12 month unless stated otherwise by operating instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice.	Inspection by competent engineer	Inspected and serviced yearly.