AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Evacuation
APM Object	CT.FIRE.EVACUATION
APM Description	Evacuation tests / Fire drills
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.FIRE.FRAMANAGEMENT		

Scope

All sites are required to have a site-specific fire emergency evacuation plan which should be based on the risks identified as part of the Fire Risk Assessment (covered under "Fire Risk Management (FRA)")
Fire drills or evacuation tests are essential elements of fire safety and aim to provide a comprehensive understanding of the fire evacuation procedures, risks and strategy to all employees.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment, but at least annually. Additionally, following any changes to the building, occupants, activities, etc.	Review of fire emergency evacuation plan to ensure all procedures are suitable. It needs to be communicated to all employees and visitors.	Competent person	Fire emergency evacuation plan						CT		
All	2	Frequency of fire drills based on fire risk assessment, but at least once a year.	Evacuation test or fire drill to familiarise employees with the emergency procedures in place Drill shall assess, whether; •the alarm can be triggered immediately at any time, •the alarm reaches all persons who are in the building, •all persons in the building are aware of the significance of the respective alarm, •the escape routes can be used quickly and safely.	Competent person, but generally delivered by site manager or owner	Written fire risk assessment, Records of attendance Summary of fire drill Any actions and evidence to follow up						CT		
FR	3	^ Monthly fire drill	As per [2]	Competent person, but generally delivered by site manager or owner	Written fire risk assessment, Records of attendance Summary of fire drill Any actions and evidence to follow up					CT			

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Competent person in fire protection	According to the set exercise schedule, but at least once in 12 month.

DE	Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände ASR A2.3 - Fluchtwege und Notausgänge, Flucht- und Rettungsplan	Employer, supported by fire protection and evacuation assistants	Evacuation tests should be completed at least annually based on the emergency and rescue maps (Flucht- und Rettungspläne).
ES	RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). RD 393/2007, of March 23, which approves the Self-Protection Basic Regulation on premises, facilities and all spaces dedicated to activities which may give rise to emergency situations.	Competent person or company.	The self-protection emergency plan must be reviewed at least every 3 years. Evacuation simulations at least once per year.
FR	Labor Code Article R4227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386	Competent person, but generally delivered by site manager or owner.	Fire drills to be completed every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DM 10/03/1998 (Currently being replaced)	Competent person, but generally delivered by site manager or owner.	Mandatory in businesses with more than 10 employees or in activities subject to control by the Fire Brigade in accordance with DPR 151/2011. Fire and evacuation drills to be completed every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	The owner or manager	For buildings with more than 50 regular workers, every 2 years.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety Signs at a Place Work - Health and Safety Authority (hsa.ie)	Competent person, often delivered by manager or owner.	Fire drills frequency based on fire risk assessment, but at least annually.
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention	Competent person, generally a fire protection technician	Fire drills every 12 months.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5499 - Safety Signs, Including Fire Safety Signs ISO 7010 - Safety colours and safety signs — Registered safety signs BS 5839 – Fire detection and fire alarm systems for buildings	Competent person, often delivered by manager or owner	Fire drills frequency based on fire risk assessment, but at least annually.