AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire alarm system (FAS)					
APM Object	CT.FIRE.FAS					
APM Description	Fire Alarm System (FAS).					
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template					
Last Update: (Version) ago-23	**Last Update Change Detail:** Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:** Yes	**Special Certification Required:**	**Delivered By:**		
Evidenced part or full by PM: Yes	**Related BBM PM:** FIRE.DET.FIREALRM	**Related CT Areas:** Not Specified				

Scope

All sites are required to have a suitable and sufficient fire detection system. The complexity of the fire detection system will depend on the site-specific fire risk assessment, which is covered under CT.FIRE.FRAMANAGEMENT, and will be based on the size and complexity of the premises, the type of activities undertaken or materials stored, the presence of vulnerable occupants and the ease of spotting and making everyone aware of a fire.
Small, single-storey or open-plan premises, where no high-risk substances are stored, no high-risk activities are undertaken, no vulnerable occupants can be present and where a fire is easy to spot and a shout of "fire" would be easily heard might be exempt from requiring a Fire Alarm system.
If either of these conditions does not apply to your premises, then a Fire Alarm System is likely to be required.
Inspection and testing of heat and smoke detectors is covered under CT.FIRE.SMOKEDETECT.
Fire drills and evacuation tests are covered under CT.FIRE.EVACUATION

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	Fire alarm test to ensure correct operation, including Voice communication.	Competent person, generally internal	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment		CT						
All	2	Based on risk assessment, but at least every 6 months	Routine maintenance and servicing of the Fire Alarm System in its entirety.	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months	Inspection and servicing of Voice Communication Systems / Voice Alarm Systems.	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment					CT			
All	4	Based on risk assessment, but at least annually. Electrical emergency lighting covered under "Emergency lighting systems"	Fire signing inspection and testing	Competent person (e.g. Fire safety assessor / engineer)	Fire alarm logbook Maintenance records Inspection records, report or certificate Fire risk assessment	PM					EVID		
DE	6	3 years	Additional inspection in accordance with building law.	Expert (Sachverständiger) in accordance with building law	No additional requirements								3 year (CT)

DE	7	3 months	Visual and functional inspection of FAS	No additional requirements	No additional requirements	(PM)					EVID		
DE	8	Every 3 months and at regular intervals when inspection FAS	Inspection of notifier and data transmission system to the fire brigade	No additional requirements	No additional requirements	(PM)					EVID		
ES	9	Every 3 months	Maintenance of FAS, including functional checks, replacements of faulty parts, etc.	Accredited company	No additional requirements	(PM)					EVID		
FR	5	No additional requirements	Inspection as per [1], [2], [3] and [4].	No additional requirements	Fire and security register	(PM)							N A R
IT	1	Daily.	Visual inspection of the control unit	No additional requirements	No additional requirements	PM					EVID		
IT	1	Every 12 years.	Review of the compliance of the installation	No additional requirements	No additional requirements								12 Year CT
SK	1	In case of a need to perform more frequent than annual inspection, inspection is performed daily (changes in reported parameters), monthly (mechanical check, communication channels) or quarterly (functional control	Inspection and testing of FAS	No additional requirements	No additional requirements	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll. Act No. 133/1985 Coll. on fire protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company Review technician	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually. Voice communication system to be checked every year Inspection and testing of fire markings annually.
DE	Federal State building codes and building permit. Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A2.2 - Maßnahmen gegen Brände DIN 14675 - Brandmeldeanlagen, Teil: 1 Aufbau und Betrieb und Teil 2: Anforderungen an die Fachfirma DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen Model Ordinance for Inspections (Muster-Prüfverordnung)	Competent person FAS / qualified electrician FAS Inspection as per building permit by expert according to state building law	Visual and functional inspection of FAS and voice communication/alarm systems (VAS) conducted every 3 months. Annual maintenance of VAS and FAS in accordance with manufacturer's instructions. Additional inspection of FAS and VAS in accordance with building law every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23007: fire detection and fire alarm systems. UNE-EN 54-1. Fire detection and fire alarm systems	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Maintenance of FAS every 3 months, including functional checks, replacements of faulty parts and verifications. Every year by authorised maintenance company: software, programmed manoeuvres, and all existing manoeuvres. Inspection carried out by accredited company (OCA) every 10 years.
FR	Labor Code Article R4227-34 to 36 relating to Alarm system https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489143/#LEGISCTA000018532069 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Qualified person or competent external company	FAS Inspection yearly and testing (firedrill) to be conducted every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Daily surveillance of the state of the central control unit. Inspection and testing of FAS to be conducted every 6 months. Routine and extraordinary maintenance in the event of anomalies detected. Verification of the compliance of the installation every 12 years.

PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person (e.g. fire safety specialist)	Inspection and testing of the entire FAS in accordance with manufacturer's instructions, but at least yearly. Voice Communication system to be inspected in accordance with manufacturer's instructions, but at least yearly. Fire signage inspection and testing in accordance with internal procedures or good practice. Electric signage should be inspected at least yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI Safety Signs at a Place Work - Health and Safety Authority (hsa.ie)	Weekly testing by competent person (manager) Inspections and testing by competent person, generally outsourced.	Testing of the fire alarm system weekly. Annual inspection and test with maintenance (service) of all the components of the FAS at least every 6 months. Voice Communication Systems need to be tested weekly and serviced every 6 months. Fire signage should be inspected at regular intervals based on risk assessment.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist (e.g. fire protection technician)	Before activation of fire alarm system: Complex inspection During the use of fire alarm system: Annual inspection unless producer of equipment prescribes more frequent inspections.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5499 - Safety Signs, Including Fire Safety Signs ISO 7010 - Safety colours and safety signs — Registered safety signs BS 5839 – Fire detection and fire alarm systems for buildings	Weekly testing by competent person (manager) Inspections and testing by competent person, generally outsourced	Testing of the fire alarm system (including RED break glass point) weekly. Annual inspection and test with maintenance (service) of all the components of the FAS at least every 12 months. Voice Communication Systems need to be tested weekly and serviced quarterly and annually. Fire signage should be inspected at regular intervals based on risk assessment.