AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Firefighting media
APM Object	CT.FIRE.FIGHTINGEQUIP
APM Description	Firefighting media (e.g. fire extinguishers, fire blankets, etc.).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

All sites with firefighting equipment (e.g. fire extinguishers, fire blankets, etc.).

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least monthly.	Regular checks to ensure fire extinguisher are in good condition and are unused. If defects are identified, prevent subsequent use through quarantine prior to replacement – do Not use. Report issue.	Competent person, generally internal	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher	PM					EVID		
All		Based on risk assessment, but at least yearly.	Servicing of all fire extinguishers.	Competent person, best practice to outsource (e.g. fire safety engineer).	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher	PM					EVID		
All		Every 5 years for water, powder and foam fire extinguishers. Every 10 years for CO2 fire extinguishers.	Regular pressure and discharge test of all fire extinguishers (extended service)	Competent person, best practice to outsource (e.g. fire safety engineer).	Record of inspections Label must be affixed to the extinguisher after each inspection. Label must show type of extinguisher								5 year 10 Year (CT)
DE	4	Every 5 or 10 years	Additional inner inspection of pressure equipment depending on pressure of the pressure device.	Competent person according to TRBS 1203	Inspection records								5 year 10 Year (CT)
DE	5	Every 10 years	Additional strength / rigidity inspection of pressure equipment depending on pressure of the pressure device (Druckgerät)										10 Year (CT)

IT	7	Every 6 months	Inspection as for [2]	No additional requirements.	CE Declaration of Conformity.	(PM)					EVID		
ROI	6	Every 3 years	Test discharge (and refill) of all extinguishers every 3 years (recommended 33% of all extinguishers every year).	No additional requirements	Service record								3 Year (CT)

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. CSN 73 0802, CSN 11602 - 2, CSN 73 0804, CSN 73 0873, CSN 73 0875	Accredited fire protection specialist	Optime control once a year. Pressure test every 3 years for water and foam fire extinguishers and every 5 years for each other type of fire extinguisher
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbstättV) Technische Regel für Arbeitsstätten ASR A 2.2 - Maßnahmen gegen Brände DIN 14406-4 - Tragbare Feuerlöscher - Teil 4: Instandhaltung Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen	Competent person (befähigte Person) Accredited inspection body (ZÜS) for inner and strength testing/ inspections according to BetrSichV	Based on risk assessment (use and operating conditions), but at least every 2 years for portable fire extinguishers. Additional inner inspection to assess pressure equipment every 5 years, and depending on the type of fire extinguisher, and additional strength test (Festigkeitsprüfung) every 10 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI)	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Check for accessibility, presence, condition, label, etc. every 3 months. Every 12 month by authorised maintenance company. Intrusive inspection carried out by accredited company (OCA) every 10 years.
FR	Labor Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	Checks by qualified or competent person. Service by certified company (APSAD, NF)	Check for accessibility, presence, condition, label, etc. every 6 months. Servicing of fire extinguishers annually.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 20/12/2012 DM 10/03/1998 (Currently being replaced) UNI 9994:2013 (Fire extinguishers maintenance) UNI EN 3-7:2008 (Performance requirements) Directive 2014/68/EU	Competent, qualified person, best practice to outsource to specialist.	Monthly check for accessibility, presence, condition, label and manometer's needle in green position (surveillance). Inspection of all fire extinguishers every 6 months (correct filling in of the maintenance card and check of the state of charge through weight measurement (CO_2) or independent pressure verification). Technical review every 24 months for water or foam extinguishers (48 months in presence of inox tanks), every 36 months for powder devices and every 60 months for CO_2 extinguishers. Testing every 6 years for foam devices (12 for inox tanks), 12 years for powder devices and every 10 years for CO_2 extinguishers.
PL	Regulation of the Minister of Internal Affairs and Administration dated 7 June 2010 on the fire protection of buildings, other buildings and sites OJ 2010 No 109, item 719 Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	Qualified or competent person (e.g. fire safety specialist)	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) I.S 291:2015 The Use, Siting, Inspection and Maintenance of Portable Fire Extinguishers NSAI	Competent person, best practice to outsource to specialist	Monthly checks to ensure fire extinguishers are in good condition and unused. Annual servicing 3 yearly test discharge and refill
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 719/2002 Coll. on characteristics, operating conditions and ensuring regular inspection of portable fire extinguishers and mobile fire extinguishers	Qualified and certified person.	Every 12 months or 24 months depending on the type of fire extinguisher and manufacturer's instructions

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Monthly checks by competent person (internally). Inspection and servicing by competent person, best practice to outsource to specialist.	Monthly checks to ensure fire extinguishers are in good condition and unused. Annual inspection of all (P50 extinguishers only every 10 years). 5 yearly extended service for water, foam and powder fire extinguishers and 10 years for CO2 fire extinguishers.