AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Risk Management (FRA)
APM Object	CT.FIRE.FRAMANAGEMENT
APM Description	Fire risk assessment
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

All non-domestic properties are required to complete a suitable and sufficient Fire Risk Assessment (FRA) specific to each site identifying the risks to relevant persons and the fire precautionary measures that need to be implemented in order to comply with relevant regulations, as well as the emergency procedures to follow in the event of a fire.
FRAs need to be reviewed and updated regularly to reflect the most up-to-date situation of the premises.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Before the premises are occupied for the first time. At regular intervals based on risk assessment, but at least every 12 months. Following any changes to the number of occupants, materials stored, furniture, equipment	A Fire Risk assessment needs to be completed for all non-domestic premises. As a minimum, it should cover fire detection systems, emergency exits, emergency signage and routes (including evacuation plans), firefighting equipment and the availability of information and advice to the building's occupants.	Competent person (e.g. fire risk assessor, fire technician engineer).	Current Fire Risk Assessment document Major findings and reportable issues.						CT		Additional As Required CT
IT	2	Before the premises are occupied.	CLASS A: submission of the SCIA and work project followed, on a sample basis within 60 days, by inspections of the Fire Brigade.	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								As Needed CT
IT	2a	Every 5 years for most activities.	CLASS B: presentation of the prior opinion of conformity for which the fire brigade gives an answer within 60 days, followed by the submission of the SCIA in the manner described above.	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								5Yr CT*
IT	2b	Every 10 years for activities listed in rows 6, 7, 8, 64, 71, 72, 77 of the Annex. I of DPR 151/20	CLASS C: submission of the prior opinion of conformity for which the Fire Brigade gives response within 60 days, followed by the presentation of the SCIA with systematic control of the Fire Brigade and release of the CPI	Fire Brigade	Certificato di Prevenzione Incendi (CPI). Segnalazione Certificata Inizio Attività (SCIA)								10Yr CT*
PL	3	Before the construction of the building and prior to any alteration that may affect fire safety.	Certain buildings are required to prove compliance with fire protection in relation to the purpose, method of usage, running technological process, the method of storage, fire hazards and technical conditions occurring in the building, including fire hazards ("Project reconciliation")	No additional requirements	Documentation to prove compliance with fire protection.								As Needed CT

PL	4	Reviewed after changes to the number of occupants, materials stored, furniture, equipment, activities or any alteration to the building.	Completion of a Fire Safety Instruction, including emergency procedures, drawings, etc.	Manager or owner	Fire Safety Instruction								As Needed CT
ROI	5	Before the construction of new buildings and alterations, changes to materials or use of existing buildings.	A Fire Safety Certificate is required prior to the construction of new buildings and alterations, changes to materials or use of existing buildings.	Fire safety consultant, architect or engineer for FSC	Fire Safety Certificate								As Needed CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Act. No. 133/1985 Coll.	Authorised person in the field of fire protection	Before the construction of new buildings and modifications, changes in materials or use of existing buildings, the development of a Fire Safety Solution for the construction is required
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände ASR A2.3 - Fluchtwege und Notausgänge, Flucht- und Rettungsplan DIN 14095 - Feuerwehrpläne für bauliche Anlagen DIN 14096 - Brandschutzordnung - Regeln für das Erstellen und das Aushängen	Competent person (befähigte Person)	FRA needs to be completed before the premises are occupied, in case of significant (structural and technical) changes and regularly based on risk assessment but at least every 2 years
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA).	Accredited company (OCA) in case of inspections on industrial premises	FRA needs to be completed before the premises are occupied and every time any change in the facility is carried out. In case of industrial premises FRA needs to be inspected according to their Intrinsic Risk (art. 7 RD 2267/2004: 2, 3 or 5 years).
FR	Labor Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	No additional requirements	No additional requirements
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced)	Fire risk assessment conducted by a competent person (outsourced to specialist). Fire Prevention Certificate (CPI) and SCIA provided by Fire Brigade	FRA is required in businesses with more than 10 employees or for activities subject to control by the Fire Brigade in accordance with DPR 151/2011. Additional inspections to ensure appropriate building design in relation to fire safety required depending on the type of building and associated risk (Class A, B or C). Successful inspections lead to the provision of a Fire Prevention Certificate Certificato di Prevenzione Incendi – (CPI, for activities of Category C), which needs to be renewed every 5 years, ,every 10 years for activities listed in rows 6, 7, 8, 64, 71, 72, 77 of the Annex I of DPR 151/2011.
PL	Ordinance of the Minister of Internal Affairs and Administration of 7 June 2010 on Fire Safety of Buildings, Other Constructions and Sites (Dz.U. 2010, No. 109, Item 719), Section 36 Regulation of the Minister of Internal Affairs and Administration of 2 December 2015 on the reconciliation of the construction project in terms of fire protection Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869)	Qualified or competent person, best practice to outsource to fire safety expert.	FRA is part of general workplace risk assessment. Regular reviews, generally every 1 or 2 years, and following any significant changes that might affect fire risk. Additionally, businesses are required to complete a Fire Safety Instruction, which includes procedures in case of fire, drawings, fire equipment, etc. Certain buildings are required to prove compliance with fire protection in relation to the purpose, method of usage, running technological process, the method of storage, fire hazards and technical conditions occurring in the building, including fire hazards. This needs to be completed before the construction of the building and prior to any alteration that may affect fire safety.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) Fire - Health and Safety Authority (hsa.ie)Fire Services Act, 1981 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company (e.g. fire safety engineer or assessor) for FRA. Fire safety consultant, architect or engineer for FSC	FRA needs to be completed before the premises are occupied, and reviewed regularly. The frequency of the review is determined as part of the risk assessment, but it is good practice to do so at least every 12 months. FRA reviews should also be conducted before any changes to the occupants, the activities, the materials stored or located in the premises, and any alteration to the building. A Fire Safety Certificate is required prior to the construction of new buildings and alterations, changes to materials or use of existing buildings.
SK	Ordinance No. 94/2004 Coll. technical requirements for fire safety during construction and use of buildings Ordinance No. 611/2006 Coll. on fire-fighting brigades	Competent and certified person	FRA needs to be completed before the premises are occupied. FRA is being prepared on the request from the side of fire-surveillance authority. Analysis needs to be adapted based at changed conditions within the time frame of 3 month from the factual change of situation.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) BS 9999 : 2017 The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS 9999 : 2017 – Fire safety in the design, management and use of buildings. Code of practice. DocHdl1OnPTRSERVERtmpTarget (publishing.service.gov.uk)	Competent person, best practice to outsource to specialist company (e.g. fire safety engineer or assessor)	FRA needs to be completed before the premises are occupied, and reviewed regularly. The frequency of the review is determined as part of the risk assessment, but it is good practice to do so at least every 12 months, but not longer than every 5 years. Additionally, FRA reviews should be conducted before any changes to the occupants, the activities, the materials stored or located in the premises, and any alteration to the building.