AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hose reels
APM Object	CT.FIRE.HOSES
APM Description	Hose reels for fire fighting.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.HDRNT	**Related CT Areas:**	Not Specified		

Scope

Any site where hose reels are installed to aid firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 6 months.	Routine maintenance to ensure correct operation and integrity of the hose reels	Competent person (e.g. engineer), generally outsourced	Maintenance logbook					CT			
All	2	Every 12 months	Water pressure check	Competent person (e.g. engineer), generally outsourced	Inspection & test records	PM					EVID		
All	3	Every 5 years	Full water pressure test.	Competent person (e.g. engineer), generally outsourced	Inspection & test records	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit

DE	DIN EN 671-3:2009-07 - Ortsfeste Löschanlagen - Wandhydranten - Teil 3: Instandhaltung von Schlauchhaspeln mit formstabilem Schlauch und Wandhydranten mit Flachschlauch; Deutsche Fassung EN 671-3:2009 DIN EN 694:2014-10 - Feuerlöschschläuche - Formstabile Schläuche für Wandhydranten DIN 14462:2012-09 – Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten DIN 14461-1 Feuerlösch-Schlauchanschlusseinrichtungen	Qualified person (sachkundige Person) according to DIN 14462	A full assessment including operating pressure test, at least once a year for wet risers and wet/dry risers and every two years for dry risers. Annual inspection of pressure hoses W (dimensionally stable hoses). Pressure hoses C (collapsible hoses) inspection interval every 5 years or after each use. A highest permissible operating pressure test every 5 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE: 23091. firefighting equipment. impulsion hose: flat flexible hose of 25, 45, 70 and 100 mm. for hard service.	Quarterly servicing by competent person. Annual, maintenance by authorised company. 10 years inspections by accredited company (OCA).	Check for accessibility, presence, condition, label, etc. every 3 months. Every 12 month by authorised maintenance company. Fully and intrusive Inspection every 10 years.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams APSAD - voluntary standard for insurance	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 10779:2021 (Fire hydrant networks) UNI EN 671-3:2009 (Maintenance)	Competent, qualified person.	Maintenance every 6 months. Water pressure check every 12 months. Full water pressure test every 5 years.
PL	Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Internal Affairs and Administration of 2 December 2015 on the reconciliation of the construction project in terms of fire protection	Qualified or competent person	According to manufacturer's instruction but at least once per year. Pressure test once every 5 years. (at their maximum working pressure, which is 1.2 MPa)
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 671-3:2009 Fixed Firefighting Systems - Hose Systems - Part 3: Maintenance of Hose Reels with Semi-rigid Hose and Hose Systems with Lay-flat hose (NSAI)	Competent person, best practice to outsource to specialist	Visual inspection (maintenance) at least every 6 months. Water pressure check every 12 months. Water pressure test every 5 years
SK	Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent person, best practice to outsource to specialist	Inspections every 12 months unless stated otherwise by manufacturer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice British Standard EN-671/3 (Fixed firefighting systems. Hose systems)	Competent person, best practice to outsource to specialist	Visual inspection (maintenance) at least every 6 months. Water pressure check every 12 months. Water pressure test every 5 years