AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire hydrants
APM Object	CT.FIRE.HYDRANTS
APM Description	Fire hydrants
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 6M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.HDRNT	**Related CT Areas:**	Not Specified		

Scope

Any site with fire hydrants under their jurisdiction to provide a water supply connection for firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 6 months	Visual checks to ensure there is no apparent damage to the hydrant frame and cover. General maintenance of fittings.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	2	At least every 6 months	Cut back and clear any overgrown vegetation.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	3	At least every 6 months	Check information on hydrant plate is accurate and clearly visible.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	4	At least every 6 months	Check the hydrant pit and hydrant itself for integrity, debris and leakage.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		
All	5	At least every 12 months	Inspection and testing of hydrant, including wet test, water pressure and flow.	Competent person	Maintenance logbook Inspection records, report or certificate	PM					EVID		

DE	6	Every 3 years.	Additional inspection and testing for effectiveness and operational safety according to building law.	Expert according to state building law	Inspection records				(CT)				
ES	7	every 3 to 6 months	General maintenance (accessibility, tightness of connections, grease and check condition of fittings, etc.).	Accredited company or internal competent person	No additional requirements	PM					EVID		
IT	8	Every 5 years.	Full water pressure test	No additional requirements.	No additional requirements.								5 Year CT

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit
DE	Technische Regel für Arbeitsstätten: ASR A2.2 - Maßnahmen gegen Brände DIN EN 671-3:2009-07 - Ortsfeste Löschanlagen - Wandhydranten - Teil 3: Instandhaltung von Schlauchhaspeln mit formstabilem Schlauch und Wandhydranten mit Flachschlauch; Deutsche Fassung EN 671-3:2009 DIN 14462:2012-09 – Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten Federal State construction laws and according to building permits	Inspection by qualified person (sachkundige Person) according to DIN 14462 Building regulations inspection by expert according to state building law, legitimation and certificate necessary.	Inspection frequency in accordance with the manufacturer's specifications, but no longer than 1 year. Additional inspection and testing for effectiveness and operational safety according to building law every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 14384: 2006. Pillar fire hydrants. UNE-EN 14339:2006. Underground fire hydrants.	Quarterly and half-year servicing by competent person. Annual, quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	General maintenance every 3 to 6 months (accessibility, tightness of connections, grease, and check condition of fittings, etc.). Every 12 months: water tightness in plugs. Every 5 years: Change of the union joints. Intrusive inspections.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD or NF - voluntary standard for insurance	APSAD and NF certified companies	Annual inspection and testing.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 10779:2021 (Fire hydrant networks)	Competent, qualified person, best practice to outsource to specialist.	Regular checks of hydrant every 6 months. Water pressure testing every 12 months. Regular checks of water tank and full water pressure test every 5 years.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030)	Qualified or competent person, usually a fire safety specialist	Inspection and testing yearly.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 14339:2005 Underground Fire Hydrants I.S. EN 14384:2005 Pillar Fire Hydrants	Competent person, best practice to outsource to specialist (engineer)	Inspection and testing of fire hydrants, including water pressure testing and flow annually.
SK	Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent person, best practice to outsource to specialist.	Inspections every 12 months unless stated otherwise by manufacturer.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk)	Competent person, best practice to outsource to specialist (engineer)	Inspection and testing of fire hydrants, including water pressure testing and flow annually.