AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Smoke detectors
APM Object	CT.FIRE.SMOKEDETECT
APM Description	Fire (smoke and heat) detectors
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.DET.FIREALRM	**Related CT Areas:**	CT.FIRE.FAS		

Scope

Any site where smoke and heat detectors are installed to give early warning in the event of fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Every 3 months	Functional inspection and testing of 1 detector per area or transmission path.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	PM					EVID		
All	2	Every 6 months	Servicing of all smoke and heat detectors to ensure correct operation of the system.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	(PM)					(EVID)		
All	3	Every 12 months	Testing of all detectors.	Competent person, best practice to outsource (e.g. fire safety engineer).	Maintenance logbook Risk assessment Inspection records, report or certificate.	(PM)					(EVID)		
CZ	4	Every 6 months	Inspection as per [3]	No additional requirements	No additional requirements					CT			
FR	5	Every 6 months	Inspection as per [3]	No additional requirements	Fire/Security register					CT			

IT	6	Every 6 months	Inspection as per [3]	No additional requirements	No additional requirements					CT			
IT	7	Every 12 years.	Verification of the compliance of the installation.	No additional requirements	No additional requirements	(PM)					(EVID)		
SK	8	In case of a need to perform more frequent than annual inspection: Monthly (mechanical check, communication channels): or Quarterly (functional control, power supply, remote controls, data recording).	Inspection as per [3].	No additional requirements	No additional requirements	(PM)					(EVID)		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. on Fire Protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually.
DE	Arbeitsstättenverordnung (ArbStättV) DIN 14675 - Brandmeldeanlagen, Teil: 1 Aufbau und Betrieb und Teil 2: Anforderungen an die Fachfirma DIN 18232 - Rauch- und Wärmefreihaltung DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen.	Qualified electrician FAS	In accordance with manufacturer's recommendations. Functional inspection of 1 detector per transition path every 3 months according to DIN 14675 und DIN VDE 0833. Annual maintenance according to DIN 14675 and inspection. Replacing components with a limited service life (e.g. fire detectors, accumulators, devices and storage batteries) after expiry of technical useful life.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23007:2020. Fire detection and fire alarm systems.	Quarterly servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Routine checks (maintenance) every 3 months. Official maintenance operation every year. Fully inspections every 10 years.
FR	Labor Code Article R4227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Inspection of fire and smoke detectors every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11224:2019 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Periodic maintenance and inspections of all detectors every 6 months for conventional detection systems. Analogue addressed detection systems are subject to the inspection of 25% of the detectors every 6 months from the first year to the sixth year, from the seventh year to the twelfth year 50% of all detectors must be inspected every 6 months. Routine and extraordinary maintenance in the event of anomalies detected. Verification of the compliance of the installation every 12 years.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065)Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. 3218:2013 Fire Detection and Alarm Systems for Buildings - System Design, Installation, Commissioning, Servicing and Maintenance NSAI	Competent person, best practice to outsource to specialist.	Testing of 1 detector per zone every 3 months. Servicing of all detectors every 6 months. Testing of all detectors every 12 months.
SK	Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent person, best practice to outsource to specialist (e.g. fire protection technician)	Regular inspections. In case annual inspection is performed, more frequent inspections are not needed.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice	Competent person, best practice to outsource to specialist.	Testing of 1 detector per zone every 3 months. Servicing of all detectors every 6 months. Testing of all detectors every 12 months.