AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Smoke vent systems
APM Object	CT.FIRE.SMOKEVENTS
APM Description	Smoke vent systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	FIRE.SUP.SMOKEHEATVENT - FIRE.SUP.SMOKEEXT	**Related CT Areas:**	Not Specified		

Scope

All site where smoke vent systems are used to provide an escape route for the smoke in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Every 3 months	If the smoke ventilation system is interfaced with the Fire Alarm System, regular testing when the alarm is tested.	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	2	Every 3 months	Visual inspection of ventilation systems for obstructions and cleaning (regular maintenance)	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	3	Every 3 months	Smoke control system to be simulated on all zones (area) fitted with a smoke vent.	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment						CT		
All	4	Every 12 months	Regular servicing of the entire smoke vent system to ensure correct operation (e.g. key features such as seals and actuator) .	Competent person	Maintenance logbook Inspection records, report or certificates Risk assessment	PM					EVID		
DE	5	Every 3 years	Additional inspection to assess compliance with building regulation.	expert according to building law	Inspection records								3Y CT

FR	6	Every 6 months	Inspection as per [3].	No additional requirements	Fire/Security register	(PM)					(EVID)		
IT	7	Every 6 months	Inspection as per [3].	No additional requirements	CE Declaration of Conformity.						(CT)		
PL	8	Every 6 months	Inspections as per [3] for buildings with an area greater than 2000 m2 or roof area greater than 1000 m2.	No additional requirements	No additional requirements					CT			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) DIN 18232 - Rauch- und Wärmefreihaltung DIN VDE 0833-1 - Gefahrenmeldeanlagen für Brand, Einbruch und Überfall - Teil 1: Allgemeine Festlegungen. Model Ordinance for Inspections (Muster-Prüfverordnung)	3 annual inspection by expert according to building la.	Visual inspection every 12 months. Functional and operational inspection in accordance with manufacturer's instruction, but at least yearly. In the case of particularly dirty or dusty operating sites, the maintenance intervals should be reduced accordingly. Additional inspection to assess compliance with building regulations every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). UNE 23585:2017. Fire safety. Smoke and heat control systems. Requirements, calculation and design methods for temperature control systems and smoke exhaust systems projecting in case of stationary	Quarterly servicing by competent person Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular visual checks for obstructions or changes that might affect the effectiveness of the smoke vents every 3 months. Functional inspection (manual activation) and cleaning of the system every 6 months. Every year: Functional inspection of system positions, including manual and automatic signals. Smoke curtains testing, power supply testing. Inspection of smoke vents system every 10 years.
FR	Labor Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Regular inspections every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 9494-3:2014 (Maintenance)	Competent, qualified person, best practice to outsource to specialist	Regular maintenance and surveillance. Initial inspection and regularly every 6 months.
PL	Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	Regular inspections every 12 months, or every 6 months for buildings with an area of more than 2000 m2 or a roof area of at least 1000 m2.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 12101-2:2017 - Smoke and heat control systems. Natural smoke and heat exhaust ventilators	Weekly and quarterly inspections conducted by manager or owner. Service is best practice to outsource to specialist engineer.	If interfaced with alarm, testing of smoke vents weekly. Smoke control system to be simulated on all zones every 3 months. Annual service of smoke ventilation system.
SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention Ordinance no. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of fuel appliances, electrothermal appliances and central heating equipment and in the construction and use of chimneys and flues and the deadlines for their cleaning and inspections	Competent person, best practice to outsource to specialist	Regular inspections every 12 months.

UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 12101-2:2017 - Smoke and heat control systems. Natural smoke and heat exhaust ventilators	Weekly and quarterly inspections conducted by manager or owner. Service is best practice to outsource to specialist engineer.	If interfaced with alarm, testing of smoke vents weekly. Smoke control system to be simulated on all zones every 3 months. Annual service of smoke ventilation system.