AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Sprinkler systems
APM Object	CT.FIRE.SPRINKSERVICE
APM Description	Sprinkler systems, associated pipework and storage tanks
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP - FIRE.SUP.HDRNT - FIRE.SUP.PRESSWTR.VESSELS - MTR.FIRE-DSL - FIRE.SUP.PUMP.JP - FIRE.SUP.PUMP.CNTRL	**Related CT Areas:**	FIRE.SUP.FOAM		

Scope

Any site where a sprinkler system is used to prevent, extinguish and/or contain fire from spreading or occurring.
Fire pumps inspection requirements are covered under CT.FIRE.PUMP
Dry risers inspection requirements are covered under CT.FIRE.DRYRISERS
Fire hydrant inspection requirements are covered under CT.FIRE.HYDRANTS

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	Inspection of valves to ensure they are locked and open, water levels, water and air pressure gauges, water flow alarm, etc.	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	PM					EVID		
All	2	Monthly	Regular checks of batteries and sprinkler tanks	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	3	In accordance with risk assessment, but at least annually.	Regular inspections of sprinkler heads for obstructions	Competent person usually internal	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	4	Based on risk assessment and type of installation, but at least annually	Regular professional servicing of the sprinkler system	Competent person, best practice to outsource	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.	(PM)					(EVID)		
All	5	Every 3 years	Draining and overhauling of sprinkler tanks and valves	Competent person	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.								3Y CT

All	6	Every 10 years	Internal and external examination of tanks for corrosion, deterioration or damage	Competent person	Inspection records, report or certificate. Testing reports. Risk assessment Maintenance logbook and records.								10Y CT
All	7	Based on risk assessment and type of installation, but between 12 and 25 years.	Laboratory testing of sprinkler heads	Competent Person to sample. Analysis to be completed at UKAS accredited laboratory	Analysis results								12Y CT
DE	8	Monthly	Inspection as per [3]	No additional requirements	Inspection records and certificate			CT					
DE	9	Every 12.5 years for wet plants and 25 years for dry plants	Inspection as per [7]	No additional requirements	No additional requirements								12,5Y CT
DE	10	Every 25 years for wet plants and 12.5 years for dry plants	Inspection of pipe network	No additional requirements	No additional requirements								12,5Y & 25Y CT
DE	11	Every 3 years	Additional inspection to comply with building regulations	Expert according to building law	Inspection records								3Y
ES	12	Every 3 to 6 months	Inspection as per [4]	Accredited company or competent person.	No additional requirements	(PM)					(EVID)		
FR	13	No additional requirements	Inspection as per [1] to [7]	No additional requirements	Fire/Security register	(PM)					(EVID)		12Y CT
IT	15	Every 3 months	Hazard level reassessment, valves inspection, sprinklers inspection, inspection of piping and associated supports, inspection of water and electrical supplies, check of the number of spare sprinklers available.	No additional requirements	No additional requirements						CT		
IT	16	Every 6 months	Inspection of dry alarm valves, verification of the efficiency of escort equipment, inspection of the alarm reporting link with the fire station.	No additional requirements	No additional requirements					CT			
IT	17	Every 3 years	Inspection as per [6].	No additional requirements	No additional requirements								10Y CT
IT	18	Every 10 years	Cleaning and waterproofing interventions, examination of water reserves.	No additional requirements	No additional requirements								10Y CT
IT	19	Weekly (visual inspection, functionality check, control of pre-defined parameters/values) Monthly (visual inspection, functionality check) Annually (visual inspection, functionality check, control of metric systems, technical	In case frequency of inspections is not prescribed by manufacturer, following frequencies apply	No additional requirements	No additional requirements	(PM)					(EVID)		
UK	14	At least annually	Regular audits to ensure compliance with relevant regulations	Third party, independent from service provider	Audit records and actions.						CT		

Related Regional Legislation			
Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Decree no. 246/2001 Coll. Act. No. 133/1985 Coll	Accredited company - manufacturer-trained worker	Inspection and service every 12 months unless the manufacturer sets a shorter time limit
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) Betriebssicherheitsverordnung (BetrSichV) DIN 14464 Direktanschlussstationen für Sprinkleranlagen und Löschanlagen mit offenen Düsen – Anforderungen und Prüfung DIN 1988-600 Technische Regeln für Trinkwasser-Installationen – Teil 600: Trinkwasser-Installationen in Verbindung mit Feuerlösch- und Brandschutzanlagen DIN EN 12259-1 Ortsfeste Löschanlagen – Bauteile für Sprinkler- und Sprühwasseranlagen – Teil 1: Sprinkler	Accredited inspection body (ZÜS) for inspections according to BetrSichV Regular checks and controls conducted by internal personnel (trained). All maintenance, repair and modification work should be carried out by the company that built the installation. Inspections and examination conducted by external professional, qualified and authorised to undertake the task.	Inspections according to BetrSichV comprise inspections prior first use (vor Inbetriebnahme), after significant changes (vor Wiederinbetriebnahme nach prüfpflichtigen Änderungen); inner inspection of pressure devices every 5 years and strength testing every 10 years of pressure devices. Regular checks to ensure correct status and operation: - Weekly (e.g. test alarm at the valve station); - Monthly (e.g. functional readiness of the pumps and their drives, control of oil levels of pumps and diesel engines, checking the function of the proportioning device, checking the devices for operating and releasing fire doors and flaps in CO2 extinguishing systems); and - Quarterly (e.g. sprinklers and control valves for deposits(dirt))
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 12845:2016+A1:2021. Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance.	Quarterly and half-year servicing by competent person. Annual, triennial and quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance of extinguishing agents and system components, including reading and checking manometers, checking signalling circuits and general cleaning every 3 months. Visual checks of pipes, tanks and hoses and their infrastructure every 6 months. Fully inspection every 1, 3 and 5 years. Intrusive Inspections every 10 years.
FR	Labor Code Article R47227-39 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Regular sprinkler testing every 6 months. Inspections of sprinkler head obstructions every 6 months. Servicing of sprinkler system every 6 months.
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 12845:2020 (Maintenance)	Weekly and monthly testing conducted by internal employee (trained) Inspections conducted by competent, qualified person, best practice to outsource to specialist.	Pressure check, water level inspection, valves inspection and start-up test of pump and diesel engine conducted weekly by trained employee. Batteries check and inspection of the electrolyte level every month by trained employee. Hazard level reassessment, valves inspection, sprinklers inspection, inspection of piping and associated supports, inspection of water and electrical supplies, check of the number of spare sprinklers available every 3 months. Inspection of dry alarm valves, verification of the efficiency of escort equipment, inspection of the alarm reporting link with the fire station every 6 months. Tests of pump flow rate, of the failure to start the engine, float valve tests, tests on suction chambers and pump filters every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030) Regulation of the Minister of Interior and Administration of June 16, 2003 on the reconciliation of a	Competent person, usually a fire safety specialist.	Sprinkler testing in accordance with manufacturer's instructions, but at least yearly. Inspections of sprinkler head obstructions in accordance with manufacturer's instructions, but at least yearly. Servicing of the sprinkler system at least yearly
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) I.S. EN 12845:2015+A1:2019 Fixed Firefighting Systems - Automatic Sprinkler Systems - Design, Installation and Maintenance NSAI	Weekly inspections of valves and inspections of sprinkler heads by internal employee (trained). Servicing of sprinkler system by competent specialist	Weekly inspection of all valves to ensure they are locked and fully open, water levels, water and air pressure gauges, water flow alarm test, etc.. Monthly checks of batteries and sprinkler tanks Regular servicing of sprinkler systems at least every 12 months. Additional inspection to ensure compliance (audit) every 12 months Internal and external examination of tanks every 10 years. Inspection of sprinkler heads for obstructions in accordance with fire risk assessment and manufacturer's instructions. Regular servicing of sprinkler systems at least every 12 months.
SK	Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection	Qualified and certified person	Frequency of inspections prescribed by manufacturer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice BS EN 12845: 2015 + A1: 2019 Fixed firefighting systems. Automatic sprinkler systems. Design, installation and maintenance	Weekly inspections of valves and inspections of sprinkler heads by internal employee (trained). Servicing of sprinkler system by competent specialist. Annual audit by independent third party	Weekly inspection of all valves to ensure they are locked and fully open, water levels, water and air pressure gauges, water flow alarm test, etc.. Monthly checks of batteries and sprinkler tanks Inspection of sprinkler heads for obstructions in accordance with fire risk assessment and manufacturer's instructions. Regular servicing of sprinkler systems at least every 12 months. Additional inspection to ensure compliance (audit) every 12 months Draining and overhauling of sprinkler tank every 3 years (unless classified as a 10 year tank). Internal and external examination of tanks every 10 years. Sprinkler head testing at laboratory at least every 25 years (unless manufacturer specifies earlier).