AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Compliance - Air Conditioning > 12kW
APM Object	CT.HVAC.12kW
APM Description	Air conditioning systems with an effective rated output of more than 12kW, with addition requirements if >12kW.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.CHILL HVAC.AC HVAC.CU	**Related CT Areas:**	Not Specified		

Scope

Any site with air conditioning systems with an effective rated output of more than 12 kW, when either an individual unit is ≥ 12 kW or multiple individual units of < 12 kW are connected in the same system to give ≥ 12 kW in total.
This applies to all refrigerants including non-fluorinated e.g Ozone Depleting Substances like R22. This is a sustainability-driven requirement to identify system defects that can lead to leaks.
Additional requirements are present for systems >70kW.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 5 years, at regular intervals. Defects and opportunities for improvement to be scheduled as required.	Intrusive inspections and condition assessment.	Qualified or Competent Person (e.g. energy assessor), registered with appropriate certification body	Retain records of most recent inspection.								5 Year CT
All	2	Annual	Maintenance of system (>12kW <70kW)	Qualified or Competent Person	Retain records of maintenance	PM					EVID		
All	3	Monthly	Maintenance of system (>70kW)	Qualified or Competent Person	Retain records of maintenance	PM					EVID		
ES	6	Every 2 years	For installations with power above 70 kW	No additional requirements	Cooling/refrigeration systems >70kW must be legalised through a project	PM					EVID	(CT)	
FR	5	Every 2 years	Inspection thermodynamic systems with an effective rated output of between 4 kW and 70 kW.	No additional requirements	No additional requirements	PM					EVID	(CT)	

IT	4	No additional requirements	Inspection as per [1].	No additional requirements	Installation logbook. CE Declaration of conformity.								N A R

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Energy management Act No. 406/2000 Coll., §6a Regulation No. 193/2012 Coll., on the inspection of air-conditioning systems	Authorised energy inspector.	First inspection 10 years after commissioning (12-100 kW), 4 years (>100 kW), then regular inspection every 10 years (12-100 kW, >100 kW with continual monitoring system), 4 years (>100 kW without continual monitoring system) Above mentioned are energy performance inspections, inspections of units/systems containing refrigerants are set independently (see 35&36 compliance standards).
DE	Gebäudeenergiegesetz - GEG – Abschnitt 3: Energetische Inspektion von Klimaanlagen Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Expert (Fachkundiger), according to GEG.	Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Inspection in the 10th year after commissioning, and then at least every 10 years thereafter (for energy efficiency). When operating more than ten systems of the same type and output in comparable non-residential buildings, a sampling procedure will be permissible.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required. Maintenance carried out annually. Inspections every 15 12 monthsyears (Pn>20KW heat, Pn>12kW cold)
FR	Environment Code : Art. R224-44 to R224-44-5 relating to maintenance on thermodynamic systems with an effective rated output of between 4 kW and 70 kW Paragraphe 1 : Entretien des systèmes thermodynamiques dont la puissance nominale est comprise entre 4 kW et 70 kW (Articles R224-44 à R224-44-5) - Légifrance (legifrance.gouv.fr) Arrêté du 24 juillet 2020 relatif à l'entretien des systèmes thermodynamiques dont la puissance nominale est comprise entre 4 kW et 70 kW - Légifrance (legifrance.gouv.fr) Environment Code : Art. R224-45 to R224-45-9 relating to maintenance on thermodynamic systems with an effective rated of > 70 kW Paragraphe 2 : Inspection des systèmes thermodynamiques et des systèmes de ventilation combinés à un chauffage par effet joule d'une puissance nominale supérieure à 70 kW (Articles R224-45 à R224-	Accredited person	Inspection every 2 years (thermodynamic systems with an effective rated output of between 4 kW and 70 kW). Inspection every 5 years (thermodynamic systems with an effective rated output of > 70 kW).
IT	Legislative Decree 9/04/2008 n.81 DPR n.74/13 Decree 10/02/2014 D.M. 37/2008 DPR n. 146/18 UNI EN 15218:2013 (Terms, definitions, test conditions and methods, requirements) UNI EN 14511-1:2018 (Terms and definitions) UNI EN 14825:2019 (Test methods and seasonal performance evaluation) UNI 11135:2004 (Seasonal performance evaluation) UNI EN 16798-17:2018 (Guidelines for inspections)	Competent and accredited person.	Inspections every 4 years.
PL	Regulation of Minister of Labor and Social Policy of 26 September 1997 on general health and safety regulations (Journal of Laws 2003, number 169, item 1650) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	N/A	N/A
ROI	S.I. No. 346/2006 - European Communities (Inspection and Assessment of Certain Air-Conditioning Systems) Regulations 2006 (irishstatutebook.ie)	Accredited energy inspector and assessor.	Regular inspections every 5 years after the unit has been commissioned.
SK	Act No. 286/2009 Coll. on fluorinated greenhouse gases Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems STN EN 378-2: Refrigerating systems and heat pumps. Safety and environmental requirements	Qualified and certified person.	Regular inspections every 5 years. Inspection of actual performance efficiency improvements proposal.
UK	The Energy Performance of Buildings (England and Wales) Regulations 2012 (legislation.gov.uk) Building (Scotland) Amendment Regulations 2006 SSI 534 Energy Performance of Buildings (EPB) (Certificates and Inspections) Regulations (Northern Ireland) 2008, as amended	Accredited energy assessor for TM44.	Regular Inspections, at least every 5 years.