AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Boilers
APM Object	CT.HVAC.BOILERS
APM Description	Gas-powered boilers and associated infrastructure (e.g pipework, flues etc).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.BLR HVAC.HTR HVAC.GHGAS	**Related CT Areas:**	CT.PRESSURE.SYS, CT.HVAC.GASINSTALL		

Scope

Any site with gas boilers designed to provide heating or hot water.
This Compliance Standard only covers the maintenance of boilers, inspections of expansion tanks and pressure vessels is covered in Compliance Standard CT.PRESSURE.SYS and gas installations in CT.HVAC.GASINSTALL

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas-fired boilers.	Competent Person (Accredited on Gas Safe Register).	Maintenance records, examination report or certificate.	PM					EVID		
All	2	Inspections to be carried out at least every 12 months, as best practice. Consider scheduling in summer.	Examination of safe operation, physical integrity and ensure performance of the boiler. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance records, examination report or certificate.	PM					EVID		
All	3	Slam shut-off valves to be inspected every 12 months	Regular checks of slam shut-off valves (if present) to ensure correct operation.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.).	Maintenance records, examination report or certificate.	PM					EVID		
CZ	4	Slam shut-off valves to be inspected every 4 months.	Inspection as per [3].	Certified specialised gas equipment technician.	Maintenance logbook.	(PM)					EVID		
DE	5	Every 2 years for plant older than 12 years (≤12J) Every 3 years for plants of 12 years or less.	Monitoring measurements based on heating plant certificate.	Chimney sweeper	Records of monitoring measurements. Sweep logbook Heating Plant Certificate							CT	

FR	6	Every 2 years for systems > 400kW and <20MW	Inspection as per [2]	Certified specialised gas equipment technician.	Control Report	(PM)					EVID		
PL	7	Every 6 months	Inspection of shut-off valves in buildings of more than 2000 m2.	No additional requirements	No additional requirements	PM					EVID		
SK	8	Before first operation, during general maintenance or building reconstruction, during change of fuel, after 12 months of operation (at the beginning of every season in case of seasonal operation).	Inspections as per [2].	Qualified person for boilers above 100 kW.	Written report to be archived for 5 years.	(PM)					EVID		
UK	9	Schedule inspections if Written Scheme of Examination requires examination at greater frequency that RME standard in [1]	Inspections must be undertaken in line with a Written Scheme of Examination if steam boiler	Qualified or Competent Person.	Written Scheme of Examination.							CT	

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 85/1978 Coll. Decree No.21/1979 Coll. Decree No. 34/2016 ČSN 69 0012, ČSN EN 12 186	Specialized technician of gas equipment. Chimney sweep.	Regular checks yearly. Operational inspection every 3 years. Inspection of shut-off valves every 4 months. Chimney inspection yearly.
DE	Betriebsicherheitsverordnung (BetrSichV) – Tabelle 12 Verordnung zum Bundesimmissionsschutzgesetz (1. BImSchV) §15 Kehr- und Überprüfungsordnung (KÜO) Anlage 1 Schornsteinfegerhandwerksgesetz (SchfHwG) Gesetz zur Einsparung von Energie und zur Nutzung erneuerbarer Energien zur Wärme- und Kälteerzeugung in Gebäuden (Gebäudeenergiegesetz - GEG)	Expert (Fachkundiger) according to GEG. Chimney sweep (Schornsteinfeger) according to KÜO Competent Person (befähigte Person) According to BetrSichV	Recurring inspections every 2 or 3 years depending on criteria outlined in BImSchV §15. Sweeps and inspections every 1 – 3 years depending on plant type according to KÜO- Anlage 1. Inspection frequency of 10 years for expansion vessels in heating and cooling systems with water or heating medium temperature of 120°C or less (integrity and strength inspection of pressure systems), risk assessment mandatory, according to BetrSichV. According to GEG § 72, gas boilers are no longer allowed to be used if installed before 1991. If installed after 1991 they must be decommissioned after 30 years.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required.
FR	For boilers (400kW and <20MW): Environment Code: Art . R . 224-20 to 38 Sous-section 2 : Rendements, équipement et contrôle des chaudières (Articles R224-20 à R224-41-9) - Légifrance (legifrance.gouv.fr) For boilers (4kW and <40kW): Environment Code: Art . R . 224-41 Paragraphe 4 : Entretien annuel des chaudières dont la puissance nominale est comprise entre 4 et 400 kW (Articles R224-41-4 à R224-41-9) - Légifrance (legifrance.gouv.fr)	Accredited company or qualified person	Inspection every 2 years (for boilers (400kW and <20MW), maintenance every 12 months and quarterly performance check.
IT	Legislative Decree 9/04/2008 n.81 DM 11/04/2011 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) DPR 74/2013 Legislative Decree 4/07/2014 n.102 Legislative Decree 19/08/2005 n.92 Regulation 2016/426/EU Directive 2014/68/EU UNI 7129-1:2015 (Construction and improvements) UNI EN 15502-1:2015 (General requirements and test)	Competent and accredited person, considered best practice to outsource to specialist company.	Maintenance as per manufacturer instructions Every year. Inspection of operation every 5 years, and of integrity every 10 years. Inspection of boiler flue gases every 2 years (boilers >100KW) or every 4 years (boilers </= 100KW). Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 on construction law (Journal of Laws 1994 item 1333) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of the Environment of August 24, 2012 on the levels of certain substances in the air (Journal of Laws 2021, item 845) Regulation of Minister of Environment of 2 July 2010 on the types of installations the operation of which requires notification (Journal of Laws 2019, item 1510) Regulation of the Minister of the Environment of 2 July 2010 on cases where the introduction of gases or dust into the air from the installation does not require a permit (Journal of Laws 2010, number 130, item 881) Regulation of the Minister of Development and Finance of August 1, 2017 on the requirements for	Qualified or competent person.	Every 12 months. For objects more than 2000m2, every 6 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Engineer on the Register of Gas Installers Ireland (RGII)	Regular maintenance of equipment in accordance with manufacturer's recommendations. Inspections at least every 12 months

SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 25/1984 Coll. on ensuring work-safety in low-pressure boiler rooms Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment. Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections	Qualified person	Every 12 months. The operating rules shall specify the method, procedure, scope and deadlines for cleaning the boilers.
UK	The Gas Safety (Installation and Use) Regulations 1998 (legislation.gov.uk) The Pressure Systems Safety Regulations 2000 Pressure Systems Safety Regulations (Northern Ireland) 2004	Competent person on the Gas Safe Register.	Routine maintenance carried out during regular examination, following manufacturer's recommendations. Inspections 12 months.