AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Gas Detectors
APM Object	CT.HVAC.GASDET
APM Description	Gas detectors (mobile and permanent fixed)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Roof Top Units Air Conditioning Units Air Handling Units	**Related CT Areas:**	Not Specified		

Scope

Any site where fitted or portable gas detectors are used to identify potential leaks of, of accumulation of gases.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all gas detectors.	Competent Person.	Retain records of inspections and calibrations.						CT		
All	2	In accordance with manufacturer's recommendations and instructions, but at least every 4 months.	Functional inspection	Competent Person.	Retain records of inspections and calibrations.						CT		
All	3	Once per year	Calibration	Competent Person.	Retain records of inspections and calibrations.						CT		
IT	4	No additional requirements	No additional requirements	No additional requirements	CE Declaration of Conformity.								As Needed EVID

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	1.Routine maintenance of all gas detectors. 2.Functional control 3.Toalibism	Manufacturer or competent person determined by the manufacturer.	In accordance with manufacturer's instructions.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Information 213-056 - Gaswarneinrichtingen für toxische Gase/Dämpfe und Sauerstoff - Einsatz und Betrieb (Merkblatt T 021 der Reihe Sichere Technik) DGUV Information 213-057 - Gaswarneinrichtungen für den Explosionsschutz - Einsatz und Betrieb (Merkblatt T 023 der Reihe Sichere Technik)	Visual inspection by an instructed person (unterwiesene Person). Functional inspection by a qualified person (qualifizierte Person). System inspection by a competent person (befähigte Person).	Visual inspection once a month. Functional inspection every 4 months. If system has self-monitoring system only once a year. System inspections, including calibration and adjustment every 12 months.
ES	RD 919/2006, which approves the Technical Regulation for the distribution and use of gaseous fuels and its complementary technical instructions ICG 01 to 11. UNE-EN 60079-29-1 gas detectors industrial and commercial UNE-EN 60079-29-2, gas detectors industrial and commercial UNE 60601 gas detectors in machine room	Accredited company, gas installers	Maintenance as per manufacturer's recommendation. Inspection of appliances every 5 years, and installation every 2 years.
FR	N/A	N/A	N/A
IT	EN 50291:2010 (Test and performance requirements for carbon monoxide detectors) UNI CEI EN 50244:2001 (Maintenance) UNI CEI EN 50194-1:2010 (Test and performance requirements) EN 50271:2018 (Test and requirements) EN 50104:2019 (Test and requirements) EN 60079-29-1:2016 (Performance requirements; currently under review) UNI EN 14624:2020 (Mobile detectors) EN 50292:2013 (Carbon monoxide detectors) UNI 11522:2014 (Installation and maintenance)	Competent person.	Maintenance in accordance with manufacturer's instructions.
PL	Regulation of Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Economy of 28 December 2009 on occupational health and safety in the construction and operation of gas networks and the commissioning of natural gas installations (Journal of Laws 2010, number 2, item 6)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, typically the entity undertaking the leak checking	Routine maintenance of gas detectors. Regular calibration in accordance with manufacturer's instructions, but at least 6-monthly
SK	Act No. 124/2006 Coll. on safety and health at work	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Provision and Use of Work Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person	Monitoring equipment should be in good working order. Calibrated to relevant gas and tested at least in accordance with the manufacturer's recommendations, or in line with risk assessment.