AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	ODS Air-Conditioning
APM Object	CT.HVAC.ODS
APM Description	All stationary refrigeration, air-conditioning, heat-pump (RAC) or fire protection equipment, fire extinguishers that contain ozone-depleting substances. HV switchgear may also contain such substances such as SF
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	HVAC.RTU HVAC.CU HVAC.CHILL	**Related CT Areas:**	CT.HVAC.FGAS		

Scope

Any site with air conditioning systems containing Ozone-Depleting Substances (ODS), where the fluid charge of controlled substances is greater than 3 kg.
Cooling units containing Fluorinated Gas are outlined in Compliance Standard CT.HVAC.FGAS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing ODS.	Competent person.	Maintenance logbook	PM					EVID		
All	2	At least every 12 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of 3 to 30 kg, with the exemption of hermetically sealed systems (labelled) that contain <6 kg of controlled substances. Best practice to include units <3 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.						CT*		
All	3	At least every 6 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of 30 to 300 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.					CT			
All	4	At least every 3 months.	Statutory requirement for leak inspection of all ODS containing equipment with a fluid charge of more than 300 kg.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.						CT		
All	5	As soon as possible, but not later than 14 days from detection.	Repair of any leakage detected during inspections	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.								One off EVID

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register, including type and quantity of controlled substances. Re-inspection evidence for fixed leaks.									One off EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".								CT*	

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer Act No. 73/2012 Coll., on substances depleting the ozone layer and F-gases (§4) Regulation No. 257/2012 Coll., on preventing ODS a F-gases emissions	Competent person, certified by the relevant body	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge. Units with more than 300 kg of fluid charge must have been fitted a leakage detection system, the system must be inspected by a competent person (operator) every 12 months at least.
DE	Verordnung (EG) Nr. 1005/2009 Chemikalien-Ozonschichtverordnung (ChemOzonSchichtV) § 4	Competent Person (befähigte Person)	Regular tightness checks as follows: Equipment without hermetically sealed systems, with fluid charge of 3 kg or more, at least every 12 months. Equipment with fluid charge of 30 kg or more, at least every 6 months. Equipment with fluid charge of 300 kg or more, at least every 3 months. Tightness must be re-checked 1 month after any leakage repairs have been conducted.
ES	Regulation EC/1005/2009 of the European Parliament and of the Council of September 2009 on substances that deplete the ozone layer.	Competent person, certified by the relevant body	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charg
FR	No additional requirements	N/A	No additional requirements
IT	Regulation 1005/09/EU	N/A	With some special exceptions (critical uses, laboratory uses, process agents and raw materials) described in Regulation 1005/2009/EU, the production, placing on the market and use of all controlled ODS, new ODS and products and equipment containing or relying on such substances are prohibited in the European Community.
PL	Regulation EC/1005/2009 of the European Parliament and of the Council of September 2009 on substances that deplete the ozone layer. Act of 15 May 2015 on substances that deplete the ozone layer and on certain fluorinated greenhouse gases (Journal of Laws 2020, item 2065) Act of 29 August 2014 on the energy performance of buildings (Journal of Laws 2021, item 497) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge. Tightness must be re-checked 1 month after any leakage repairs have been conducted.
ROI	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer (europa.eu) (as amended)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.
SK	Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Act. No. 321/2012 Coll. on the Protection of the Earth's Ozone Layer and on Amendments to Certain Acts	Qualified and certified person.	Inspection is realized upon request from the side of the state authority. Otherwise, the minimum inspection period is 5 years.

UK	Regulation (EC) No 1005/2009 of the European Parliament and of the Council of 16 September 2009 on substances that deplete the ozone layer (as amended) The Ozone-Depleting Substances Regulations 2015 The Environmental Protection (Controls on Ozone-Depleting Substances) Regulations 2011 The Controls on Ozone-Depleting Substances Regulations (Northern Ireland) 2011	Competent person with the appropriate certification (eg. City & Guilds, CITB).	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.