AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Lifting Accessories
APM Object	CT.LIFT.ACCESSORIES
APM Description	Lifting accessories (e.g. chains, ropes, shackles, slings/straps, etc.)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Lifting Equipment	**Related CT Areas:**	Not Specified		

Scope

Any site where lifting accessories are used as part of lifting equipment.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent, trained person.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.	PM							
All	2	Once assembled, before first use	Acceptance inspection before it is first used.	Independent, accredited or authorised to undertake the inspection.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.								CT
All	3	Based on risk assessment, but at least every 6 months. More frequent inspections might be conducted based on site and environmental conditions.	Regular thorough inspection of safety-critical parts to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or disposal and replacement - do Not use. Report issue	Independent, accredited or authorised to undertake the inspection.	Inspection and maintenance records, reports or certificates. Risk assessment Register of lifting equipment.					CT			
DE	4	Thorough inspection at least every 3 years	Round steel chains used as slings must be subjected to an additional special inspection for cracks	Competent person (befähigte Person)	No additional requirements								3Y CT
DE	5	Thorough inspection at least every 3 years	Lifting straps/slings with vulcanized-on coating must be inspected for wire breaks and corrosion	Competent person (befähigte Person)	No additional requirements								3Y CT

FR	8	Inspections before it is first used and at least every 6 or 12 months.	6 months: - tail lifts; - furniture lifts; - construction hoists; - earthmoving equipment equipped for lifting; - self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or disassembly of major parts;	Qualified person	Maintenance logbook				CT				
IT	7	Inspections at least every 3 months	Inspections as per [3].	No additional requirements	CE Declaration of Conformity. Records to be kept for at least 3 years.				CT				
SK	6	Every month in metallurgical plants and aggressive environments. Every 3 months in other operations, including in outdoor areas. Every 6 months when rarely used.	The binding system and its components must be checked more regularly depending on the task/industry.	No additional requirements	No additional requirements				CT				

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	ČSN 270142 ČSN 9927-1 ČSN 12482-1, 19/79; ČSN EN 1492-1 + A1, ČSN EN 1492-2 + A1 ČSN 4309 ČSN 8792 (steel ropes)	Competent person. Lift equipment technician.	Checks on steel ropes carried out every 6 months. Checks on chains, links and hinges carried out at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: DGUV Regel 100-500 Kap. 2.8 Betreiben von Lastaufnahmeeinrichtungen im Hebezeugbetrieb DGUV Regel 109-017 - Betreiben von Lastaufnahmemitteln und Anschlagmitteln im Hebezeugbetrieb TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Regel 109-004 Rundstahlketten als Anschlagmittel in Feuerverzinkereien DGUV Regel 109-005 Gebrauch von Anschlag-Drahtseilen DGUV Regel 109-006 Gebrauch von Anschlag-Faserseilen	Competent person (befähigte Person).	Inspection before its first use and at least every 12 months.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. UNE-EN 818: 2008 Standard (7 PARTS) Chain slings. Prevention Technical Note 861 (Sling chanins). Prevention Technical Note 824 (equipment for lifting goods).	Competent person.	Maintenance and inspection frequency depend on the use of equipment and the service conditions. Daily inspections on slings and a thorough inspection every 12 months (recommendation according to NTP861).
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Inspections before it is first used and at least every 6 or 12 months. (6 months: - tail lifts; - furniture lifts; - construction hoists; - earthmoving equipment equipped for lifting; - self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or disassembly of major parts; - fork-lift trucks; - pipelaying tractors;
IT	UNI EN 818:2008 (Short link chains for lifting) UNI ISO 4309:2019 (Ropes: care, maintenance, inspection and waste) UNI EN 1492:2009 (Fabric slings) UNI EN 1677:2009 (Sling's components) UNI EN 13001:2018 (Lifting equipment) UNI EN 13155:2021 (Removable load carrying equipment) UNI EN 13411:2009 (Steel rope ends) UNI EN 13414:2009 (Steel rope slings) UNI EN 13889:2009 (Lifting shackels) UNI EN ISO 3266:2016 (Lifting eyelets)	Competent, authorised person.	Regular maintenance in accordance with manufacturer's instructions. Inspection at least every 3 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Minister of Development of 3 June 2016 on the requirements for lifts and safety components for lifts (Journal of Laws 2016, item 811) Regulation of the Minister of Infrastructure of 12 April 2002 on on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	Competent person. UDT technical inspection, government body.	Inspection according to manufacturer's instructions or internal procedures, but at least once every 12 months. Some accessories must be inspected more regularly depending on the conditions and task.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 232/2017 - European Union (Lifts and Safety Components for Lifts) Regulations 2017. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 0142: Cranes and hoists. Testing	Competent person, best practice to outsource to specialist company.	Inspection before its first use, and at least every 12 months. Technical inspection of chains every 12 months and technical examination (testing) every 24 months. GENERAL: Inspections in accordance with manufacturer's instructions.

UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource. Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before it is first used and every 6 months. Planned maintenance programme in place.