AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Escalator
APM Object	CT.LIFT.ESCALATOR
APM Description	Escalators.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where escalators are operated (moving staircase for people).
Passenger lifts are covered under Compliance Standard CT.LIFT.PASSENGER and goods lifts are covered under Compliance Standard CT.LIFT.GOODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	- tail lifts;	Competent person.	Maintenance logbook Declaration of Conformity (upon purchase) - retain for as long as the escalator is in service.								
All	2	Inspection frequency based on risk assessment, but at least every 6 months.	- furniture lifts;	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, report or certificates. Risk assessment					CT			
CZ	3	Inspections conducted every 3 months. Testing conducted every 3 years. Accredited inspections every 6 years.	- construction hoists;	No additional requirements	Protokol o urceni vnejsich vlivu						CT		3, 6 Year
DE	7	Inspection prior to first use as per BetrSichV, DGUV Information 208-028 and DIN EN 115-1:2018-01.	- fork-lift trucks;	No additional requirements	No additional requirements								
PL	4	Technical maintenance of elevators to be conducted at least every month.	- earthmoving equipment equipped for lifting;	No additional requirements	No additional requirements			CT					

ROI	6	No additional requirements	disassembly of major parts;	No additional requirements	Keep inspection records for at least 5 years. Register of lifting equipment					(CT)			
SK	5	Professional inspections at least every 3 months. Professional examination every 3 years.	- self-propelled or carrier vehicle mounted mobile cranes, not requiring assembly or	No additional requirements	No additional requirements						CT		3 Year

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree 50/1978, Decree 19/1979 EN 81-1 EN 81-2 ČSN 274007- ČSN 274002 EN 81 - 80	Competent person. Lift equipment technician.	Inspections before first use and at regular intervals of at least 3 months. Equipment testing every 3 years. Accredited inspections every 6 years.
DE	DIN EN 115-1:2018-01 Section 7.3.1- Sicherheit von Fahrtreppen und Fahrsteigen DGUV 208-028 - Fahrtreppen und Fahrsteige; Teil 1: Sicherer Betrieb BetrSichV §3 VdTÜV Merkblatt 1504 "Grundsätze für die Prüfung von Fahrtreppen und Fahrsteigen Technische Regeln für Arbeitsstätten: ASR A1.8 – Verkehrswege	Accredited inspection body or competent person (befähigte Person)	Inspection before first use and after significant changes (DIN EN 115-1) by an accredited inspection (ZÜS) such as TÜV, DEKRA, etc or a competent person (befähigte Person). Regular recurrent inspection to be determined by risk assessment. Annual basis is common
ES	RD 2291/1985, approving regulation for lifting machines and their maintenance. RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. EN-115. Safety in escalators and mobile platforms. ISO 14798:2009. Lifts (elevators), escalators and moving walks - Risk assessment and reduction methodology.	Competent person.	Technical maintenance at least every month. Inspections at least every 12 months
IT	UNI EN 115:2017 (Safety requirements) Directive 2006/42/CE on machinery UNI EN 13015:2008 (Maintenance) Decree 22/12/17	Competent person.	Technical maintenance at least every month. Inspections at least every 12 months
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065)	UDT technical inspection, government body.	Technical maintenance at least every month. Inspections at least every 12 months
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular inspections conducted at least every 6 months.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN 27 4802: Escalators. Assembly, tests, operation, maintenance and repairs	Competent person, best practice to outsource to specialist engineer.	Professional inspections to be conducted every 3 months. Professional examination at least every 3 years. Repeated official test every 10 years.
UK	The Provision and Use of Work Equipment Regulations 1998 The Workplace (Health, Safety and Welfare) Regulations 1992 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Regular planned maintenance in accordance with manufacturer's recommendations. Thorough inspections at least every 6 months.