AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Hoists
APM Object	CT.LIFT.HOIST
APM Description	Hoists.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	BLDG.CRANES	**Related CT Areas:**	Not Specified		

Scope

Any site where engine hoists and other types of hoists are used to move, install or remove heavy loads.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance of the equipment (lubrication, parts replacement, etc.).	Competent person	Inspection records, reports or certificates. Risk assessment Marking, e.g. inspection test sticker to be placed on equipment/permit for use	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months. More frequent inspections might be conducted based on site and environmental conditions.	Regular thorough inspection of safety-critical parts and operation to ensure safe use. This include lifting (e.g. chain, slings) and non-lifting (e.g. brakes, lights, fall-over protection) parts of the equipment If defects are identified, prevent subsequent use through quarantine prior to repair or disposal and replacement - do Not use. Report issue	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be completed by insurance company	Inspection records, reports or certificates. Risk assessment Marking, e.g. inspection test sticker to be placed on equipment/permit for use					CT			
CZ	4	Every 6 to 60 months, depending on the electrical environment.	Inspection of electrical components	Certified electrician	No additional requirements	PM					EVID		
CZ	5	Once a year	Inspection of other components	As [2], [3]	No additional requirements	PM					EVID		
FR	6	Thorough inspections of engine hoists every 3 to 6 months and annually	No additional requirements	Competent, trained person	Maintenance logbook Security register					CT			

IT	7	Thorough inspections at least every 3 months, unless risk assessment identifies further inspection requirements.	No additional requirements	External competent person	CE Declaration of Conformity. Inspection records to be kept for 3 years.				CT				

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No. 378/2001 Coll., Decree No. 73/2010 Coll., ČSN 331500	Competent person. H&S specialist / electrician.	Inspections carried out every 12 months. Electrical parts every 6-60 months.
DE	Technische Regeln für Betriebssicherheit: DGUV Vorschrift 52 - Krane DGUV Grundsatz 309-001 - Prüfung von Kranen DGUV Grundsatz 309-008 Hinweise für die Prüfung von Winden, Hub- und Zuggeräten	Competent person (befähigte Person) according to DGUV 309-001.	Inspection before its first use if cranes are not delivered ready for operation, after any major modifications, and at least every 12 months. Electrical parts as part of hoists every 6-60 months. Power-operated wire rope and chain hoists for lifting loads as well as power-operated crane hoists must be inspected at least every 48 months, with exceptional case requirements outlined in §27 4 & 5.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. NTP 78. Hands-operated pulley blocks.	Competent person.	Maintenance according to manufacturer's instructions. Inspection frequency depends on operating conditions.
FR	Art. 1 à 7 Decree of 29th December 2010 "Arrêté du 29 décembre 2010 relatif aux vérifications générales périodiques portant sur les ascenseurs et les monte-charges ainsi que sur les élévateurs de personnes n'excédant pas une vitesse de 0,15 m/s, installés à demeure, et modifiant l'arrêté du 1er mars 2004 modifié relatif aux vérifications des appareils et accessoires de levage" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000023386810/ 21. january 2011 decision 1 march 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 march 2004 Decree (modified)	Qualified person	Annual inspections for all hoists. Additional Inspections once the equipment is back in service and every 3 to 6 months for engine hoists
IT	D.Lgs 81/2008, annex VI, p.to 3.1.2 DM 11/04/2011 UNI EN 12644:2008 (Use and testing) UNI EN 12077:2008 (Safety requirements) UNI EN 13557:2008 (Controls) UNI EN 13135:2018 (Safety requirements) UNI EN 14492:2009 (Hoists) UNI ISO 9927:2016 (Inspections) UNI ISO 23814:2012 (Requirements for inspectors) UNI ISO 4306:2010 (Lifting equipment - Vocabulary)	Competent, authorised person.	Regular maintenance in accordance with manufacturer's instructions. Inspection at least every 3 monthsfor lifting components. Periodic inspection every 12 months.
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical inspection in the field of operation, repair and modernization of handling equipment Regulation of the Council of Ministers of 7 December 2012 on the types of technical devices subject to technical inspection (Journal of Laws 2012, 1468)	UDT technical inspection, government body.	Inspections of engine hoists every 2 years and other hoists every 3 years. Accessories must be checked more regularly depending on the conditions/task.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) S.I. No. 426/1981 - Safety in Industry (Vehicle Lifting Tables and Other Lifting Machines) (Register of Examinations) Regulations, 1981. (irishstatutebook.ie)	Competent person, accredited by INAB Accreditation Service (BS EN ISO/IEC 17020:2004)	Inspection every 6 months. Planned maintenance programme in place.
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment STN EN 27 0142: Cranes and hoists. Testing	Competent person, best practice to outsource to specialist company.	Inspections in accordance with manufacturer's instructions.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent, Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Inspection before it is first used and at least every 12 months. Planned maintenance programme in place.