AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Pressure systems
APM Object	CT.PRESSURE.SYS
APM Description	Pressure systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	COMPR - HVAC.CHILL - HVAC.HS - HVAC.HTR - FIRE.SUP - FIRE.SUP.PUMP.JP - HVAC.CU - WTR.SUPPLY	**Related CT Areas:**	Not Specified		

Scope

Any site that operates pressure systems and vessels, such as boilers, condensers, heating and air conditioning devices (vapor compressing), etc associated pipework in which a breach may give rise to danger, primary shut off valves and protective devices. Typically, equipment with steam at any pressure, gases which exert a pressure in excess of 0.5 bar above atmospheric pressure and fluids which may be mixtures of liquids, gases and vapours where the gas or vapour phase may exert a pressure in excess of 0.5 bar above atmospheric pressure.
Inspection requirements for boilers are covered in CT.HVAC.BOILERS.
Note this standard excludes hired plant e.g. mobile compressors as some responsibilities will fall to the provider.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Routine maintenance of all air compression systems (topping up fluids, filters, etc.)	Competent person, generally sourced internally.	Maintenance logbook.	PM					EVID		
All	2	Before the pressure system is first put into service.	Initial assessment to identify all pressure systems, verify conformity (CE Marking), the risk associated with them, and any examination identified in risk assessment/written scheme of control.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate								One off EVID
All	3	Based on risk assessment and manufacturer's instructions, but at least every 12 months.	Examination of air steam boilers, associated pipework and protective devices and steam heating devices of more than 100°C	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate						CT		
All	4	Based on risk assessment, but at least every 12 months.	Inspection and servicing of all air compression systems.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate	(PM)					(EVID)		
All	5	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres.	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	

All	6	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of refrigeration and air conditioning systems (vapor compression) where the installed power exceeds 25kW	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
All	7	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of steam receiving plants	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
All	8	Based on risk assessment and manufacturer's instructions, but at least every 2 years.	Examination of other pressure systems (e.g. LPG storage systems to supply fuel)	Competent person (e.g. specialised pressure equipment technician)	Risk assessment Maintenance and inspection logbook Inspection records, report or certificate							CT	
CZ	9	Every year	Operational inspections of all pressure equipment (items [2], [3], [4], [5] and [6]).	No additional requirements	Passport protocol of the vessel	(PM)					(EVID)		
ES	10	Every 2 - 12 years depending on Inspection type and Class of equipment	Operational inspections of all pressure equipment	Level A - installer company. Levels B and C - accredited external inspector	Inspection reports and repair records (where required)	(PM)					(EVID)		
IT	1	Usually every 10 years	Integrity verification	No additional requirements	No additional requirements								10Y CT
IT	13	Every 2, 3, 4 and 5 years depending on the categories of systems and fluids involved (see comment on Italy's section of table 2)	Functional inspection of all systems	No additional requirements	CE Declaration of Conformity	(PM)					(EVID)		
SK	11	Every 6 months to 15 years, depending on inspection type and pressure equipment type	Operational inspections of all pressure equipment	Competent and authorized person	Inspection reports and repair records (where required)	(PM)					(EVID)		
UK	12	No additional requirements	Inspections as per [2], [3], [4], [5] and [6].	No additional requirements	Written scheme of examination	(PM)					(EVID)	(CT)	(One off EVID)

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 18/1979 Coll. ČSN 69 0012 EN 286	Technician of specialized pressure equipment certified by the national authority	Initial assessment to identify all pressure systems and the risk associated with them. Air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years or whenever the vessel has been opened. Air steam boilers associated pipework and protecting devices and steam heating devices of more than >100°C to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years. Refrigeration and air conditioning systems where the installed power exceeds 25kW to be inspected every year to assess operation, 5 years to check internal condition and conduct a pressure test every 9 years. Steam receiving plants at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen TRBS 1203 - Befähigte Personen	Competent person (befähigte Person) OR Approved inspection agency (ZÜS Zugelassene Überwachungsstelle) Depending on type of pressure device/system	Before first use and after modifications and in regular intervals subject to mandatory inspection. Regular and periodic inspection of pressure systems and vessels consists of outer inspection (äußeren Prüfung), inner inspection (innere Prüfung) and resistance inspection (Festigkeitsprüfung). Outer inspections at least every 1- 5years depending on type and specification of pressure device/system. Inner inspections at least every 3 -5 years depending on type and specification of pressure device/system. Inner inspections at least every 3 -5 years depending on type and specification of pressure device/system. Resistance / Strength inspections at least every 5 - 10 years depending on type and specification of pressure device/system.
ES	RD 2060/2008, approves the Equipment Regulation to pressure and its complementary technical instructions.	Level A inspection: installer company. Level B inspection: accredited company (OCA). Level C inspection: accredited company (OCA).	Categories I-2 and II-2: 4 years. Level A Inspection. 8 years. Level B Inspection. Categories I-1, II-1, III-2, and IV-2. 3 years. Level A Inspection. 6 years. Level B Inspection. 12 years. Level C Inspection. Categories III-1, IV-1. 2 years. Level A Inspection. 4 years. Level B Inspection.

FR	Labor Code - Ministerila Order of 20 november 2017 concerning pressure equipment. https://www.legifrance.gouv.fr/loda/id/JORFTEXT000036128632/	Competent and authorised person	Inspection of pressure heat and refrigeration systems every 2 years Vessels inspected every 2 years. Compressed air systems inspected before use then every 3 years (4 years for equipment inspected during the commissioning) Fluid pipes re-qualification every 6 years if toxic/very toxic gas Vessels re-qualification every 10 years
IT	Legislative Decree 25/02/2000 n.93 Legislative Decree 9/04/2008 n.81 Decree 11/04/2011 (Inspection criteria for equipment in annex vii of Legislative Decree 9/04/2008 n.81) Decree 1/12/2004 n. 329 Directive 2014/68/EU Directive 2014/29/EU UNI 11325-12:2018 (Maintenance)	Competent and accredited person (under UNI CEI EN ISO/IEC 17020:2012 in accordance with Decree 11/04/2011)	Equipment containing fluids of class 1 in accordance with Legislative Decree 25/02/2000 n.93: -Vessels of categories 3 and 4 and vessels containing unstable gases of categories 1 to 4: functional inspections every 2 years and integrity verification every 10 years -Vessels of categories 1 and 2: functional inspections every 4 years and integrity verification every 10 years -Pipework for gases, liquids and steams of categories 1, 2 and 3: functional inspections every 5 years and integrity verification every 10 years -Vessels for liquids of categories 1, 2 and 3: functional inspections every 5 years and integrity verification every 10 years Equipment containing fluids of class 2 in accordance with Legislative Decree 25/02/2000 n.93: -Vessels containing gases of categories 3 and 4 and vessels for water steam or heated water belonging to
PL	Regulation of the Minister of Economy, Labor and Social Policy of 9 July 2003 on technical conditions of technical inspection in the field of operation of certain pressure equipment (Journal of Laws 2003, number 135, item 1269) Act of 21 December 2000 on technical inspection (Journal of Laws 2021, number 272) Regulation of The Council of Ministers of 7 December 2012 on types of technical devices subject to technical inspection (Journal of Laws 2012, item 1468) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Government Authority for the Technical Inspection (Polish UDT - Urząd Dozoru Technicznego)	
ROI	Safety, health and welfare at work (general application) amendment Regulations 2012 SCHEDULE 12 Part 10 Part B Regulations 191 and 192. The period for any particular piece of equipment maybe subject to change pursuant to the application of Regulation 191(3) S.I. No. 400/1999 - European Communities (Pressure Equipment) Regulations, 1999 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company or person, usually accredited under BS EN ISO/IEC 17020: 2004	Initial assessment to identify all pressure systems and the risk associated with them. Steam rand hot water boilers, water tube boilers, cast iron sectional boilers, superheaters and economisers, associated pipework, self-generating autoclaves, etc. to be inspected at least every 14 months. Air receivers, steam receivers, autoclaves, jacketed pans and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres to be inspected at least every 26 months. Refrigeration and air conditioning systems (vapor compression) where the installed power exceeds 25kW at least every 26 months. Other pressure systems (e.g. LPG storage systems) based on risk assessment. Generally, inspections every
SK	Act No. 17/2007 Coll. on the regular inspection of boilers, heating systems and air-conditioning systems and on the amendment of certain laws Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection when working with technical pressure, lifting, electric and gas equipment and laying down technical equipment which is considered to be the reserved technical equipment Ordinance No. 25/1984 Coll. on ensuring work safety in low-pressure boiler rooms	Competent and authorized person	Pressure vessels - repeated inspection of exterior: Annually Internal space inspection: 1x 5 years Pressure testing: 1x 10 years Steam and hot water boilers Repeated inspection of exterior and internal space: Annually Pressure testing: 1x 10 years Steam and hot water boiler rooms Inspection at least annually Gas atmospheric pressure systems Inspection: Annually
UK	The Pressure Systems Safety Regulations 2000 (legislation.gov.uk) Pressure Systems Safety Regulations (Northern Ireland) 2004 (legislation.gov.uk) Safety of pressure systems: Pressure Systems Safety Regulations 2000. Approved Code of Practice L122 (hse.gov.uk) The law - Pressure systems (hse.gov.uk)	Competent person, best practice to outsource to specialist company or person, usually accredited under BS EN ISO/IEC 17020: 2004	Initial assessment to identify all pressure systems and the risk associated with them. Employers are required to have a written scheme of examination with defined inspection periodicities, in accordance with the Safety Assessment Federation (SAFed): - Air receivers and associated pipework where the product of the pressure times the internal capacity of the receiver is greater than 250 bar-litres at least every 26 months. - Air steam boilers, associated pipework and protecting devices and steam heating devices of more than >100oC at least every 14 months. - Refrigeration and air conditioning systems where the installed power exceeds 25kW at least every 48 months. - Steam receiving plants at least every 26 months.