AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Microwave ovens
APM Object	CT.RAD.MICROWAVES
APM Description	Microwave ovens
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where microwave ovens are used. This Compliance Standard does not cover the electrical inspections of microwaves, which are covered under "Portable Appliance Testing".

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of equipment.	Competent person, usually sourced internally	Maintenance logbook.						CT		
All	2	Not statutory requirements, but can be checked during PAT examination	Regular inspections of radioactive leaks from microwave ovens.	Competent person	Inspection records, report or certificate. Risk assessment						CT		
FR	3	Every 12 months	Inspection as per [2].	Accredited company	No additional requirements						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., ČSN 331500, ČSN 333320 ed.2, ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree 50/1978 Coll.	Competent, competent electrician Review technician	Frequency determined by the Protocol on the list of external influences, between 6and 60months.

DE	N/A	Competent person (befähigte Person)	Before the first use and after any modifications or alterations. Frequency of inspections in accordance with risk assessment, and manufacturer's recommendations and instructions.
ES	RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note 234. Exposition to radiofrequencies and microwaves. Evaluation. RD 486/2010, of April 23, about health and safety on workers against risks related to the exposure of artificial optic radiations. RD 1644/2008, of October 10, which establishes regulation for the commercialization and commissioning of machines (annex I: 1.5.10 to 12).	Qualified expert according to RD 39/1997	Inspection frequency not stipulated, based on risk assessment according to RD486/2010 – art. 6.
FR	Labor Code R. 4453-6 to R. 4453-12 : Electromagnetic exposition – risk assessment https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018491265/	Accredited company	Electromagnetic waves exposition has to be assessed
IT	Legislative Decree 9.04.2008 n° 81 CEI EN 60335-2-25/A1/A2 (Safety requirements)	Competent person.	Inspection frequency not stipulated, based on risk assessment and manufacturer's instructions.
PL	Act of 29 November 2000 on Atomic Law (Journal of Laws 2021, item 623)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Regular maintenance. Frequency of inspection not regulated, based on risk assessment.
SK	Ordinance No. 209/2016 Coll. on the minimum health and safety requirements for the protection of workers from the risks related to exposure to electromagnetic fields Ordinance No. 533/2007 Coll. on details of requirements for mass caterers	Qualified expert	Frequency of inspection not regulated, based at manufacturer recommendation
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk)	Competent person, usually a trained employee	Regular maintenance. Frequency of inspection not regulated, based on risk assessment.