AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	F-Gas Refrigeration
APM Object	CT.REFR.FGAS
APM Description	All stationary refrigeration plant that contain F-Gas refrigerants.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	New system created.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Refrigeration System.	**Related CT Areas:**	CT.HVAC.FGAS		

Scope

Any site with refrigeration systems containing fluorinated refrigerants listed in https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32014R0517&qid=1608306002561, where the combination of type and mass gives a CO2 equivalent in the range of 50-500 te. CO2 equivalent values for various refrigerants are given here:

https://www.gov.uk/guidance/calculate-the-carbon-dioxide-equivalent-quantity-of-an-f-gas

For pressure systems refer to CT.PRESSURE.SYS. For HVAC FGAS refer to CT.HVAC.FGAS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing F-gas.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Maintenance logbook	PM					EVID		
All	2	12 months without leak detection system. 24 months with leak detection system	Statutory requirement for leak inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 50 tonnes of CO2. Best practice to include units <5 tonnes CO2 equivalent.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.							CT*	
All	3	6 months without leak detection system. 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 50 to 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*			
All	4	3 months without leak detection system. 6 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*	CT*		
All	5	Every 12 months.	Leak detection system inspections.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT		

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.								On Demand EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT	CT	
PL	8	Every 6 months without leak detection system or every 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 10 to 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT*			
PL	9	Every 6 months. Leak detection system mandatory.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT			
SK	10	Every 3 months without leak detection system or 6 months with leak detection system.	Leak inspection of units with more than 300 kg of fluid charge.	No additional requirements	No additional requirements.					CT*	CT*		