AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Emergency showers and eyewash stations
APM Object	CT.SAFE.WASH
APM Description	Emergency showers and eyewash stations
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.WATER.LEGIONELLA		

Scope

Any site with eye wash stations and emergency showers fed by mains water.
Disposable eyewash solutions are not covered within this Compliance Standard.
Water quality inspection requirements are covered under "Cold water services" and "Legionella Risk Assessment (LRA)".

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance of all safety critical equipment.	Competent person, usually internal	Maintenance logbook			CT					
All	2	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular inspections of all plumbed-in safety showers to ensure a minimum discharge of water at a rate of 60 l/s for at least 15 minutes and that a minimum of 95% of the water flow is contained within a 40cm diameter.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
All	3	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular inspections and testing of all plumbed-in eyewash stations to ensure a minimum discharge of water at a rate of 6 l/s for at least 15 minutes and at a jet height of between 100mm and 300mm, and a response time when activated via a valve of less than 1 second.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
All	4	In accordance with manufacturer's instructions and recommendations, and based on risk assessment, but at least monthly	Regular temperature checks of the water discharged via eyewash stations and emergency showers to ensure it is no less than 15°C.	Competent person, can be sourced internally or externally	Inspection records, report or certificate. Risk assessment Equipment should be labelled.			CT					
CZ	6	In accordance with the manufacturer's instructions and recommendations	Regular inspection of equipment	Competent person	Record of the check performed			(CT)					

IT	5	Every 6 months.	Inspection as for [1]	No additional requirements.	CE Declaration of Conformity.					(CT)			

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Act No. 262/2006 Coll. Traumatological plan Manufacturer's instructions Nam. Government Regulation No. 378/2001 Coll.	Competent person	At least once a year, unless stated otherwise by the manufacturer
DE	Arbeitsschutzgesetz (ArbSchG) Arbeitsstättenverordnung (ArbStättV) DGUV Information 204-022 Erste-Hilfe im Betrieb Betriebssicherheitsverordnung (BetrSichV) Gefahrstoffverordnung (GefStoffV) DIN EN 15154-5:2019-12	Competent person (befähigte Person)	Regular inspection of emergency showers and eyewash stations based on risk assessment, but a functional inspection and inspectional of effectiveness of technical protective measures at least every third year. A general inspection of the functionality at least monthly and annual maintenance.
ES	RD 656/2017, of June 23, which approves Chemical Substances Storage regulation and its Complementary Technical Instructions MIE APQ 0 to 10. UNE-EN 15154: 2007. Emergency safety showers	Official inspections by accredited company (OCA) authorised by ENAC. On-site inspection by competent person.	Regular and official inspections according to Royal Decree 656/2017 its Complementary Technical Instructions: every 5 years.
FR	Labor Code Art R4224-17 to 19 relating to site and installation maintenance Code du travail article R4224-17 à 19 relatifs à la maintenance du site et de ses installations https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532199/ NF X15-221 - voluntary standard for insurance	On-site inspection by competent person	Regular inspection of emergency showers and eyewash stations based on risk assessment, but at least monthly (Best practice).
IT	Legislative Decree 9/04/2008 n.81 Decree 15/07/2003 n.388 UNI EN 15154-2:2007 (Eye washers) UNI EN 15154-1:2007 (Emergency showers)	Competent person.	Functional test (as for [2], [3], [4]) every month or in accordance with manufacturer's instructions. Maintenance every 6 months.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (Journal of Laws 2003, number 169, item 1650) Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Dz.U. 2008 nr 199 poz. 1228)	Competent person.	Functional test (every month or in accordance with manufacturer's instructions. Maintenance every 6 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) BS EN 15154 – Safety Shower Stations	Competent person	Regular maintenance of all safety critical equipment. Regular inspections of all plumbed-in safety showers to ensure appropriate operation, based on risk assessment and manufacturer's instructions. Regular inspections of all plumbed-in eyewash stations to ensure appropriate operation, based on risk assessment and manufacturer's instructions.
SK	STN EN 15154-2 Emergency safety showers - Part 2: Plumbed-in eye wash units STN EN 15154-4 Emergency safety showers - Part 4: Non plumbed-in eyewash units	Competent and qualified person	Monthly functionality test (performed by user) and annual inspection (performed by qualified person)
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Health and Safety (First-Aid) Regulations 1981 (legislation.gov.uk) The Health and Safety (First-Aid) Regulations (Northern Ireland) 1982 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) BS EN 15154 – Safety Shower Stations	Competent person	Regular maintenance of all safety critical equipment. Regular inspections of all plumbed-in safety showers to ensure appropriate operation, based on risk assessment and manufacturer's instructions. Regular inspections of all plumbed-in eyewash stations to ensure appropriate operation, based on risk assessment and manufacturer's instructions.