AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Sewage pumping Stations
APM Object	CT.SEWAGE.SEWAGEPUMP
APM Description	Pumping stations / pumps, in take filters, operation panels, telemetry/sensors and alarms.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Waste water pumps Waste macerator pumps Drainage Systems (Gravity system)	**Related CT Areas:**	CT.FAC.DRAIN		

Scope

Any site where pumping stations are operated to pump sewage from site into the foul networks.
This standard does not cover sewage treatment plants.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In line with manufacturers requirements but at least monthly.	Regular inspection and maintenance of pumps and clearance of any filters and telemetry/sensors to ensure correct operation. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	2	In line with manufacturers requirements but at least every 3 months.	Regular maintenance (cleaning and testing) of other associated assets e.g. operational panel, alarms etc.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	3	In line with drainage survey findings.	Regular flushing of the system to remove deposits.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)	PM					EVID		
All	4	As per 1- 3 unless stated in the Permit.	If pump system is used to discharge treated sewage into the environment, septic tank or treatment system, a permit might be required or in place. The discharge to a sewer network may also need a permit from the utility company. The permit could determine the frequency of inspections and maintenance. Ensure current permit or discharge consent stored on Document Management System.	Competent person	Maintenance logbook Inspection records, report or certificate Operating logbook Permit (where appliable)						Doc Check		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

ALL	No region specific legislation specified	N/A	N/A
CZ	Water Act No. 258/2000 Coll. Act No. 274/2001 Coll., on Water supply and sewerage systems for public use	N/A	The discharge to a sewer network needs an agreement with a network operator. The agreement could determine maintenance/inspection requirements.
DE	Wasserhaushaltsgesetz (WHG) §60 DIN 1986 - Entwässerungsanlagen für Gebäude und Grundstücke DIN EN 12050-1 Abwasserhebeanlagen für die Gebäude- und Grundstücksentwässerung - Bau- und Prüfgrundsätze - Teil 1: Fäkalienhebeanlagen entsprechen.	Competent person (befähigte Person).	Prior first use, the tightness of the facility has to be checked. Regular visual inspections of structural condition of the system. Monthly checks of the operational capability should be conducted by the operator, by observing at least two system cycles. Regular maintenance at least every 3 months. Regular flushing of the system at least every 2 years.
ES	RD 1644/2008, which establishes the rules for marketing and commissioning of the machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. RD1435/1992, of November 27, which establishes the regulation of the Directive 89/392/CEE, related to the approach to the regulation of the member Estates related to machines.	Competent person.	Maintenance follow manufacturer's instructions. Regular inspections and checks.
FR	No additional requirements Observe local site permit.	N/A	N/A
IT	UNI EN 12050-1:2015 (Sewage lifting plants) UNI EN 15885:2018 (Restoration, repair, replacement and maintenance of wastewater disposal installations) UNI EN 13508-1:2012 (wastewater disposal installations evaluation) UNI EN 752:2017 (Drain connections and sewer collectors outside buildings)	Competent person.	Maintenance in accordance with manufacturer's instructions. The periodicity of the maintenance activities is not set by Italian legislation
PL	Act of 20 July 2017 on water law (Journal of Laws 2021, item 624) Act of 7 July 1994 on construction law (Journal of Laws 2020, item 1333) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028) Act of 27 April 2001 on environmental law (Journal of Law 2020, item 1219) Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	N/A	N/A
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.
SK	Act No. 124/2006 Coll. on safety and health at work	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations (Northern Ireland) 1999	Competent person.	Based on risk assessment (use and environment) and manufacturer's recommendations.