AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Backflow prevention devices
APM Object	CT.WATER.BACKFLOW
APM Description	Water systems (drinking, sanitary and process water)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	WTR.SUPPLY.VALVES BLDG.INT	**Related CT Areas:**	Not Specified		

Scope

All sites are required to have backflow prevention devices to avoid contaminated water flowing back and contaminating the system or mains supply pipework.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Based on risk assessment, but at least annually. Where repair works or new work is undertaken, inspect work following completion.	Regular inspection and testing of water systems to ensure that backflow preventers (e.g. double check valves, pipe interrupters) are present and operating correctly.	Competent person, best practice to outsource	Inspection records, report or certificate. Maintenance and operating logbook	PM					EVID		
IT	2	Every 6 months	Inspection of the backflow protection devices	No additional requirements	No additional requirements	PM					EVID		
IT	3	Every 12 months	Maintenance (functional test) of the devices	No additional requirements	No additional requirements	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months.

DE	VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung DIN EN 806-5 - Technische Regeln für Trinkwasser-Installationen - Teil 5: Betrieb und Wartung	Competent person (befähigte Person) of a registered installation company	Regular inspection and maintenance of backflow preventers based on risk assessment, but at least annually.
ES	Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4). Section 3.3.	Competent person of a registered installation company	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.
FR	Departmental Health Regulations - article 16.3 https://www.paca.ars.sante.fr/sites/default/files/2017-01/RSD_13_ars_paca_01.pdf	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months
IT	Legislative Decree 02/02/2001 n. 31 Legislative Decree 04/09/2008 n.81 UNI EN 806-5:2012 (Maintenance) UNI EN 1717:2002 (Backflow protection devices)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspection of backflow protection devices every 6 months and maintenance (functional test) every 12 months.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 July 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028) Act of 27 April 2001 on Environmental Law (Journal of Law 2020, item 1219) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	N/A	N/A
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.
SK	Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply STN EN 1717 Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow	Competent person, best practice to outsource to specialist	Functional test intervals depend on the type of construction site.
UK	The Water Supply (Water Fittings) (England and Wales) Regulations 1999 The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009 Water Supply (Water Fittings) (Scotland) Byelaws 2014	Competent person, best practice to outsource to specialist.	Regular inspection of all backflow preventers based on manufacturer's instructions and risk assessment.