AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Cold water services
APM Object	CT.WATER.COLDSERVICE
APM Description	Cold water storage and supply systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.LEGIONELLA, CT.WATER.COOLINGTOWERS, CT.WATER.HOTSERVICE and CT.SAFE.WASH		

Scope

Any site with cold water services, such as water supply storage tanks and distribution network, that might lead to a risk of employees contracting legionella disease (or other water borne pathogen).
Legionella risk assessment requirements are covered under CT.WATER.LEGIONELLA. Hot water systems are covered in CT.WATER.HOTSERVICE and cooling towers in CT.WATER.COOLINGTOWERS.
Additional requirements of emergency showers and eyewashes are covered under CT.SAFE.WASH

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Based on risk assessment, but at least weekly.	Flush through water distribution dead legs to drain for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. (Programme removal of dead legs ASAP) These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella Risk Assessment Inspection and checks records, report or certificate. Schematic diagram of cold water services. Legionella log book (results of temperature checks, management actions etc)		CT						
All		Based on risk assessment, but at least weekly.	Flush through satellite/sentinel outlets and taps (rarely used) for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services		CT						
All		Based on risk assessment, but at least weekly.	Staff showers, emergency eyewash and emergency showers need to be flushed through for minimum of 5 minutes, ensuring period of flushing is sufficient to remove all stagnant water. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services		CT						
All		Based on risk assessment, but at least monthly.	Check that temperature is <20°C after running the water for up to two minutes in the sentinel taps. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services			CT					
All		Based on risk assessment, but at least every 6 months	Check tank water temperature remote from ball valve and mains temperature at ball valve is <20°C. Note maximum temperatures recorded by fixed max/min thermometers where fitted. These locations should be identified in the Legionella Risk Assessment.	Competent person, usually sourced internally.	Legionella log book (results of temperature checks, management actions etc) Legionella Risk assessment Schematic diagram of all cold water services					CT			

All		Based on risk assessment and manufacturers instructions but at least annually	Visually inspect cold water storage tanks and carry out remedial work where necessary. Check representative taps for temperature as above on a rotational basis	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		
All		Based on risk assessment and manufacturers instructions but at least annually	Check thermal insulation of cold water storage tanks and associated pipework to ensure it is intact	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		
All		Based on risk assessment and manufacturers instructions but at least annually	Service and disinfect base exchange softeners	Competent person	Inspection and checks records, report or certificate Legionella Risk Assessment Schematic diagram of cold water services.						CT		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist	Carryout checks every 12 months.
DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung VDI/BTGA/ZVSHK 6023 Blatt 2 - Hygiene in Trinkwasser-Installationen - Gefährdungsanalyse	Accredited specialist company (Zugelassener Fachbetrieb)	Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in line with risk assessment, but at least weekly. Mechanical filters: backwashing is triggered every six months for backwashable filters or replacement of the filter insert for non-backwashable filters. Shut-off valves: regular actuation of the valves by turning so that they remain mobile. Water taps / extraction fittings: use daily if possible, at least every seven days. Maintenance of softening unit every 6 months. Maintenance of Pressure reducer every 12 months.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. RD 865/2003, laying down the hygienic-sanitary criteria for the prevention and control of legionellosis. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Periodic servicing: Competent person.	Annual inspection, cleaning, disinfection and sampling of equipment.
FR	Labor Code article R4225-4 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/	Competent person, best practice to outsource to specialist	Best Practice: Annual inspection, cleaning, disinfection and sampling of equipment.
IT	Legislative Decree 04/09/2008 n.81, Annex IV Legislative Decree 02/02/2001 n. 31, Annex I Guidelines for prevention and control of legionnaires' disease Min salute 2015 UNI EN 918:2014(hot and cold water supply and distribution systems). UNI EN 806-5:2012 (operation and maintenance of installations inside buildings for the conveyance of water intended for human consumption) UNI EN ISO 11731: 2017 (cultural methods for the determination of the charge in water parameters)	Qualified person	Control measurements are required. Frequency of periodical check and inspection are not specified by Italian legislation; however the best practices, in accordance with the guidelines of the Ministry of health regarding the water system maintenance are: - Descaling of less worn elements by immersion in acid solution (sulfamic acid, acetic acid, etc.) and subsequent disinfection (not less than 30 minutes, in cold water containing at least 50 mg/L free chlorine). - Periodically replacement of faucet valve, faucet water filters, shower heads and pipes, as well as any other discontinuity element. The frequency of replacement is usually a function of water characteristics. - Microfiltering that allows the removal of Legionella from the water exiting at the point of use, through a mechanical barrier. - Thermal treatment at temperatures between 50 and 55 degrees. In case of presence of Legionella,
PL	Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624) Act of 7 June 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in accordance with manufacturer's instructions. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in accordance with manufacturer's instructions. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in accordance with manufacturer's instructions. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant water. Frequency in accordance with manufacturer's instructions.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in line with risk assessment, but at least 6-monthly. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in line with risk assessment, but at least monthly. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis. Frequency in line with risk assessment, but at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in line with risk assessment, but at least annually. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant
SK	Act No. 442/2002 Coll. on public water supply and public sewerage Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Annual water quality control or control based at request from the regional public health office. Periodic inspection of technical equipment.

UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk) Legionnaires' disease: The control of legionella bacteria in water systems. Approved Code of Practice and guidance on regulations L8 (hse.gov.uk) HSG 274 Part 2 - The control of legionella bacteria in hot and cold water systems (legionellacontrol.com)	Regular checks conducted by internal trained employee Regular inspections conducted by competent person, best practice to outsource to specialist.	Regular check of tank water temperature remote from ball valve and mains temperature at ball valve in line with risk assessment, but at least 6-monthly. Regular checks to ensure temperature is below 20°C after running the water for up to two minutes in the sentinel taps in line with risk assessment, but at least monthly. Regular visual inspection of cold water storage tanks and undertaking of remedial work where necessary. Check representative taps for temperature as above on a rotational basis. Frequency in line with risk assessment, but at least annually. Regular check of thermal insulation of cold water storage tanks and undertaking remedial work where necessary. Frequency in line with risk assessment, but at least annually. Regular flushing of dead legs to drain, ensuring period of flushing is sufficient to remove all stagnant