AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Legionella Risk Assessment (LRA)
APM Object	CT.WATER.LEGIONELLA
APM Description	Hot and cold-water systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	CT.WATER.COLDSERVICE CT.WATER.HOTSERVICE CT.WATER.COOLINGTOWERS CT.SAFE.WASH		

Scope

All sites are required to conduct a legionella risk assessment to ensure that hot and cold-water systems are managed effectively to manage the risk of legionella. This includes fire sprinkler systems.
Specific inspection requirements for the physical water systems are covered under CT.WATER.COLDSERVICE, CT.WATER.HOTSERVICE and CT.WATER.COOLINGTOWERS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Before the installation is occupied. Regularly, at intervals identified in the risk assessment, but at least every 2 years for low-risk systems. Following any significant water system changes or following	Conduct and maintain up to date a legionella risk assessment of all water systems within your installation, ensure reviewed and approved by Duty Holder	Competent person, best practice to outsource	Legionella risk assessment. Inspection records, report or certificate. Logbook Record of incidents. Records of remedial actions taken. Schematic diagram of all water							CT	

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Act No. 258/2000 Coll.	Accredited company	Carry out regular analyses according to the scope of the legislation.

DE	Trinkwasserverordnung (TrinkwV)	Health department (Gesundheitsamt) or Accredited institutions (zugelassene Institute/Prüfstellen)	First tests must be conducted within 3 – 12 months after the installation of a water supply system. Based on risk assessment but at least every 3 years. Water samples are taken both from hot and cold-water points. Legionella analysis of drinking water samples for hot water installations with more than 400L storage volume or hot water pipes with more than 3L content between the water heater and the tapping point. Frequency of sampling is 3 years. Additional drinking water analysis for legionella and pseudomonas based on risk assessment for cold and hot water systems, but at least every 3 years.
ES	RD 487/2022, of June 21, which establishes the health requirements for the prevention and control of legionellosis.	Legionella inspections: authorised companies (by ENAC).	- Sanitary water systems: Legionella spp .(UFC/L) : Quarterly Aerobes (UFC/ml) : Quarterly Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily, rotating. Turbidity (UNF)(2) :Weekly Biocide (3) : Diary, if applicable, with automatic continuous reading. Total iron (µg/L) : Quarterly Conductivity: N/A. - Cooling towers and evaporative condensers.: Legionella spp .(UFC/L) : Monthly. Aerobes (UFC/ml) : Quarterly Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily. Turbidity (UNF)(2) :Weekly Biocide (3) : Diary, if applicable, where appropriate, with automatic continuous reading. Total iron (µg/L) : Monthly. Conductivity: Monthly. - Installations with heated water systems or with temperatures similar to heated ones and aerosolization with agitation and recirculation through high-speed jets and/or air injection, etc. Legionella spp .(UFC/L) : Monthly. Aerobes (UFC/ml) : Monthly. Ph (1) (2) : Daily. Temperature (ºC)(2) : Daily. Turbidity (UNF)(2) :Daily. Biocide (3) : Diary, if applicable, where appropriate, with automatic continuous reading. Total iron (µg/L) : N/A. Conductivity: N/A. -Evaporative spray cooling devices using aerosol cooling elements. Legionella spp .(UFC/L) : Biannual. Aerobes (UFC/ml) : Biannual. Ph (1) (2) : Monthly. Temperature (ºC)(2) : Monthly. Turbidity (UNF)(2) :Monthly. Biocide (3) : Monthly. Total iron (µg/L) : N/A.Conductivity: N/A. (1) Depending on the biocide. (2) In the case of pH, temperature and turbidity, it can be controlled in situ, preferably with automatic continuous reading. (3) In the case of using physical disinfection treatments, the control of the biocide must be replaced by controls that ensure the correct functioning of the disinfection system. (4) If necessary, other parameters that are considered useful in determining the quality of the water or the effectiveness of the water treatment program will be included. However, the health authority may exempt the person who owns the facility from analyzing any of these parameters if, based on the type of facility in question, their presence in the water at levels such that they pose a risk is not likely to health.
FR	Site Authorization Permit can require periodic exams. See CT. WATER.COOLINGTOWERS	N/A	N/A
IT	Legislative Decree 04/09/2008 n.81	The Employer	All sites need to have a legionella risk assessment that must be updated every three years or in case of significant changes in work activity.
PL	Regulation of Health Minister of 22 April 2005 on harmful biological agents for health in the work environment and protection of the health of workers professionally exposed to these factors (Journal of Laws 2005, number 81, item 716) Regulation of Health Minister of 7 December 2017 on the quality of water intended for human consumption (Journal of Laws 2017, item 2294) Act of 7 July 2001 on collective water supply and collective sewage disposal (Journal of Laws 2020, item 2028)	The State Sanitary Inspection	All sites need to have a legionella risk assessment. Review frequency not stipulated by regulations.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person	All sites need to have an initial legionella risk assessment. Review frequency is based on findings of risk assessment, but at least every 1-2 years, and following any changes to the water systems.
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 247/2017 Coll. on details of drinking water quality, drinking water quality control, monitoring and risk management program for drinking water supply STN P ISO/TS 12869 Water quality. Detection and quantification of Legionella	Competent person, best practice to outsource to specialist	Annual quality control or control based at request from the regional public health office.
UK	The Control of Substances Hazardous to Health Regulations 2002 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003 (legislation.gov.uk) Legionnaires' disease: The control of legionella bacteria in water systems. Approved Code of Practice and guidance on regulations L8 (hse.gov.uk)	Competent person, best practice to outsource to specialist	All sites need to have an initial legionella risk assessment. Review frequency is based on findings of risk assessment, but at least every 2 years, and following any changes to the water systems.