AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Reverse osmosis water systems
APM Object	CT.WATER.OSMOSISSYS
APM Description	RO water systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site where Reverse Osmosis (RO) systems are used to purify and filter water.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendation	Routine maintenance to ensure optimal operation of the RO system, including pre- and post-filter and membrane replacements.	Competent person	Maintenance logbook	PM					EVID		
All		In accordance with manufacturer's instructions and recommendation, but at least every 12 months.	Disinfection and cleaning of RO system tank and associated pipes to manage fouling	Competent person	Inspection records, report or certificate. Risk assessment						CT		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
ALL	No region specific legislation specified	N/A	N/A
CZ	Government Regulation No. 101/2005 Coll., Nam. Government Regulation No. 378/2001 Coll.	Competent person, best practices for outsourcing to a specialist.	Carryout checks every 12 months.

DE	Trinkwasserverordnung (TrinkwV) VDI 3810 Blatt 2 - Betreiben und Instandhalten von Gebäuden und gebäudetechnischen Anlagen - Trinkwasser-Installationen VDI 6023 Blatt 3 - Hygiene in Trinkwasser-Installationen - Betrieb und Instandhaltung DIN EN 806-5 - Technische Regeln für Trinkwasser-Installationen - Teil 5: Betrieb und Wartung	Competent person (befähigte Person)of a registered installation company (Zugelassenes Fachbetrieb)	Change of filter at least every 6 months, and the membrane at least every 24 months. Best practice to disinfect before any filter change. The system must be flushed regularly, at least after every change of the membrane or filter. In accordance with manufacturer's instructions and recommendations.
ES	RD 140/2003, which establishes the health criteria of the quality of water for human consumption. Building Technical Code (CTE). - Health Standards Basic Document: water supply (HS4)	Competent person	Change of membranes and/or other filtering devices according to the periodicity and instructions of the manufacturer or supplier
FR	Labor Code article R4225-4 https://www.legifrance.gouv.fr/codes/id/LEGISCTA000018532171/	Competent person, best practice to outsource to specialist	Best Practice: Change of membranes and/or other filtering devices according to the periodicity and instructions of the manufacturer or supplier
IT	Legislative Decree 04/09/2008 n.81 Legislative Decree 02/02/2001 n. 31	Qualified person.	Maintenance in accordance with manufacturer's instructions. The periodicity of the maintenance activities is not set by Italian legislation.
PL	Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624)	N/A	N/A
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person	Regular maintenance of RO systems in accordance with manufacturer's instructions or recommendations. Regular disinfection of tanks and pipes to avoid fouling, at least yearly.
SK	Act No. 355/2007 on the protection, promotion and development of public health Ordinance No. 550/2007 Coll. on details of requirements for products intended to come into contact with drinking water	Certified and accredited person	Regular inspection on annual basis or based at current user need.
UK	Health and Safety at Work etc. Act 1974 (legislation.gov.uk) Health and Safety at Work (Northern Ireland) Order 1978 (legislation.gov.uk)	Competent person	Regular maintenance of RO systems in accordance with manufacturer's instructions or recommendations. Regular disinfection of tanks and pipes to avoid fouling, at least yearly.