# AMAZON BASE BUILDING COMPLIANCE STANDARD

| | |
|---|---|
| **Task Title** | Abrasive wheels |
| **APM Object** | CT.WORK.ABRASIVE |
| **APM Description** | Abrasive wheels |
| **General tasks always required** | Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc.<br>Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required<br>Add notes for each observation and create a FWO if necessary to eliminate defects<br>Use appropriate tools, chemicals and industry standard practices (RME policy permitting)<br>Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE)<br>To suggest improvements please raise a SIM or contact document authors<br>Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA)<br>SIM - Link to SIM template |

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| **Last Update: (Version)** | ago-23 | **Last Update Change Detail:** | Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft. | **Activities may be covered by No-Go restrictions:** | Not Specified | **Special Certification Required:** | **Delivered By:** |
| **Evidenced part or full by PM:** | Not Specified | **Related BBM PM:** | Not Specified | **Related CT Areas:** | Not Specified | | |

## Scope

Any site where employees use abrasive wheels, whether fixed or portable.

## Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

## Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

## Key to Abbreviations

The key to the below document is as follows:
**CT** - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
**CT*** - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
**(CT)** - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
**PM** - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
**(PM)** - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
**EVID** - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
**EVID*** - Conditional requirement to upload evidence at the interval provided
**N A R** - No Additional Requirement

## Required Tasks

| Region | Task Index | Task Frequency | Task Requirements | Qualification of Inspector | Records Required | PM | Weekly | Monthly | 3 Monthly | 6 Monthly | 12 Monthly | 24 Monthly | Additional |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| All | 1 | In accordance with manufacturer's instructions and recommendations. | Regular maintenance of equipment. | Competent person. | Inspection records, report or certificate<br>Risk assessment<br>Maintenance logbook. | | | CT* | | | CT* | | |
| All | 2 | Based on risk assessment, but at least every 12 months. | Regular inspection of its integrity to ensure safe use. If defects are identified, prevent subsequent use through quarantine prior repair or destruction and replacement - do Not use. Report issue. | Competent person. | Inspection records, report or certificate<br>Risk assessment<br>Maintenance logbook. | | | | | | CT | | |
| IT | 7 | 6 months | Inspection as per [2]. | No additional requirements | CE Declaration of conformity. Records to be kept for at least 3 years. | | | | | CT | | | |
| ROI | 6 | No additional requirements | Inspection as per [2]. | No additional requirements | Records need to be kept for at least 5 years. | | | | | | CT | | |
| SK | 8 | Every 6 months | Inspection of portable, hand-held abrasive wheels | No additional requirements | Records need to be kept for at least 5 years. | | | | | CT | | | |

| | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| UK | 3 | Weekly for 110v grinders.<br>Daily for 240v grinders. | Safety checks to be carried out on portable electric grinders. | No additional requirements | Record of pre use checks / inspections | | | | | | EVID | | These are pre-use checks |
| UK | 4 | Monthly for 110v grinders.<br>Weekly for 240v grinders. | Formal visual inspection to be carried out on portable electric grinders. | No additional requirements | Record of inspections | | CT* | CT* | | | | | |
| UK | 5 | 3-monthly for 110v grinders.<br>Monthly for 240v grinders. | Formal inspection and testing to be carried out on portable electric grinders. | No additional requirements | Record of inspections | | | CT* | CT* | | | | |

| Related Regional Legislation | | | |
|---|---|---|---|
| **Region** | **Relevant legislation** | **Vendor Certification** | **Statutory requirement** |
| CZ | Regulation No. 101/2005 Coll.<br>Regulation No. 378/2001 Coll. | Competent person, best practice to outsource to specialist company. | Inspections carried out every 12 months. |
| DE | Betriebssicherheitsverordnung (BetrSichV)<br>Technische Regeln für Betriebssicherheit:<br>TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen<br>DGUV Regel 100-500 Section 2.19 and Section 2.25<br>DGUV Vorschrift 3 - Elektrische Anlagen und Betriebsmittel<br>DGUV Information 209-002 - Grinders | Competent person (befähigte Person). | Visual inspection before clamping the abrasive wheel and dry run. Inspection frequency based on risk assessment.<br>Electrical safety tests every year according to DGUV Vorschrift 3, as well as before commissioning and after repairs |
| ES | RD 1644/2008, of October 10, which establishes the rules for the marketing and commissioning of machines.<br>RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment | Competent person. | Maintenance follow manufacturer's instructions. Regular inspections and checks. |
| FR | 28 July 1961 Decree<br>"Arrêté du 28 juillet 1961 relatif aux mesures particulieres de securite relatives a l'utilisation des meules et machines a meuler"<br>https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000656198/ | Qualified person. | Daily visual check. Regular maintenance and inspections. |
| IT | Law n. 320/1990<br>UNI EN 12413:2020 (Safety requirements for rigid abrasives)<br>UNI EN 13743:2017 (Safety requirements for flexible abrasives)<br>ISO 525:2020 (Bonded abrasive products -- Shape types, designation and marking)<br>UNI EN 13236:2019 (Safety requirements for super-abrasive products)<br>UNI EN ISO 6103:2014 (Permissible unbalance of grinding wheels)<br>UNI EN ISO 16089:2016 (Safety requirements for grinding machines)<br>ISO 13942:2019 (Bonded abrasive products -- Limit deviations and run-out tolerances)<br>Directive 2006/42/CE on machinery<br>D. Lgs 81/08 | Qualified person. | Maintenance follow manufacturer's instructions. |
| PL | Regulation of Minister of Labour and Social Policy of 26 September 1997on general provisions for occupational health and safety (Journal of Laws 2003 No 169 item 1650) as amended.<br>Regulation of the Minister of Economy of 30 October 2002 on the minimum requirements for occupational health and safety in the use of machines by employees at work (Journal of Laws 2002, number 191, item 1596)<br>Regulation of the Minister of Economy of October 21, 2008 on essential requirements for machines (Journal of Laws 2008, number 199, item 1228) | Competent person or person with Electrical qualification | Inspection frequency follow manufacturer's instructions, or internal policies and procedures. |
| ROI | Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)<br>S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) | Competent person, best practice to outsource to specialist company. | Initial inspection before it is first used or assembled, and periodic inspections based on risk assessment. |
| SK | Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts<br>Government Regulation No. 392/2006 Coll. on minimum safety and health requirements for the use of work equipment<br>Ordinance No. 59/1982 Coll. laying down the basic requirements to ensure the safety of work and technical equipment<br>STN EN 33 1610/Z1: Verification and checking of electrical appliances during use | Competent person. | Abrasive wheels – portable – to be held in the hand: Control before first use, inspections at least every 6 months as defined by STN EN 33 1610/Z1.<br><br>Abrasive wheels – portable: Control before first use, inspections at least every 12 months as defined by STN EN 33 1610/Z1.<br><br>Abrasive wheels – not portable (GENERAL): Inspection after installation and before first use. Further inspection intervals to be defined by employer. |

| | | | |
|---|---|---|---|
| UK | The Provision and Use of Work Equipment Regulations 1998<br>Safety in the use of abrasive wheels; Revised in line with the Provision and Use of Work Equipment Regulations 1998 (PUWER 98); HSG17 (hse.gov.uk)<br>Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 | Competent person. | Maintenance. Regular inspections based on risk assessment. Additional frequency for portable grinders based on voltage. |